

Technical Working Group Meeting

Proposed GWP Limit for New Stationary Air Conditioning Equipment

August 6, 2019

Kathryn Kynett

Greenhouse Gas Reduction Strategy Section

Research Division

California Air Resources Board

kathryn.kynett@arb.ca.gov

Phone: (916) 323-8598



Today's Presentation




- Background
- Regulatory Proposal and Process
- Economic Analysis (SRIA)
- Enforcement Requirements
- Alternatives
- Next Steps
- Discussion


Background

Hydrofluorocarbon (HFC) Emissions in California

Year 2018



Year 2030 BAU




Majority of Emissions from AC Sector

Increasing Demand for AC in California

Population Growth


California has experienced rapid population growth



SOURCE: California Department of Finance estimates.

Climate Change

Observed Change in Annual Temperatures
(1986-2016 compared to 1901-1960)













Proposed Limit on Stationary Air Conditioning Equipment

Proposed GWP Limit on AC Equipment




- Effective January 1, 2023, new air conditioning systems must use a refrigerant with a global warming potential (GWP) value < 750
- Effective January 1, 2024, new chillers must use a refrigerant with a GWP value < 750 (consistent with SB 1013)

Status of <750 GWP Alternatives


Category	Global Status	California Status
window/wall + portable		
packaged terminal		
ductless split systems		
ducted split + package systems		
VRV/VRF		

 commercially available

 Product under development or pending codes/standards updates

Regulatory Processes Overview

Rulemaking Overview



Economic Analysis: Standardized Regulatory Impact Assessment (SRIA)

- Required if estimated economic impact exceeds \$50 million, i.e., “major” regulation
 - Costs and benefits to businesses, individuals, and the environment
 - Macroeconomic impacts (jobs, investment, income) in California
 - Fiscal impacts
 - Costs and benefits for regulatory alternatives

CARB seeks and considers information given by stakeholders and interested parties

SRIA Overview (continued)




- Baseline costs – costs of traditional AC systems (first + ongoing)
- Added costs – how much more does it cost for < 750 GWP equipment compared to baseline?
- Growth rates of affected equipment

Economic Analysis (SRIA)

Preliminary Analysis and Input Requested

- a. Affected Entities
- b. Cost by Equipment Category
- c. California AC Market
- d. Component Replacements (Existing Systems)

SRIA – Who is affected by the proposed regulation?



AC Equipment Categories

small self-
contained AC +
dehumidifiers



portable



window and
through-the-wall



packaged terminal AC (PTAC)
packaged terminal HP (PTHP)



dehumidifiers

residential +
commercial
(ducted/ductless)



split and packaged AC/HP
<65,000 BTUH (Residential)



split and packaged AC/HP
≥65,000 BTUH (Commercial)



chillers
(Commercial)


1. Are we capturing all the equipment types that would be affected by the proposed regulation?
2. What is the best way to distinguish residential versus commercial equipment? Capacity?

What added costs are associated with a refrigerant change?



- Factory changes
 - Design changes
 - Performance optimization
 - Certify new products
 - Additional safety features (sensors for A2Ls)
 - Transportation costs
 - Technician training
 - Different tools
-
- Specific to California market
 - AC costs come down over time (learning curve)

Residential Life Cycle AC Cost Breakdown



Room AC + Dehumidifiers

Preliminary Cost Estimates (stakeholder input/reports)

small self-
contained AC +
dehumidifiers



portable



window and
through-the-wall




packaged terminal AC (PTAC)
packaged terminal HP (PTHP)



dehumidifiers

- How many self-contained AC + dehumidifiers are shipped to California?
- Some units are sold with R-32 at no added cost. What % of the market is now R-32?
- What alternatives refrigerants are being considered for PTHP and dehumidifiers?



R-32 available today
(GWP <750)

Residential AC

Preliminary Cost Estimates (stakeholder input/reports)

packaged systems



split systems (ducted)



split systems (ductless)



	Baseline (Avg.)	Added Cost
Equipment	\$4,000	5-15%
Installation	\$3,200	0-10%
Maintenance/Repairs	?	0-10%

Commercial AC Preliminary Cost Estimates (stakeholder input/reports)

Small – Medium (<50 lb.)



65,000 – 185,000 BTUH
(5 to 15 Ton)


Large (50 lb. +)



185,000 BTUH+
(16 to 60 Ton)

	Baseline (Avg.)	Added Cost	Baseline (Avg.)	Added Cost
Equipment	\$9,000	5-15%	\$25,000	5-15%
Installation	\$7,200	0-10%	\$20,200	0-10%
Maintenance/ Repairs	?	0-10%	?	0-10%

Variable Refrigerant Flow/Volume (VRF/VRV) Preliminary Cost Estimates (stakeholder input/reports)



	R-410A	Added Cost
Equipment	\$30,000	5-15%
Installation	\$24,000	0-10%
Maintenance/Repairs	?	0-10%

1. How much more energy efficient are these systems?
2. How much do these systems leak?

California Market Characterization – How many units?

In 2018...



14 million homes
100,000 new homes

54% existing homes have a central AC
100% new homes install a central AC
system lifetime: 15 years

7.6 million existing systems
504,000 system replacements
100,000 new systems

AHRI Shipment Data: 640,000 units (8% of U.S. Sales)
37,000 units (12% of U.S. Sales)




>700,000 commercial and other
nonresidential buildings

100% of new buildings have an AC
System lifetime 15 years


900,000 existing systems
60,000 system replacements
10,000 new systems

...proposed regulation takes effect in 2023

Market Characterization – System Replacement and Repairs



1. What portion of shipments are for full system changeouts versus single component replacements?
2. How can we allow for component replacement?




Enforcement Requirements (Stakeholder Input Requested)





Enforcement Requirements

- Recordkeeping (manufacturers/distributors)
- Date and refrigerant type included on label



Dates can currently be encoded, what would the impact be of a requirement to use a format that clearly indicates the year?



DALLAS, TEXAS		ASSEMBLED IN MEXICO	
M/N 13HPX - 048 - 230 - 18			
S/N 1913H18804			
CONTAINS HFC - 410A		DESIGN PRESSURE	
FACTORY CHARGE		HI	446 PSIG
9 LBS 11 OZS		LO	236 PSIG
ELECTRICAL RATING		NOMINAL VOLTS: 208/230	
1 PH	60 HZ	MIN 197	MAX 253
COMPRESSOR		FAN MOTOR	
PH	1	PH	1
RLA	21.8	FLA	1.7
LRA	99.0	HP	1/4
MIN. CKT. AMPACITY AMPERAGE MINIMUM	28.8	MAX FUSE OR CKT. BKR. FUSIBLE/COUPE CIRCUIT (HACR PER NEC)	50
			
1913H18804			
			
CONFORMS TO UL STD 1995 CERTIFIED TO CSA STD C22.2 NO. 231			
FOR OUTDOOR USE			

Enforcement Requirements

Residential Central AC

New Construction Market



Typical Distribution Chain

Replacement Market



Typical Distribution Chain



Direct-to-Dealer Distribution Chain

Do other types of equipment also use these distribution pathways?

Regulatory Alternatives (Stakeholder Input Requested)

Next Steps and Anticipated Timelines



Stationary AC Equipment	
Public workshops and Stakeholder meetings	1 st workshop: October 2018
	Technical Working Group: March 6, 2019
	Technical Working Group: August 6, 2019
	2 nd Workshop: Fall 2019
45-Day Notice	March/April 2020
Board Meeting	May 2020
Regulation Effective Date	January 1, 2023

To consider your input on the cost data in our economic analysis, we need your feedback by **September 1**

Feedback and Questions – Contact Us

Richie Kaur, Proposed HFC Regulations on Refrigeration, Virgin Refrigerant Sales
Limit

richie.kaur@arb.ca.gov; (916) 323-1506

Kathryn Kynett, Proposed HFC Regulation on AC

kathryn.kynett@arb.ca.gov; (916) 322-8598

Glenn Gallagher, SB1013 and Proposed HFC Regulations

glenn.gallagher@arb.ca.gov

Aanchal Kohli, Incentive Funding and Proposed HFC Regulations

aanchal.kohli@arb.ca.gov

Pamela Gupta, Manager, Greenhouse Gas Reduction Strategy Section

pamela.gupta@arb.ca.gov

Michael FitzGibbon, Branch Chief, Research Division

michael.fitzgibbon@arb.ca.gov

For more information, please visit:

[Stationary Hydrofluorocarbon Reduction Measures Website](#)



Technical Working Group Meeting Proposed HFC Limit for Stationary Refrigeration Equipment

August 6, 2019

Richie Kaur

Greenhouse Gas Reduction Strategy Section

Research Division

California Air Resources Board

Richie.kaur@arb.ca.gov

Phone: (916) 323-1506



Today's Presentation




- Background
- Proposed HFC Regulations
- Regulatory Process Overview
- Economic Analysis (SRIA)
- GWP Limit on Stationary Refrigeration Equipment
- Discussion Topics – Seeking Stakeholder Input
- Next Steps and Anticipated Timelines

Background


HFCs are the fastest growing greenhouse gases

- Currently 4% of California GHG emissions (**Increasing to 10% by 2030 under BAU**)
- SB 1383 reduction goal: 40% below 2013 levels by 2030 (**one-half of today's HFC emissions**)



Source: CARB, 2018

Sources of HFC Emissions in California



Year 2018

Source: CARB, 2018

Majority of Emissions from Refrigeration and AC Sector



Proposed HFC Regulations


Proposed HFC Reduction Measures Overview



- **Proposed Equipment GWP Limits (Board Hearing, May 2020)**
 - **Stationary Refrigeration:** New equipment containing more than 50 lbs. of refrigerant, GWP < 150, starting January 1, 2022
 - **Stationary AC:** New Equipment, GWP < 750, starting January 1, 2023
- **Proposed Virgin Refrigerant Sales Prohibition (Separate Board Hearing, TBD)**
 - No sales, distribution, or import for use in California, of virgin refrigerants with a GWP of 1500 or greater (GWP threshold still under consideration)

Regulatory Process Overview

Regulatory Process Overview



Economic Analysis: Standardized Regulatory Impact Assessment (SRIA) Overview

- Required if estimated economic impact (costs and savings) exceeds \$50 million, i.e., “major” regulation
- Included in the economics chapter in the ISOR (released as part of the 45-day notice)

- The SRIA includes:
 - Direct Costs and Benefits to Businesses, Individuals, Environment
 - Macroeconomic Impacts (jobs, investment, income) in California
 - Fiscal Impacts
 - Analysis of Regulatory Alternatives
- **CARB seeks and considers information given by stakeholders.**


Proposed GWP Limit on Stationary Refrigeration Equipment

Proposed GWP Limit on Refrigeration Equipment

- **New equipment containing more than 50 pounds of refrigerant,**
- **GWP < 150, January 1, 2022**
- **Affected End-uses**
 - Commercial Refrigeration – retail (supermarkets, grocery stores) + non-retail
 - Industrial Process Refrigeration – manufacturing and/or processing
 - Cold Storage – warehouses, packaging and storage facilities




Current HFC Use in Stationary Refrigeration > 50 lb. Systems in CA



- RMP – largest systems reporting refrigerant purchase, use and leaks since 2012
- 6,600 facilities; ~28,000 systems
- Total banked refrigerant: 17 MMT CO_2e
- Average GWP: 2,700

Low-GWP options for Stationary Refrigeration

End-Use Sector	System Sizes	Low-GWP Options Currently Available
Supermarkets and grocery stores	Large (≥ 2000 lb)	t-CO ₂ , HC/CO ₂ , NH ₃ /CO ₂ , HFO?
	Medium (200 – 2000 lb)	
	Small (50 – 200 lb)	t-CO ₂ , HCs, HFO?
Cold storage warehouses, Industrial refrigeration	All Sizes	Majority already use NH ₃ others: NH ₃ /CO ₂ , HFO?



100+ supermarkets in California using low-GWP refrigerants in 2018

Discussion Topics (Stakeholder Input Requested)

1. Economic Impacts
2. a) Enforcement Requirements; b) Definition of “New Refrigeration Equipment”
3. Feasibility of 150 GWP Limit for New and Existing Facilities
4. Feasibility of 750 GWP Limit on Refrigeration/Process Chillers
5. Regulatory Alternatives

Discussion Topics (Stakeholder Input Requested)

1. Economic Impacts

1. Economic Impacts

Data requested for SRIA:

- Growth rates of affected equipment
- Baseline costs – costs of traditional HFC systems (first + ongoing costs)
- Added costs – How much more does it cost for < 150 GWP systems compared to baseline?

End-user cost estimates will be discussed in this presentation

Commercial Refrigeration Preliminary Cost Estimates (stakeholder input/reports)



- Supermarkets: 45,000 sq. ft. size, average charge 3,500 lb.
- Grocery stores: 15,000 sq. ft. size, average charge 1,000 lb.
- Other: Non-retail and other retail

End-Use	Equipment Costs \$		Installation Costs \$		Routine Maintenance \$/year		Refrigerant \$/lb.		Added Electricity \$/year
	Baseline	Added (%)	Baseline	Added (%)	Baseline	Added (%)	Baseline	Added (%)	
Supermarkets	600,000 to 1M	15% to 20%	250,000 to 450,000	-10% to +10%	5,000 to 7,000	TBD	5 to 10	-30% to -50%	Potential Savings
Grocery Stores	200,000 to 300,000		90,000 to 140,000		2,000 to 3,000				
Other	Baseline: 30% lower than retail Added: Same as above								

Industrial Process Refrigeration & Cold Storage Except Chillers

Preliminary Cost Estimates (stakeholder input/reports)



- Large Facilities, Average Refrigerant Charge 8,500 lb.
- Medium and Small Facilities: Average Refrigerant Charge 1,000 lb.

Facility Size	Equipment Costs \$		Installation Costs \$		Routine Maintenance \$/year		Refrigerant \$/lb.		Added Electricity \$/year
	Baseline	Added (%)	Baseline	Added (%)	Baseline	Added (%)	Baseline	Added (%)	
Large	800,000 to 1.2M	15% to 20%	200,000 to 300,000	-10% to +10%	5,000 to 7,000	TBD	5 to 10	-30% to -50%	-10% to -20%
Medium and Small	200,000 to 400,000		50,000 to 100,000		2,000 to 3,000				

Discussion Topics (Stakeholder Input Requested)

2a. Enforcement Requirements

Enforcement Requirements

Manufacturers

- Recordkeeping
- Date and refrigerant type included on label

MODEL FAMILY: _____ RL	DATE 01/16/2001	60 HZ
LIGHT CIRCUIT: _____	120 VOLTS	3.30 AMPS
DEFROST HEATER CIRCUIT: _____ 1 PH	208 VOLTS	22.80 AMPS
ADDITIONAL CONDENSATE HEATERS: _____	120 VOLTS	5.80 AMPS
FAN CIRCUIT (MAY INCLUDE CONDENSATE HTRS.): _____	120 VOLTS	2.50 AMPS
MINIMUM FAN CIRCUIT AMPACITY: _____		2.50 AMPS
MAXIMUM FAN CIRCUIT OVERCURRENT PROTECTION: _____		20.00 AMPS
REFRIGERANT: R507	LOW SIDE DESIGN PRESSURE: 200 PSIG	

FOR SINGLE POINT CONNECTION – ADD LIGHT AMPERE AND ANTI – CONDENSATE AMPERE VALUES TO FAN CIRCUIT MINIMUM AMPACITY, IF THE TOTAL VALUE IS 16 AMPERES OR LESS, THEN THIS APPLIANCE MAY BE WIRED TO ONE 20 AMPERE NEC BRANCH CIRCUIT.

MADE IN THE
U.S.A.
2215 – 0399760

End-users

- One-time registration for <150 GWP facilities in RMP (no fee)

Q. Any challenges?

California Environmental Protection Agency
Air Resources Board

ARB RMP Home Page

CA.GOV R3 Home Reports & Forms Contact FAQ Survey Test Your XML Help

Welcome to Refrigerant Registration and Reporting System (R3)

Welcome to the Refrigerant Registration and Reporting System (R3). The R3 is a web-based tool for implementing the registration, reporting, and fee payment provisions of ARB's Refrigerant Management Program (RMP). In addition, the R3 offers the public a means to view select preformatted reports of refrigerant emissions. The R3 can be conveniently accessed on any computer with an internet connection.

The RMP is California's regulation for stationary, non-residential refrigeration systems using more than 50 pounds of a high global warming potential (high-GWP) refrigerant. The RMP seeks to reduce emissions of high-GWP refrigerants from leaking refrigeration equipment and the installation and servicing of refrigeration and air-conditioning appliances.

At the top of this page are links to the general ARB home web page and the home page of the RMP. Below that, on the red tab bar are links to preformatted reports and forms, important contacts for the RMP, and answers to frequently asked questions.

[RMP R3 Registration Check List](#) (information you will need before registering)

LOGIN

USERNAME:

PASSWORD:

(case-sensitive)

[Can't Access my Account?](#)

Companies with facilities with refrigeration systems, distributors, wholesalers, and reclaimers must first setup a user account and company profile in order to use R3.

[Sign Up for New Registration](#)

Defining “New Refrigeration Equipment”



Current definition of “New Refrigeration Equipment” in CARB’s 2018 Regulation¹:

- (1) Any refrigeration equipment that is **first installed using new or used components**;
- or
- (2) Any refrigeration equipment that is **modified** such that it is: (i) Expanded after the date at which this subarticle becomes effective, to handle an expanded cooling load by the addition of components in which the **capacity of the system is increased**, including refrigerant lines, evaporators, compressors, condensers, and other components; or (ii) Replaced or cumulatively replaced after the date at which this subarticle becomes effective, such that the **capital cost of replacing or cumulatively replacing components exceeds 50 percent of the capital cost of replacing the entire refrigeration system.**


[Q. Will this definition work for this proposed regulation?](#)

[1 HFC Rulemaking webpage](#)

Discussion Topics (Stakeholder Input Requested)

3. Feasibility of 150 GWP Limit for New and Existing Facilities

Feasibility of Low-GWP Equipment in New and Existing Facilities



Why is this important?

e.g., ~4,000 supermarkets in CA; New construction: Only 1 – 2% per year
Most of the new systems will go into existing stores

Q. Feasibility of low-GWP systems in existing stores, for all system sizes > 50 lb.?

Discussion Topics (Stakeholder Input Requested)

4. Feasibility of 750 GWP Limit on
Refrigeration / Process Chillers

