Figure 20: Space Created by Dispensing as a Function of Throughput and ORVR V	//Ls
	43
List of Tables	
Table 1: Sample Distribution of 400 GDF Site ISD Data Downloads (5% sample siz	e) 10
Table 2: Parameters That Can Affect the UST Pressure Profile	20
Table 3: General Site Information – Statewide	21
Table 4: General Site Information for October 2013	22
Table 5: General Site Information for November 2013	22
Table 6: Prevalence of Overpressure Alarms	23
Table 7: Prevalence of Leak Alarms	23
Table 8: Statewide PWD Percentage	25
Table 9: PWD and Loading Terminals	26
Table 10: Prevalence of Sites Equipped with Secondary Containment Vacuum	
Monitoring	29
Table 11: Overpressure Alarm Frequency at Sites Equipped with SCVM	29
Table 12: Prevalence of PWD after Round 1 and 2 of ISD Downloads	30
Table 13: Prevalence of PWD after Round 3 and 4 of ISD Downloads	31
Table 14: Prevalence of Leak Alarms at Assist Sites	31
Table 15: Prevalence of Leak Alarms at Balance Sites	32
Table 16: Prevalence of PWD and Leak Alarms at Assist Sites	32
Table 17: Assist Sites with PWD and Average Throughput	33
Table 18: Ullage Volume and Prevalence of PWD	34

Table 19: V/L Ratios of PWD and non-PWD Assist Sites	35
Table 20: V/L Ratios at Three Classifications of Assist Sites	35
Table 21: V/L Ratios of Non-PWD (Balance) Sites	36
Table 22: Assist Sites with PWD and ORVR Percentage	36
Table 23: ISD Estimate Site ORVR Percentage at Non-PWD vs. PWD Sites	37
Table 24: Tiers of Overpressure Severity within Mega Blitz Sample Population	38
Table 25: V/L Ratios at Balance Sites	42
Table 26: Throughput Range and Prevalence of PWD	42

Veeder-Root and INCON. Approximately 90 percent of ISD systems are Veeder-Root, while 10 percent are INCON. Based on this information, it was determined that data gathering activities during the Mega Blitz would attempt to emulate the distribution of EVR and ISD system type weighted by manufacturer sales. (Table 1, Appendix I)

Once the sites were selected, staff proposed data collection from each site to occur in a two to three week period before the RVP limit changes on November 1 and March 31 and a two to three week period after the RVP change. These collections dates would ensure the capture of pressure data before and after the wintertime switch to high RVP fuel and the pressure data before and after the summertime switch to control RVP fuel, in October, December, February, and April. The data downloads were performed primarily by CARB staff with site access provided by local air district staff. In some cases, especially in the South Coast AQMD, district staff performed the data download.

To conduct each site visit, both CARB and district staff were sent out with detailed ISD download instructions, a list of ISD download commands, an informational letter for the GDF operators, cables, laptop computers, and a data form for GDF details and operating parameters. The ISD download instructions (see Appendix II) detailed the explicit steps to take while connecting to the ISD console (Veeder-Root) via laptop and inputting the ISD text commands that indicate what report data to copy and save. The specific download commands include:

- Vapor Pressure Events (see Figure 1);
- ISD Monthly Status Report (see Figure 2);
- ISD Daily Report (see Figure 3);
- Delivery Report (see Figure 4);
- Flowmeter, AFM Busy Events Report (see Figure 5); and
- Assist Vapor Collection Test Results / Balance Flow Monitoring Test Results (see Figure 6 below)

The informational letter provided to GDF operators (see Appendix III) explained the purpose of the staff visit and download and provided staff contact information for those with questions or concerns. The GDF data collection form (see Appendix IV) prompted staff to document detailed information on the EVR and ISD systems, inventory reports, fuel deliveries, and site information. In order to properly examine the Mega Blitz information, all ISD overpressure and leak alarm data, as well as GDF site characteristics were consolidated into an Excel database.

Figure 1: Example of Raw ISD Data - Vapor Pressure Events

OCT 8, 2013 10:32 AM	
VAPOR PRESSURE EVENTS	
INDEX DATE-TIME	PRESSURE ULLAGE FLAGS
0001 13-10-07 04:22:52	-0.013 25880.1 0000
0002 13-10-07 04:23:12	-0.014 25880.1 0000
0003 13-10-07 04:23:32	-0.016 25880.1 0000
0004 13-10-07 04:23:53	-0.017 25880.1 0000
0005 13-10-07 04:24:13	-0.018 25880.1 0000
0006 13-10-07 04:24:33	-0.019 25880.1 0000
0007 13-10-07 04:24:53	-0.019 25880.1 0000
0008 13-10-07 04:25:13	-0.020 25880.1 0000
0009 13-10-07 04:25:33	-0.020 25880.1 0000
0010 13-10-07 04:25:53	-0.020 25880.2 0000

Figure 2: Example of Raw ISD Data - ISD Monthly Status Report

```
OCT 8, 2013 10:39 AM
ISD MONTHLY STATUS REPORT
EVR TYPE: BALANCE
ISD TYPE: 01.04
VAPOR PROCESSOR TYPE: VEEDER-ROOT POLISHER
                                             EVR VAPOR COLLECTION :WARN
OVERALL STATUS
                            :WARN
EVR VAPOR CONTAINMENT
                            :WARN
ISD MONITOR UP-TIME
                            :100%
                                            VAPOR PROCESSOR
EVR/ISD PASS TIME
                            : 62%
                                                                   :PASS
ISD MONITORING TEST PASS/FAIL THRESHOLDS
                                                     PERIOD
                                                                BELOW ABOVE
VAPOR COLLECTION BALANCE SYS FLOW PERFORMANCE
                                                      1DAYS
                                                                 0.60
                                                                ---- 1.30"wcg
---- 0.30"wcg
---- 12.50cfh
---- 2.50"wcg
VAPOR CONTAINMENT GROSS FAIL, 95th PERCENTILE
                                                       7DAYS
VAPOR CONTAINMENT DEGRADATION, 75th PERCENTILE
                                                     30DAYS
VAPOR CONTAINMENT LEAK DETECTION FAIL @2"WCG
                                                      7DAYS
STAGE I VAPOR TRANSFER FAIL, 50th PERCENTILE
                                                     20MINS
VAPOR PROCESSOR SELF TEST FAIL
                                                      1DAYS
                                                                 ----
VAPOR PROCESSOR MASS EMISSION FAIL (LB/KGAL)
                                                                 ---- 0.32
                                                      1DAYS
WARNING ALARMS
DATE
         TIME
                  DESCRIPTION
                                                   READING
                                                                    VALUE
13-10-03 10:00:40 VAPOR CONTAINMENT LEAKAGE
                                                   CFH@2 INCHES WC 78.73
13-10-02 10:00:50 VAPOR CONTAINMENT LEAKAGE
                                                    GROSS FAIL
13-10-01 10:01:52 FLOW PERFORMANCE HOSE BLOCKAGE FP 8 BLEND3
                                                                      0.59
FAILURE ALARMS
DATE
         TIME
                  DESCRIPTION
                                                    READING
                                                                    VALUE
SHUTDOWN & MISCELLANEOUS EVENTS
        TIME
                 DESCRIPTION
                                                   ACTION/NAME
13-10-04 08:42:10 CONTAINMENT VAPOR LEAKAGE
                                                  TEST MANUALLY CLEARED
13-10-01 12:17:50 COLLECTION TEST HH08 GRADE
                                                   TEST MANUALLY CLEARED
```

Figure 3: Example of Raw Data - ISD Daily Report

ISD DAILY REPORT DETAILS EVR TYPE: BALANCE ISD TYPE: 01.02 VAPOR PROCESSOR TYPE: VEEDER-ROOT POLISHER OVERALL STATUS :WARN EVR VAPOR COLLECTION : PASS EVR VAPOR CONTAINMENT :WARN STAGE I TRANSFERS: 1 of 1 PASS :100% ISD MONITOR UP-TIME EVR/ISD PASS TIME : 90% VAPOR PROCESSOR :WARN Status Codes: (w)warn (F)Fail (D)Degradation Fail (G)Gross Fail (ISD-W)ISD Self-Test Warning (ISD-F)ISD Self-Test Fail (N)NO Test ---CONTAINMENT TESTS------COLLECTION TESTS ISD STAGE GROSS DGRD MAX MIN LEAK 95% 75% "WC "WC CFH EVR %UP I VAPOR FP1 FP2 DATE STATUS TIME XFR PRCSR BLEND BLEND BLEND 0.0 -1.1 03/01 PASS 100% 0.5 -0.0 PASS 0.94 0.81 03/02 03/03 03/04 PASS 100% PASS 100% 0.2 -1.0 0.8 -2.0 0.86 1.02 0.90 1.11 0.96 0.97 0.94 0.4 0.0 0 PASS 6 0.5 0.0 PASS 0.95 2.0 -1.1 PASS 100% 0.4 0.0 PASS 0.93 03/05 0.0 - 1.00.80 PASS 100% 0.40.0PASS 0.82 0.79

Figure 4: Example of Raw ISD Data - Delivery Report

OCT 8, 20	13 10	):47	AM								_
DELIVERY R	EPOR	г									
	DATE	= / -							TEMP DEG F		
END: START: AMOUNT:	OCT OCT	7, 7,	2013 2013	11:42 11:20	AM AM	6873 2332 4541	6767 2286 4481	0.00	81.99 87.74	53.44 24.32	
	OCT	3,	2013	1:28	PM	7579	7481	0.00		57.67	
END: START: AMOUNT:	SEP SEP	30, 30,	2013 2013	9:10 8:46	AM AM	7002 1104 5898		0.00 0.00	76.45 83.30	54.21 14.49	
END: START: AMOUNT:						7160 1213 5947	1190	0.00 0.00	80.28 86.03	55.16 15.45	
END: START: AMOUNT:	SEP SEP	23, 23,	2013 2013	12:41 12:23	PM PM	4726 490 4236	4650 480 4170			40.33 8.34	
END: START: AMOUNT:	SEP SEP	18, 18,	2013 2013	5:51 5:24	PM PM	6721 898 5823	6623 881 5742	0.00 0.79	80.78 86.58	52.52 12.58	
END: START: AMOUNT:	SEP SEP	15, 15,	2013 2013	10:16 9:57	AM AM	6071 1521 4550	5982 1496 4486	0.00 0.00	80.84 83.37	48.60 18.06	
END: START: AMOUNT:				6:35 6:09		6331 538 5793		0.00 0.00	80.57 84.29	50.17 8.88	
END: START: AMOUNT:	SEP SEP	7, 7,	2013 2013	6:33 6:08	AM AM	6152 1626 4526		0.00 0.00	82.56 85.46	49.09 18.91	
END: START: AMOUNT:	SEP SEP	3, 3,	2013 2013	5:55 5:24	PM PM	6861 965 5896	947	0.00 0.00	84.54 85.24		

Figure 5: Example of Raw ISD Data – Vapor Flowmeter

OCT 8, 2013 10:47 AM							
AFM BUSY EVENTS: FLOWMETER 1							
INDEX START DATE-TIME DUR	A/L	VAPOR	FUEL	#EV	FLAGS	FPS	HOSES
0001 13-09-08 13:10:50 7	0.23	3.2	14.0	1	003E	02	01
0002 13-09-08 13:44:17 5	0.33	1.7	5.2	1	003E	02	01
0003 13-09-08 15:17:59 3	-0.03	-0.3	9.3	1	003E	02	01
0004 13-09-08 15:38:20 16	-0.20	-2.9	14.9	1	003E	01	00
0005 13-09-08 16:11:38 10	0.20	3.2	15.9	1	003E	02	01
0006 13-09-08 16:50:12 23	1.94	25.1	12.9	1	003E	02	01
0007 13-09-08 17:37:59 17	0.62	9.7	15.6	1	002E	01	00
0008 13-09-08 19:14:56 6	1.35	12.2	9.0	1	002E	02	01
0009 13-09-08 20:25:43 8	0.69	6.9	10.0	1	002E	02	01
0010 13-09-08 21:02:16 11	0.26	2.8	10.6	1	003E	02	01
0011 13-09-08 21:30:51 8	0.08	0.4	5.0	1	003E	02	01
0012 13-09-08 21:42:27 5	0.82	3.9	4.7	1	002E	02	01
0013 13-09-08 22:01:58 6	0.08	0.4	5.3	1	003E	02	01
0014 13-09-09 06:57:05 3	0.67	1.4	2.1	1	0037	02	01
0015 13-09-09 07:01:23 13	0.32	2.1	6.3	1	003E	01	00
0016 13-09-09 08:09:11 2	1.72	1.7	1.0	1	0037	02	01

Figure 6: Example of Raw ISD Data - Vapor Flow Monitoring Report

```
OCT 8, 2013 10:58 AM
BALANCE FLOW MONITORING TEST RESULTS
                         EstPrOrvr OrvrLimit SiteChi^2 CritVal SiteChi^2Result
Rec# Test_Timestamp
0330 13-09-02 09:59:09
                         78.52%
                                    94.00%
                                              143.16
                                                          20.48 valid_orvr_tests
Dispenser---- ----Flow Monitoring--- ----
                                                         -orvr-----
                                             -----
                             Days Evnt Status V #0 #AL %Blck %Thrs %Zero
Labl Hose AFM Status A/L
          00 PASS
00 PASS
                                                0
      00
                       0.87 11.8
                                     68 PASS
                                                    30
                                                        68 44.12 92.50 64.54
                                     91 PASS
                                                        91 34.07 90.60 66.44
  02
      00
                       0.92
                             3.9
                                                    31
                       0.98 4.9
      00
          01
              PASS
                                     69 PASS
                                                 0 57
                                                        69 82.61 92.40 64.64
                                                0 60
0 52
  04
      00
          01
              PASS
                       0.98 10.9
                                     69 PASS
                                                    60
                                                        69 86.96 92.40 64.64
  05
                                                        70 74.29 92.30 64.74
      00
          02
              PASS
                       0.84
                             0.8
                                     70 PASS
                                                0 48
  06
      00
          02
              PASS
                       0.70
                             3.9
                                     72 PASS
                                                        72 66.67 92.11 64.93
      00
          03
                       0.83
                             3.9
                                     77 PASS
2 PASS
                                                0 64
                                                        77 83.12 91.66 65.38
  07
              PASS
                                                        2100.00 0.00 1.00
73 93.15 92.01 65.03
  08
                                                0
      00
          03
              NOTEST
                             0.6
  09
      00
          04
              PASS
                       0.88
                             8.9
                                     73 PASS
                                                0
                                                    68
                             8.9
                                                 0
  10
      00
          04
              PASS
                                     72 PASS
                                                    59
                                                        72 81.94 92.11 64.93
                       0.85
                       0.90
                                                        82 81.71 91.25 65.79
72 86.11 92.11 64.93
  11
      00
          05
              PASS
                             3.9
                                     82 PASS
                                                    67
      00
                             3.9
                                     72 PASS
                                                    62
          05
              PASS
```

# 2. Methodology

Once CARB and district staff conducted their site visits and collected the target data, CARB staff returned to the office and created two large Excel databases, one for overpressure alarms and the other for leak alarms, in which to assemble and analyze the information. The goal was to determine whether a correlation existed between GDF operating parameters and overpressure occurrence severity. Additionally, an Excel macro program was created that pulls a segment of the ISD download (the ullage pressure and volume) to flag and identify sites that exhibit PWD, called "VR Vapor Pressure Events P/U Plot." A second Excel macro was created that pulls a different segment of the ISD download, the most recent 1,000 refueling transaction data available for each dispenser to determine site vapor-to-liquid (V/L) ratio and overall distribution of V/L, called "Histogram Assistance Tool" (HAT).

#### A. Mega Blitz Database – Overpressure Alarms

For the two Excel databases created, each was initially populated with 46 fields for each GDF site. The data for each GDF site includes information on location, hours of operation, types of vapor recovery and ISD systems, recent fuel deliveries, gasoline throughput, gasoline capacity, average UST and delivered fuel temperatures at each site visit, and changes to the sites between visits. Once specific site details were recorded, staff then populated another 32 fields with overpressure warning alarm information. For the Overpressure Alarm specific database (see Appendix V), staff analyzed the ISD downloads going as far back as October 2011. From the ISD monthly reports, staff tabulated the overpressure warning alarm occurrences in each month, up until the last Mega Blitz download site visit in April 2014.

### B. Mega Blitz Database – Leak Alarms

The Mega Blitz Leak Alarm database (see Appendix VI) consisted of the same 46 GDF site specific fields as the Mega Blitz Overpressure Alarm database. However, instead of quantifying the overpressure warning alarms taking place each month and across the entire Mega Blitz study period, it quantifies the warning leak alarms occurring monthly. With data gleaned from the ISD alarm reports, staff populated 32 fields with monthly leak alarm totals from October 2011 to April 2014, and tabulated the alarm totals and frequency for each site.

# C. Vapor Pressure Events Pressure / Ullage Plot – PWD Identification

Along with quantifying frequency of overpressure and leak alarms pulled from the ISD data downloads, staff also examined the UST pressure data contained in ISD Vapor Pressure Events command for evidence of PWD. The Vapor Pressure Events command provides the most recent 30 hours of pressure and ullage data and consists of 5,400 records. To identify PWD, staff created an Excel macro, VR Vapor Pressure Events P/U Plot, that identified which sites demonstrated specific data traits (flags). The

versus summertime overpressure alarm occurrences. The data presented was gathered from the first two rounds of ISD data downloads in October and December 2013 and pulled from stored alarm information dating back to April 2012. There were a total of 395 GDF sites initially studied in the Mega Blitz, with 272 being assist EVR system sites and 123 being balance EVR system sites. 313 of those sites were open 24 hours a day and 82 shut down service at night. Overpressure alarm occurrences were high in the wintertime fuel months, with 2,329 alarms taking place between December 2012 and March 2013, and in November 2013. Overpressure alarms in the summertime fuel months between April 2012 and October 2013, were relatively low, totaling 317.

Table 3: General Site Information – Statewide

All Sites	Number	Percent
Sites in Mega Blitz	395	N/A
Assist Sites in Mega Blitz	272	68.9%
Balance Sites in Mega Blitz	123	31.1%
Sites open 24 Hours	313	79.2%
Sites that shutdown at night	82	20.8%
OP Alarms: Dec 2012 – March 2013 & Nov 2013 (Winter)	2329	N/A
OP Alarms: April 2012 – October 2013 (Summer)	317	N/A
Ratio of Winter vs Summer OP Alarms	7.3	N/A
Sites with Veeder-Root ISD	377	95%
Sites with INCON ISD	18	5%

Tables 4 and 5 lists the factors associated with overpressure alarm occurrences for all sites in October and November 2013, respectively. Staff looked at the number and percentage of overpressure alarms in comparison to hours of operation (24 hour sites versus those that shut down at night). There was a ten-fold increase in the total number of overpressure alarms from October to November (the switch to winter fuel) and more sites experienced at least one overpressure alarm in November as compared to October. In October 2013, there was on average 0.12 overpressure alarms per GDF, with an average of 0.11 overpressure alarms at 24 hour sites and 0.13 overpressure alarms at sites that shut down at night. In November 2013, there was on average 1.39 overpressure alarms per GDF, with an average of 1.38 overpressure alarms at 24 hour sites and 1.43 overpressure alarms at sites that shut down at night.

Table 4: General Site Information for October 2013

October 2013 - All Sites	Number	Percent
Sites with at least 1 OP Alarm in Oct 2013	26	6.6%
Total number of OP Alarms in October 2013	46	N/A
OP Alarms/GDF	0.12	N/A
OP Alarms at 24 Hour sites in Oct 2013	35	76.1%
OP Alarms/GDF at 24 Hour sites in Oct 2013	0.11	N/A
OP Alarms at sites that shut down at night in Oct 2013	11	23.9%
OP Alarms/GDF that shut down at night in Oct 2013	0.13	N/A

Table 5: General Site Information for November 2013

November 2013 - All Sites	Number	Percent
Sites with at least 1 OP Alarm in Nov 2013	215	54.4%
Total number of OP Alarms in Nov 2013	548	N/A
OP Alarms/GDF	1.39	N/A
OP Alarms at 24 Hour sites in Nov 2013	431	78.6%
OP Alarms/GDF at 24 Hour sites in Nov 2013	1.38	N/A
OP Alarms at sites that shut down at night in Nov 2013	117	21.4%
OP Alarms/GDF that shut down at night in Nov 2013	1.43	N/A

### B. Overpressure and Leak Alarms

Initial findings from the Mega Blitz study and data analysis focused on the site visits from October and November 2013. Table 6 below shows the prevalence of overpressure alarms from that time period, as all GDF sites combined and then the split between assist and balance EVR system sites. There was an average of 0.12 overpressure alarms per site in October 2013 with summertime fuel, which increased to an average of 1.39 overpressure alarms per site in November 2013 with wintertime fuel. From October to November, the percentage of sites with at least one alarm increased from 6.6 percent to 54.4 percent. Alarms per site during that time increased for both assist and balance sites. In November 2013, nearly 70 percent of assist EVR system sites had at least one overpressure alarm while nearly 20 percent of balance EVR system sites experienced at least one alarm.

Table 6: Prevalence of Overpressure Alarms

Data Set	Overpressure Alarms	October 2013	November 2013
All Sites Combined	Average Number of Alarms Per Site	0.12	1.39
(395)	% of Sites With at Least One Alarm	6.6%	54.4%
Assist Sites (274)	Average Number of Alarms Per Site	0.16	1.84
	% of Sites With at Least One Alarm	8.8%	69.7%
Balance Sites (121)	Average Number of Alarms Per Site	0.02	0.36
	% of Sites With at Least One Alarm	1.7%	19.8%

Table 7 compares the prevalence of leak alarms for the same time periods. There was an average of 0.33 leak alarms per site in October 2013 with summertime fuel, which decreased to an average of 0.29 leak alarms per site in November 2013 with wintertime fuel. From October to November the percentage of sites with at least one alarm stayed the same at 16.2 percent. Alarms per site during that time decreased slightly for assist sites and increased slightly for balance sites. In November 2013, 8.8 percent of assist EVR system sites had at least one leak alarm while 33.1 percent of balance EVR system sites experienced at least one alarm.

Table 7: Prevalence of Leak Alarms

Data Set	Leak Alarms	October 2013	November 2013
All Sites Combined	Average Number of Alarms Per Site	0.33	0.29
(395)	% of Sites With at Least One Alarm	16.2%	16.2%
Assist Sites (274)	Average Number of Alarms Per Site	0.19	0.13
	% of Sites With at Least One Alarm	11.7%	8.8%
Balance Sites (121)	Average Number of Alarms Per Site	0.65	0.65
	% of Sites With at Least One Alarm	26.4%	33.1%

Figures 10 and 11 provide temporal trends of the prevalence of overpressure and leak alarms from month to month. Figure 10 displays the number of overpressure alarms occurring monthly, from October 2011 to March 2014, showing the increase in alarms during winter months. Figure 11 displays the number of leak alarms occurring monthly, from October 2011, to March 2014, showing an increase in the summer months.

Figure 10: Prevalence of Overpressure Alarms, October 2011 to March 2014





Figure 11: Prevalence of Leak Alarms, October 2011 to March 2014



### C. PWD Related Findings

The following tables provide information pertaining to the characteristics of GDF sites (assist versus balance, throughput, and hours of operation) in comparison to occurrences of overpressure alarms and PWD within the Mega Blitz study. Table 8 displays the percentage of PWD occurrences statewide and regionally from December 2013 to February 2014. Across all regions, instances of PWD at assist EVR system sites decreased from December 2013 to February 2014, falling from 34.2 percent to 24.4 percent. This trend followed in four of the five regions, except for South Coast where PWD occurrence increased from 33.3 percent of assist EVR system sites to 40.2 percent in the same time period. The drops in PWD can likely be attributed to cooler ambient temperatures and lower RVP.

Table 8: Statewide PWD Percentage

Location	Assist* PWD – December 2013	Assist* PWD – February 2014
All Counties/Districts	34.2%	24.4%
SJVAPCD	68%	20%
BAAQMD	50%	18%
Sacramento	11.1%	2.8%
San Diego	22.7%	22.7%
South Coast	33.3%	40.2%

<sup>\*</sup>PWD was not observed at balance EVR system sites.




Figure 17: PWD and Monthly Gasoline Throughput in February 2014

#### 4) PWD and Ullage Volume

Staff examined thirty assist sites located in SCAQMD; ten exhibiting PWD in December 2013 and February 2014; ten exhibiting PWD in December but not February; and ten not exhibiting PWD in December, but exhibiting it in February. The average throughput, UST capacity in gallons, and average ullage volume in gallons was also noted. Table 18 below shows that despite the varied stages of PWD, UST ullage was consistent at nearly 60 percent.

Table 18: Ullage \	Volume and	Prevalence	of PWD
--------------------	------------	------------	--------

Number	Average	PWD	PWD	Average UST	Average Ullage	%
of Sites	Throughput	in Dec	in Feb	Capacity (gallons)	Volume (gallons)	Ullage
10	153,900	No	No	32,800	19,230	58.6%
10	134,900	Yes	Yes	32,700	18,790	57.5%
10	149,900	Yes	No	31,800	18,600	58.5%

### 5) V/L Ratios at PWD versus non-PWD Sites

To assess the effect of PWD on vapor to liquid (V/L) ratios of assist sites, staff used the HAT tool to compare the V/L ratios of PWD to non-PWD assist sites from October 2013, to December 2013 in four regions. Data was collected from 42 sites in South Coast, 22 sites in the Bay Area, 20 sites in San Diego, and 16 sites in the San Joaquin Valley. Each region studied contained an equal number of PWD and non-PWD sites as well as a similar monthly gasoline throughput at the GDFs. Table 19 below shows that the V/L