

DEC - 7 2006

Debra Monterroso Crimson Resource Management 5001 California Avenue, Suite 206 Bakersfield, CA 93309

RE: Notice of Final Action - Emission Reduction Credits

Project Number: S-#S-1052797

Dear Ms. Monterroso:

The Air Pollution Control Officer has issued Emission Reduction Credits (ERCs) to Crimson Resource Management for emission reductions generated by the replacement of six existing IC engines driving gas compressors with three lower emitting IC engine/generator sets driving gas compressors, at the 1-C gas processing facility, at Hwy 119 and Midway Road, Taft. The quantity of ERCs issued is 76,329 lb/yr VOC, 14,242 lb/yr NOx, 40,405 lb/yr CO and 5,236 lb/yr PM10.

Enclosed are copies of the ERC Certificates and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary decision to issue the ERC Certificates was published on October 25, 2006. The District's analysis of the proposal was also sent to CARB and US EPA Region IX on October 23, 2006. All comments received following the District's preliminary decision on this project were considered.

Comments received from the US EPA during the pubic notice period resulted in the District correcting and lowering the VOC emissions factors used in determining the historical actual emissions for four of the shutdown IC engines. This correction to emissions factors resulted in lower amounts of VOC being approved for ERC banking, from 92,775 lb/yr in our preliminary decision to a corrected, final amount of 76,329 lb/yr.

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Ms. Debra Monterroso Page 2

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Thomas Goff at (661) 326-6900.

Sincerely,

David Warner Director of Permit Services

DW:RWK/ls

Enclosures



DEC - 7 2006

Mike Tollstrup, Chief Project Assessment Branch Stationary Source Division California Air Resources Board PO Box 2815 Sacramento, CA 95812-2815

RE:

Notice of Final Action - Emission Reduction Credits

Project Number: S-#\$-1052797

Dear Mr. Tollstrup:

The Air Pollution Control Officer has issued Emission Reduction Credits (ERCs) to Crimson Resource Management for emission reductions generated by the replacement of six existing IC engines driving gas compressors with three lower emitting IC engine/generator sets driving gas compressors, at the 1-C gas processing facility, at Hwy 119 and Midway Road, Taft. The quantity of ERCs issued is 76,329 lb/yr VOC, 14,242 lb/yr NOx, 40,405 lb/yr CO and 5,236 lb/yr PM10.

Enclosed are copies of the ERC Certificates and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary decision to issue the ERC Certificates was published on October 25, 2006. The District's analysis of the proposal was also sent to CARB and US EPA Region IX on October 23, 2006. All comments received following the District's preliminary decision on this project were considered.

Comments received from the US EPA during the public notice period resulted in the District correcting and lowering the VOC emissions factors used in determining the historical actual emissions for four of the shutdown IC engines. This correction to emissions factors resulted in lower amounts of VOC being approved for ERC banking, from 92,775 lb/yr in our preliminary decision to a corrected, final amount of 76,329 lb/yr.

Seyed Sadredia

Executive Director/Air Pollution Control Officer

Mr. Mike Tollstrup Page 2

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Thomas Goff at (661) 326-6900.

Sincerely,

David Warner

Director of Permit Services

DW:RKW/Is

Enclosures



DEC - 7 2006

Gerardo C. Rios (AIR 3) Chief. Permits Office Air Division U.S. E.P.A. - Region IX 75 Hawthorne Street San Francisco, CA 94105

RE: Notice of Final Action - Emission Reduction Credits

Project Number: S-#S-1052797

Dear Mr. Rios:

Thank you for your 12/4/06 E-mail comment on the above project. Following is the District's specific response to your comment:

Comment: "...the VOC emissions factors used for engines '3, '4, '7 and '8 (average of two exhaust stacks) were higher than what is allowed by Rules 4701/4702, resulting in non-surplus credits being proposed for banking."

Response: We agree that the VOC emissions factors for engines '3, '4, '7 and '8 were averaged in an inappropriate manner, thus resulting in non-surplus VOC historical actual emissions being calculated. Therefore, we have corrected the VOC emissions factors accordingly: from 750 to 528 ppmv @ 15% O_2 for unit '3, from 750 to 710 ppmv @ 15% O_2 for unit '4, from 750 to 498 ppmv @ 15% O_2 for unit '7 and from 750 to 725 ppmv @ 15% O₂ for unit '8. The use of the corrected factors reduced the amount of VOC emission reduction credits being approved from 92,775 lb/yr in our preliminary decision to a revised, final amount of 76,329 lb/yr.

We trust that the above response satisfies your concerns and we appreciate your concurrence on this project.

> Seved Sadredin Executive Director/Air Pollution Control Officer

Northern Region 4800 Enterprise Way Modesto, CA 95356-8718 Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office) 1990 E. Gettysburg Avenue Fresno, CA 93726-0244 Tel: (559) 230-6000 FAX: (559) 230-6061 www.valleyair.org

Southern Region 2700 M Street, Suite 275 Bakersfield, CA 93301-2373 Tel: (661) 326-6900 FAX: (661) 326-6985 The Air Pollution Control Officer has issued Emission Reduction Credits (ERCs) to Crimson Resource Management for emission reductions generated by the replacement of six existing IC engines driving gas compressors with three lower emitting IC engine/generator sets driving gas compressors, at the 1-C gas processing facility, Hwy 119 and Midway Road, Taft. The quantity of ERCs issued is 76,329 lb/yr VOC, 14,242 lb/yr NOx, 40,405 lb/yr CO and 5,236 lb/yr PM10.

Enclosed are copies of the ERC Certificates and a copy of the notice of final action to be published approximately three days from the date of this letter.

If you have any questions, regarding the above response, or require additional clarification, please contact Mr. Thomas Goff at (661) 326-6900.

Sincerely,

David Warner

Director of Permit Services

DW:RWK/ls

Enclosures

Bakersfield Californian

NOTICE OF FINAL ACTION FOR THE ISSUANCE OF EMISSION REDUCTION CREDITS

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued Emission Reduction Credits (ERCs) to Crimson Resource Management for emissions reductions generated by the replacement of six existing IC engines driving gas compressors with three lower emitting IC engine/generator sets driving gas compressors, at the 1-C gas processing facility, Hwy 119 and Midway Road, Taft. The quantity of ERCs issued is 76,329 lb/yr VOC, 14,242 lb/yr NOx, 40,405 lb/yr CO and 5,236 lb/yr PM10.

Comments received from US EPA during the public notice period resulted in the District correcting and lowering the VOC emissions factors used in determining the historical actual emissions for four of the shutdown IC engines. This correction to emissions factors resulted in lower amounts of VOC being approved for ERC banking, from 92,775 lb/yr in our preliminary decision to a corrected, final amount of 76,329 lb/yr. The use of lower emissions factors being used and fewer credits being approved is a minor change and does not require additional public notice.

Project #S-1052797 is available for public inspection at the SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 2700 'M' STREET SUITE 275, BAKERSFIELD, CA 93301.



Southern Regional Office • 2700 M Street, Suite 275 • Bakersfield, CA 93301-2370

Emission Reduction Credit Certificate S-2202-1

ISSUED TO:

CRIMSON RESOURCE MANAGEMENT

ISSUED DATE:

December 6, 2006

LOCATION OF REDUCTION:

1-C GAS PLANT

Intersection of Hwy 119 and Midway Rd

TAFT, CA

SECTION: SEC 1 TOWNSHIP: T32S RANGE: R23E

For VOC Reduction In The Amount Of:

Quarter 1	Quarter 2	Quarter 3	Quarter 4
23,063 lbs	20,161 lbs	19,126 lbs	13,979 lbs

[] Conditions Attached

Method Of Reduction

[] Shutdown of Entire Stationary Source


[] Shutdown of Emissions Units

[X] Other

Replacement of 6 IC engines driving compressors with IC engine electrical generators powering electrically driven inlet gas compressors

Use of these credits outside the San Joaquin Valley Unified Air Pollution Control District (SJVUAPCD) is not allowed without express written authorization by the SJVUAPCD.

Seyed Sadredin, Executive Director / APCO





Southern Regional Office • 2700 M Street, Suite 275 • Bakersfield, CA 93301-2370

Emission Reduction Credit Certificate S-2202-2

ISSUED TO:

CRIMSON RESOURCE MANAGEMENT

ISSUED DATE:

December 6, 2006

LOCATION OF

1-C GAS PLANT

REDUCTION: Intersec

Intersection of Hwy 119 and Midway Rd

TAFT, CA

SECTION: SEC 1 TOWNSHIP: T32S RANGE: R23E

For NOx Reduction In The Amount Of:

Quarter 1	Quarter 2	Quarter 3	Quarter 4
4,704 lbs	3,393 lbs	3,449 lbs	2,696 lbs

[]	Conditions	Attached

Method Of Reduction

[] Shutdown of Entire Stationary Source


[] Shutdown of Emissions Units

[X] Other

Replacement of 6 IC engines driving compressors with IC engine electrical generators powering electrically driven inlet gas compressors

Use of these credits outside the San Joaquin Valley Unified Air Pollution Control District (SJVUAPCD) is not allowed without express written authorization by the SJVUAPCD.

Seyed Sadredin, Executive Director / APCO





Southern Regional Office • 2700 M Street, Suite 275 • Bakersfield, CA 93301-2370

Emission Reduction Credit Certificate S-2202-3

ISSUED TO:

CRIMSON RESOURCE MANAGEMENT

ISSUED DATE:

December 6, 2006

LOCATION OF

1-C GAS PLANT

REDUCTION:

Intersection of Hwy 119 and Midway Rd

TAFT, CA

SECTION: SEC 1 TOWNSHIP: T32S RANGE: R23E

For CO Reduction In The Amount Of:

Quarter 1	Quarter 2	Quarter 3	Quarter 4
16,677 lbs	10,099 lbs	8,459 lbs	5,170 lbs

[] Conditions Attac	hed
----------------------	-----

Method Of Reduction

[] Shutdown of Entire Stationary Source


[] Shutdown of Emissions Units

[X] Other

Replacement of 6 IC engines driving compressors with IC engine electrical generators powering electrically driven inlet gas compressors

Use of these credits outside the San Joaquin Valley Unified Air Pollution Control District (SJVUAPCD) is not allowed without express written authorization by the SJVUAPCD.

Seyed Sadredin, Executive Director / APCO





Southern Regional Office • 2700 M Street, Suite 275 • Bakersfield, CA 93301-2370

Emission Reduction Credit Certificate S-2202-4

ISSUED TO:

CRIMSON RESOURCE MANAGEMENT

ISSUED DATE:

December 6, 2006

LOCATION OF

1-C GAS PLANT

REDUCTION:

Intersection of Hwy 119 and Midway Rd

TAFT, CA

SECTION: SEC 1 TOWNSHIP: T32S RANGE: R23E

For PM10 Reduction In The Amount Of:

Quarter 1	Quarter 2	Quarter 3	Quarter 4
1,745 lbs	1,292 lbs	1,258 lbs	941 lbs

[] Conditions Attached

Method Of Reduction

[] Shutdown of Entire Stationary Source


[] Shutdown of Emissions Units

[X] Other

Replacement of 6 IC engines driving compressors with IC engine electrical generators powering electrically driven inlet gas compressors

Use of these credits outside the San Joaquin Valley Unified Air Pollution Control District (SJVUAPCD) is not allowed without express written authorization by the SJVUAPCD.

Seved Sadredin, Executive Director / APCO





NORTHERN	REGION	
CENTRAL RE	EGION ERC/PUBLIC NOTICE CHEC	K LIST
SOUTHERN	·	
1.1	PROJECT #s: <u>#S-1052797</u>	
REQST. COMPL,	ERC TRANSFER OF PREVIOUSLY BANKED CREDITS	RECEIVED
_	ERC PRELIMINARY PUBLIC NOTICE	DEC 13 2006
<u> </u>	ERC FINAL PUBLIC NOTICE	
• •	NSR/CEQA PRELIMINARY PUBLIC NOTICE NSR/CEQA FINAL PUBLIC NOTICE	SJVAPCD Southern Region
√ □	Newspaper Notice Emailed to Clerical (Check box and tab to gen	erate Notice)
ENCLOSED	DOCUMENTS REQUIRE:	
<u> </u>	Enter Correct Date, Print All Documents from File and Obtain Signature	Directors
√	Send <i>FINAL</i> Notice Letters to CARB, EPA and Applicant; Inc. Following Attachments: Application Evaluation Other Public Notice	luding the
<u>√</u> _	Send FINAL Public Notice for Publication to Error! Reference not found. Bakersfuld Californian	e sou rce
<u>√</u> _	Send Signed Copies of FINAL Notice Letters to Regional Off Attn: Richard Karrs	ice
<u> </u>	Director's Signature and District Seal Embossed on ERC Cer	tificates
√	Director's Signature on Cover Letter and Mail Cover Letter & Certificates by Certified Mail to: √ Applicant:	ERC
	 ✓ Applicant: ✓ Applicant and Additional Addressees (see cover letters) Other 	s)
√ _	Send Copies of Signed and Seal Embossed ERC Certificates cover letter to Regional Office Attn: Richard Karrs	s and Signed
<u> </u>	Assign Mailing Date: ID# Project #: Other Special Instructions (please specify):	
Date Comple	eted [DATE COMPLETED] /By [SELECT SUPERVISOR]	
Date Added	to Seyed Directory:	

Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired. Print your name and address on the reverse so that we can return the card to you. Attach this card to the back of the mailplece, or on the front if space permits. 1. Article Addressed to: Debra Monterroso Crimson Resource Mgmt. 5001 California Ave., Suite 206 Bakersfield, CA 93309 3. Service Type Contified Mail Express Mail Registered Return Receipt for Merchandise Insured Mail C.O.D. 4. Restricted Delivery? (Extra Fee) Yes	SENDER: COMPLETE THIS SECTION	COMPLETE THIS SECTION ON DELIVERY
☐ Registered ☐ Réturn Recelpt for Merchandise ☐ Insured Mail ☐ C.O.D. 4. Restricted Delivery? (Extra Fee) ☐ Yes	Item 4 if Restricted Delivery is desired. Print your name and address on the revers so that we can return the card to you. Attach this card to the back of the mailple or on the front if space permits. 1. Article Addressed to: Debra Monterroso Crimson Resource Mgmt. 5001 California Ave., Suite 206	B. Received by (Printed Name) C. Date of Delivery C. Date of Delivery D. Is delivery address different from Item 1? If YES, enter delivery address below: 3. Service Type
7007 1/10 0007 7707 777		☐ Insured Mail ☐ C.O.D.
- 7003 1680 0001 3385 6737 FRC Project 45-1052797		
		55 6737 FRC Project 45-1052797

PROOF OF PUBLICATION

The BAKERSFIELD CALIFORNIAN

P.O. BOX 440 **BAKERSFIELD, CA 93302** RECEIVED

Class Code

NOV 0 6 2006

SAN JOAQUIN VALLEY A.P.C.D.

SJVAPCD

FRESNO, CA 93726

1990 E GETTYSBURG FRED BATISouthern Region

RECEIVED

OCT 3 1 2006

STATE OF CALIFORNIA COUNTY OF KERN

FINANCE

I AM A CITIZEN OF THE UNITED STATES AND A RESIDENT OF THE COUNTY AFORESAID: I AM OVER THE AGE OF EIGHTEEN YEARS, AND NOT A PARTY TO OR INTERESTED IN THE ABOVE ENTITLED MATTER, I AM THE ASSISTANT PRINCIPAL CLERK OF THE PRINTER OF THE BAKERSFIELD CALIFORNIAN, A NEWSPAPER OF GENERAL CIRCULATION, PRINTED AND PUBLISHED DAILY IN THE CITY OF BAKERSFIELD COUNTY OF KERN.

AND WHICH NEWSPAPER HAS BEEN ADJUDGED A NEWSPAPER OF GENERAL CIRCULATION BY THE SUPERIOR COURT OF THE COUNTY OF KERN, STATE OF CALIFORNIA, UNDER DATE OF FEBRUARY 5, 1952, CASE NUMBER 57610; THAT THE NOTICE, OF WHICH THE ANNEXED IS A PRINTED COPY, HAS BEEN PUBLISHED IN EACH REGULAR AND ENTIRE ISSUE OF SAID NEWSPAPER AND NOT IN ANY SUPPLEMENT THEREOF ON THE FOLLOWING DATES, TO WIT:

ALL IN YEAR 2006

I CERTIFY (OR DECLARE) UNDER PENALTY OF PERJURY THAT THE FOREGOING IS TRUE AND CORRECT.

DATED AT BAKERSFIELD CALIFORNIA

Ad Number: 10048523

TBC **Edition:**

Legal Notices

PO #: S-1052797 **Run Times**

Stop Date 10/25/2006

Billing Lines 43

10/25/2006

Inches 259.84

Total Cost

Start Date

\$ 79.97

Account 1SAN51

Billing Address

SAN JOAQUIN VALLEY A.P.C.D.

1990 E GETTYSBURGFRED BATES

FRESNO.CA

93726

Solicitor I.D.:

0

First Text

NOTICEOFPRELIMINARYDECISIONFORTHEPROP

Ad Number 10048523

NOTICE OF PRELIMINARY
DECISION FOR
THE PROPOSED ISSUANCE
OF EMISSION REDUCTION
CREDITS

OF EMISSION REDUCTION CREDITS

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Unified Air Pollution Control District solicits public comment on the proposed issuance of Emission Reduction Credits to Crinison Reduction Credits for the replacement of six existing IC engines driving gas compressors with three lower emitting IC engines/generator sets driving electric gas conspressors, at the 1-C gas processing facility. Hwy 119 and Midway Rosal, Tafi. The quantity of ERCs propused for banking is 92,775 lb/year VOC. 14,242 lb/year NOX. 40,405 lb/year CO and 5,236 lb/year MOX. 40,405 lb/year MOX. 40,405



OCT 2 3 2006

Debra Monterroso Crimson Resource Management 5001 California Avenue, Suite 206 Bakersfield, CA 93309

Re: Notice of Preliminary Decision - Emission Reduction Credits

Project Number: S-1052797

Dear Ms. Monterroso:

Enclosed for your review and comment is the District's analysis of Crimson Resource Management's application for Emission Reduction Credits (ERCs) resulting from the replacement of six existing IC engines driving gas compressors with three lower emitting IC engine/generator sets driving electric gas compressors, at the 1-C gas processing facility, Hwy 119 and Midway Road, Taft. The quantity of ERCs proposed for banking is 92,775 lb/year VOC, 14,242 lb/year NOx, 40,405 lb/year CO and 5,236 lb/year PM10.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. Please submit your written comments on this project within the 30-day public comment period which begins on the date of publication of the public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Mr. Richard Karrs of Permit Services at (661) 326-6954.

Sincerely,

David Warner

Director of Permit Services

DW:RWK/Is

Enclosures

Seyed Sadredin
Executive Director / Air Pollution Control Officer



OCT 2 3 2006

Gerardo C. Rios (AIR 3) Chief, Permits Office Air Division U.S. E.P.A. - Region IX 75 Hawthorne Street San Francisco, CA 94105

Re: Notice of Preliminary Decision - Emission Reduction Credits

Project Number: S-1052797

Dear Mr. Rios:

Enclosed for your review and comment is the District's analysis of Crimson Resource Management's application for Emission Reduction Credits (ERCs) resulting from the replacement of six existing IC engines driving gas compressors with three lower emitting IC engine/generator sets driving electric gas compressors, at the 1-C gas processing facility, Hwy 119 and Midway Road, Taft. The quantity of ERCs proposed for banking is 92,775 lb/year VOC, 14,242 lb/year NOx, 40,405 lb/year CO and 5,236 lb/year PM10.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. Please submit your written comments on this project within the 30-day public comment period which begins on the date of publication of the public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Mr. Richard Karrs of Permit Services at (661) 326-6954.

Sincerely,

David Warner

Director of Permit Services

DW:RWK/ls

Enclosure

Seyed Sadredin
Executive Director / Air Pollution Control Officer



OCT 2 3 2006

Mike Tollstrup, Chief Project Assessment Branch Stationary Source Division California Air Resources Board PO Box 2815 Sacramento, CA 95812-2815

Re: Notice of Preliminary Decision - Emission Reduction Credits

Project Number: S-1052797

Dear Mr. Tollstrup:

Enclosed for your review and comment is the District's analysis of Crimson Resource Management's application for Emission Reduction Credits (ERCs) resulting from the replacement of six existing IC engines driving gas compressors with three lower emitting IC engine/generator sets driving electric gas compressors, at the 1-C gas processing facility, Hwy 119 and Midway Road, Taft. The quantity of ERCs proposed for banking is 92,775 lb/year VOC, 14,242 lb/year NOx, 40,405 lb/year CO and 5,236 lb/year PM10.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. Please submit your written comments on this project within the 30-day public comment period which begins on the date of publication of the public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Mr. Richard Karrs of Permit Services at (661) 326-6954.

Sincerely,

David Warner

Director of Permit Services

DW:RWK/Is

Enclosure

Seyed Sadredin
Executive Director / Air Pollution Control Officer

NOTICE OF PRELIMINARY DECISION FOR THE PROPOSED ISSUANCE OF EMISSION REDUCTION CREDITS

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Unified Air Pollution Control District solicits public comment on the proposed issuance of Emission Reduction Credits to Crimson Resource Management for the replacement of six existing IC engines driving gas compressors with three lower emitting IC engine/generator sets driving electric gas compressors, at the 1-C gas processing facility, Hwy 119 and Midway Road, Taft. The quantity of ERCs proposed for banking is 92,775 lb/year VOC, 14,242 lb/year NOx, 40,405 lb/year CO and 5,236 lb/year PM10.

The analysis of the regulatory basis for these proposed actions, Project #S-1052797, is available for public inspection at the District office at the address below. Written comments on this project must be submitted within 30 days of the publication date of this notice to DAVID WARNER, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 2700 'M' STREET SUITE 275, BAKERSFIELD, CA 93301.

ERC APPLICATION REVIEW

Engineer:

Richard Karrs

Date:

Lead Engineer:

Leonard Scandura

Date:

Facility Name:

Crimson Resource Management

Mailing Address:

5001 California Avenue Bakersfield, CA 93301

Contact Name:

Debra Monterroso

Phone:

(661) 716-5001 x11

Project #:

1052797

ERC #'s:

S-2202-1, '2, '3 and '4

Date Received:

May 31, 2005

Date Complete:

June 23, 2005

SUMMARY:

١.

Crimson Resource Management requests emission reduction credit (ERC) banking certificates for emission reductions generated by the replacement of six lean burn, natural gas fired IC engines (S-48-3, '4, '7, '8, '9 and '10) driving gas compressors at the 1-C natural gas processing plant, facility S-48, located at Section 1, Township 32S, Range 23 East, MDB&M. The above-listed engines were replaced with three new, lower emitting IC engine/electric generators driving electric gas compressors. (IC engine '5 has also been permanently shutdown, but as it was not operated within the baseline period there are no actual emissions reductions for this engine.) Actual emission reductions in the amounts shown below were shown to quality for emission reduction credit banking.

Certificate	Pollutani	1 Q (lb/qtr)	2@ (lb/qtr)	E(Q (lb/qtr)	40 (Io/qu)
S-2202-1	VOC	23063	20161	19126	13979
S-2202-2	NOx	4704	3393	3449	2696
S-2202-3	co	16677	10099	8459	5170
S-2202-4	PM10	1745	1292	1258	941

II. APPLICABLE RULES:

Rule 2201: New and Modified Stationary Source Review Rule (April 20, 2005)

Rule 2301: Emission Reduction Credit Banking (December 17, 1992)

III. PROJECT LOCATION:

The 1C gas plant facility (S-48) is located near the intersection of Highway 119 and Midway Road, Taft, Kern County. The facility is located within Section 1, Township 32S, and Range 23E.

IV. EQUIPMENT LISTING:

The descriptions shown below for the shutdown engines are taken from the current Permits to Operate. Engines S-48-27, '28 and '29, which were approved in project 1030826, replaced the service of the shutdown engines. The approval of engines S-48-28, '29 and '30 required that the engines being replaced be designated as emergency standby engines with no more than 100 hrs/yr of operation or be removed from service. Engines '9 and '10 were removed from service and never designated as emergency standby engines. Emergency standby service was implemented for brief periods for engines '3, '4, '7 and '8 prior to the engines being permanently shutdown. The shutdown date for each engine is included under Section VII.F, of this evaluation. Each of the shutdown engines operated as a full time engine during the baseline period.

S-48-3

600 HP CLARK MODEL RA-6 NATURAL GAS-FIRED EMERGENCY STANDBY IC ENGINE POWERING COMPRESSOR S/N A-21184

S-48-4

600 HP CLARK MODEL RA-6 NATURAL GAS-FIRED EMERGENCY STANDBY IC ENGINE DRIVING COMPRESSOR S/N 21167

S-48-7

660 HP CLARK MODEL HRA-6-M NATURAL GAS-FIRED EMERGENCY STANDBY IC ENGINE DRIVING COMPRESSOR S/N 21287

S-48-8

660 HP CLARK MODEL HRA-6-M NATURAL GAS-FIRED EMERGENCY STANDBY IC ENGINE DRIVING COMPRESSOR S/N A-21286

S-48-9

800 BHP NATURAL GAS FIRED CLARK MODEL RA-8 IC ENGINE DRIVING COMPRESSOR, S/N 25748

S-48-10

660 BHP NATURAL GAS FIRED CLARK MODEL HRA-6-M IC ENGINE DRIVING COMPRESSOR, S/N A-21383

V. METHOD OF GENERATING REDUCTIONS:

Actual Emissions Reductions (AER) were generated by the replacement and permanent shutdown of six internal combustion engines driving gas compressors at the I-C gas processing plant.

The gas compression service previously provided by the six subject engines has been replaced by electric motor driven gas compressors that derive their electric power from three natural gas-fired IC engine generators, units S-48-28, -29 and '30. Units 28, -29 and '30 were approved to replace the service of the subject engines in Project 1030826. Each of the replacing engines is rated at 1970 hp, drives a 1469 kw generator and is equipped with a three-way catalyst and air/fuel ratio controllers, and meets the following emissions limits: NOx (as NO2): 5 ppmvd @ 15% O2, CO: 56 ppmvd @ 15% O2, VOC: 25 ppmvd @ 15% O2, and PM10: 0.02 gram/hp hr.

Units S-48-28, 29 and 30 have significantly lower emissions of NOx, VOC, CO and PM10 than the replaced engines, allowing the same level of service and the opportunity to bank credits. To validate the emissions reductions approved for banking as "real" reductions, they have been reduced in amounts equal to the permitted emissions increases approved for units S-48-28, '29 and '30.

VI. CALCULATIONS:

A. Assumptions

- As the applicant has not request Actual Emissions Reductions for SOx, emissions calculation for SOx will not be made.
- Historical Actual Emissions (HAE) were calculated using the actual measured quantities of fuel burned during the two year baseline period and the lower of the Rule 4702 required emissions limit or the source test derived emissions factor for each exhaust stack. (Each engine has two exhaust stacks and each stack was individually source tested. For each engine, the source test derived emissions factors represent the average of the results from the two individually source tested stacks.) The applicant has provided copies of records keep at the facility

("Daily Rounds Report") showing the amounts of fuel used for each engine during the baseline period (Appendix A) and copies of source test reports (Appendix B). The following additional assumptions were made in calculating the HAE:

Heating value

974 Btu/scf, gas sample analysis, Appendix C

Standard Temp

60 °F

O2 Correction

15%

EPA F Factor

8777 dscf/MMBTU gas sample analysis, Appendix C

Molar Volume

379.5 ft³/lb-mol

MW NOx = 46.0 lb/lb-mole, EPA Reference Test Method 7E, Rule 4702 MW CO = 28.0 lb/lb-mole, EPA Reference Test Method 10, Rule 4702 MW VOC = 16 lb/lb-mole, EPA Reference Test Method 25, Rule 4702

As previously discussed, AER were generated by shutting down six IC engine
driven gas compressors and replacing the service provided by those units with
lower emitting IC engine electric generators providing power to drive electric gas
compressors, units S-48-28, '29 and '30. For the emissions reductions to be
considered real, they must be discounted for the approved increases in
permitted emissions from the replacement engines. The permitted emissions for
the replacement units were calculated using emissions factors set forth below,
which were required to satisfy Rule 2201 BACT requirements. The following
assumptions were made in calculating the permitted emissions for each unit:

Engine Rating

1970 BHP

Utilization

8760 hrs/yr

Engine Efficiency

30% (worst-case assumption used in the District calculator

for ppmv to g/Bhp-hr conversion 30%

Standard Temp

60 °F

EPA F Factor

8777 dscf/MMBTU gas sample analysis, Appendix C

Heating value

974 Btu/scf, gas sample analysis, Appendix C

Constant

2542 Btu/BHP-HR

Molar Vol

379.5 ft³/lb-mol

O₂ Correction

15%

B. Emission Factors

Emission Factors used in calculating HAE for eng '3 are shown below:

Emission Factors				
Pollutant	Emission Factors (ppmv @ 15% O2)	Emission Factors (lb/MM Btu)	Reference	
VOC	528	0.692	Rules 4701/4702	
NOx	61.5	0.232	Source Test	
CO	131	0.301	Source Test	
PM ₁₀	-	0.0483	AP-42, Table 3.2-1	

Emission Factors used in calculating HAE for eng '4 are shown below:

Emission Factors				
Poliutant	Emission Factors (ppmv @ 15% O2)	Emission Factors (lb/MM Btu)	Reference	
VOC	710	0.931	Rules 4701/4702	
NOx	28.5	0.107	Source Test	
CO	120	0.275	Source Test	
PM ₁₀	-	0.0483	AP-42, Table 3.2-1	

Emission Factors used in calculating HAE for eng '7 are shown below:

	Emission Factors				
Pollutant	Emission Factors (ppmv @ 15% O2)	Emission Factors (lb/MM Btu)	Reference		
VOC	498	0.653	Rules 4701/4702		
NOx	65	0.245	Rules 4701/4702		
co	293	0.672	Source Test		
PM ₁₀		0.0483	AP-42, Table 3.2-1		

Emission Factors used in calculating HAE for eng '8 are shown below:

Emission Factors				
Pollutant	Emission Factors (ppmv @ 15% O2)	Emission Factors (lb/MM Btu)	Reference	
VOC	725	0.950	Rules 4701/4702	
NOx	64.2	0.242	Source Test	
CO	277.5	0.637	Source Test	
PM ₁₀	-	0.0483	AP-42, Table 3.2-1	

Emission Factors used in calculating HAE for eng '9 are shown below:

Emission Factors				
Pollutant	Emission Factors (ppmv @ 15% O2)	Emission Factors (lb/MM Btu)	Reference	
VOC	327.1	0.429	Source Test	
NOx	65	0.245	Rules 4701/4702	
CO	185.0	0.424	Source Test	
PM ₁₀	-	0.0483	AP-42, Table 3.2-1	

Emission Factors used in calculating HAE for eng '10 are shown below:

Emission Factors				
Pollutant	Emission Factors (ppmv @ 15% O2)	Emission Factors (lb/MM Btu)	Reference	
VOC	324.6	0.425	Source Test	
 NOx	65	0.245	Rules 4701/4702	
со	434.0	0.996	Source Test	
PM ₁₀		0.0483	AP-42, Table 3.2-1	

The following emissions factors were used in calculating the permitted emissions for engines '28, '29 and '30:

	Emission Factors				
	Emission				
Pollutant	Factors	Units	Reference		
VOC	25	Ppmv	BACT Guideline 3.3.12		
NOx	5	Ppmv	BACT Guideline 3.3.12		
CO	56	Ppmv	BACT Guideline 3.3.12		
PM ₁₀	0.02	g/bhp.hr	BACT Guideline 3.3.12		

C. Baseline Period Historical Fuel Usage

The baseline period is defined in Rule 2201, 3.8.1 as the two consecutive years of operation immediately prior to submission of the Complete Application for ERC. The application for ERC was deemed complete on June 23, 2005. District practice is to exclude terminal downtime from the baseline period; that is, the period following the shutdown of equipment but before submission of the complete ERC application.

The baseline period for this project is the consecutive two-year period January, 2003 through December, 2004, which is the most recent period of operation without terminal downtime for the engines taken as a group. The dates the engines were shutdown are included in Section VII. F (Timeliness)

Shown below are the quantities of fuel consumed during the baseline period.

Fuel use by engine for 2003					
	Q1 Mcf/qtr	O2 Mcf/atr	Mei/eu:	Va/qtr	
S-48-3	1402	5000	5087	11811	
S-48-4	10	476	1840	714	
S-48-7	10409	13217	10177	10129	
S-48-8	2398	243	4902	6168	
S-48-9	16169	12805	21661	21658	
S-48-10	15206	14477	14972	15445	

Fuel use by engine for	Fuel use by engine for 2004					
	Q1 Mcf/qtr	Q2 Mcf/qtr	Q3 Mcf/qtr	Q4 Mcf/qtr		
0.40.0	44470	40000	11001	004		
S-48-3	11170	12028	11894	301		
S-48-4	1562	6012	0	0		
S-48-7	1397	2771	6309	1434		
S-48-8	12241	10505	6824	1022		
S-48-9	19290	0	0	0		
S-48-10	15417	7684	0	0		

Fuel use by engine,	Fuel use by engine, average for the two yr baseline period						
	Q1 Mcf/qtr	Q2 Mcf/qtr	io3 Mcf/qtr	Mef/etr			
S-48-3	6286	8514	8490.5	6056			
S-48-4	786	3244	920	357			
S-48-7	5903	7994	824 3	5781.5			
S-48-8	7319.5	5374	5863	3595			
S-48-9	17729.5	6402.5	10830.5	10829			
S-48-10	15311.5	11080.5	7486	7722.5			

D. Calculation of Historical Actual Emissions

Shown below are a set of sample calculations for engine S-48-3 and below that a summary of the HAE for each engine for each pollutant. Spreadsheet calculations for the HAE, AER and bankable AER are included in Appendix D.

Sample Calculations for S-48-3

VOC

6286 (MSCF/qtr) x (974 Btu/scf) x 0.692 lb VOC/MM Btu = 4237 lb VOC/qtr

NOx

6286 (MSCF/qtr) x (974 Btu/scf) x 0.232 lb NOx/MM Btu = 1420 lb NOx/qtr

<u>CO</u>

6286 (MSCF/qtr) x (974 Btu/scf) x 0.301 lb CO/MM Btu = 1843 lb CO/qtr

 $\frac{\text{PM10}}{6286} \text{ (MSCF/qtr)} \times \text{(974 Btu/scf)} \times 0.0483 \text{ lb PM10/MM Btu} = 296 \text{ lb PM10/qtr}$ Historical Actual Emissions (HAE)

Unit	VOC	voc	voc	VOC
	Qtr 1	Qtr 2	Qtr 3	Qtr 4
3	4237	5739	5723	4082
4	713	2942	834	324
7	3754	5084	5243	3677
8	6773	4973	5425	3326
9	7408	2675	4525	4525
10	6338	4587	3099	3197
HAE Total	29223	25999	24849	19131

Unit	NOx	NOx	NOx	NOx
	Qtr 1	Qtr 2	Qtr 3	Qtr 4
3	1420	1924	1919	1368
4	82	338	96	37
7	1409	1908	1967	1380
8	1725	1267	1382	847
9	4231	1528	2584	2584
10	3654	2644	1786	1843
HAE Total	12521	9608	9734	8060

Unit	СО	co	co	CO
	Qtr 1	Qtr 2	Qtr 3	Qtr 4
3	1843	2496	2489	1775
4	211	869	246	96
7	3864	5232	5395	3784
8	4541	3334	3638	2230
9	7322	2644	4473	4472
10	14854	10749	7262	7492
HAE	1			
Total	32634	25325	23503	19849

Unit	PM10	PM10	PM1 0	PM10
	Qtr 1	Qtr 2	Qtr 3	Qtr 4
3	296	401	399	285
4	37	153	43	_ 17
7	278	376	388	272
8	344	253	276	169
9	834	301	510	509
10	720	521	352	363
HAE Total	2509	2005	1968	1616

E. Permitted Emissions for Replacement Engines

Summarized below are the potentials to emit (permitted emissions) for the three replacement engines, S-48-28, '29 and '30. These potentials will be subtracted from the HAE to obtain actual emission reductions. Permitted emissions for each air contaminant are the same for each calendar quarter. The calculation spreadsheet results and example calculations are included as Appendix E.

Unit	voc	NOx	со	PM10
	lb/qtr	lb/qtr	lb/qtr	lb/qtr
28	1199	690	4701	190
29	1199	690	4701	190
30	1199	690	4701	190
Total	3598	2069	14104	570

F. Actual Emissions Reductions (AER), Air Quality Improvement Deduction (10% of AER), NOx Reductions Required by Mutual Settlement Agreement and Bankable AER

Pursuant to Section 4.12 of Rule 2201, AER shall be calculated, on a pollutant-by-pollutant basis, as follows:

AER = HAE – PE2; Where, HAE = Historic Actual Emissions PE2 = Post-Project Potential to Emit

The PE2 for the shutdown engines is zero.

The AER have been reduced by the permitted emissions approved for the replacement engines, by a further10%, for an Air Quality Improvement Deduction (AQID) and, for NOx, by the 50% reduction in credits required as a result of the settlement agreement entered into between the District and Crimson Resource Management Corporation on April 6, 2005.

The bankable AER are summarized below:

	VOC	VOÇ	voc	voc
	Qtr 1	Qtr 2	Qtr 3	Qtr 4
HAE Total	29223	25999	24849	19131
Permitted Emissions	3598	3598	3598	3598
AER	25625	22401	21251	15533
AQID	2563	2240	2125	1553
Bankable AER	23063	20161	19126	13979

	NOx	NOx	NOx	NOx
	Qtr 1	Qtr 2	Qtr 3	Qtr 4
HAE Total	12521	9608	9734	8060
Permitted Emissions	2069	2069	2069	2069
AER	10452	7539	7665	<u>59</u> 91
AQID	1045	754	767	599
Reduction Req'd By Settlement	4703	3392	3449	2696
Bankable AER	4704	3393	3449	2696

	co	CO	СО	CO
	Qtr 1	Qtr 2	Qtr 3	Qtr 4
HAE Total	32634	25325	23503	19849
Permitted Emissions	14104	14104	14104	14104
AER	18530	11221	9399	5745
AQID	1853	1122	940	575
Bankable AER	16677	10099	8459	5170

	PM10	PM10	PM10	PM10
	Qtr 1	Qtr 2	Qtr 3	Qtr 4
HAE Total	2509	2005	1968	1616
Permitted Emissions	570	570	570	570
AER	1939	1435	1398	1046
AQID	194	143	140	105
Bankable AER	1745	1292	1258	941

VII. COMPLIANCE:

To be eligible for banking, emission reduction credits (ERC's) must be verified as being real, enforceable, quantifiable, permanent, and surplus pursuant to District Rules 2201 and 2301. In addition, the application must be submitted within 180 days of when the reduction occurred (Rule 2301, 4.2.3).

A. Real

The AERs quantified in this project were based on actual, historical emissions from the six subject engines located at the IC gas plant, as they were operated during the baseline period. The engines have been permanently shutdown and the permits surrendered. The emissions from the replacement engines, IC engine/generators '28.'29 and '30, have been assessed at 100% capacity and utilization and have been subtracted from the HAE as required by District Rule 2201.

IC engines '28, 29 and '30 and the gas compressors attached to those generators handle all of the natural gas compression workload at the plant that was previously handled by the six shutdown engines. There are two additional full time use IC engines permitted at the 1-C plant, units '11 and '24, but these engines are used to compress propane, which is the refrigerant in a separate heat exchange system at the plant and are not available to pick up any of the natural gas compression workload. Emissions from engines '28, '29 and '30 have been accounted for at the stationary source and have been subtracted from HAE as required by District Rule 2201.

The 1C gas plant is subject to ongoing District inspection that has confirmed the shutdown engines are no longer operational at cannot be relocated and re-started within the air basin.

Therefore, the reductions are real.

B. Enforceable

The reductions are enforceable in that the subject engines have been rendered permanently inoperable and the emissions from the replacement engines have been fully accounted for at the stationary source. The replacement engines have satisfied all applicable New Source Review requirements, including BACT, offsets and noticing.

Therefore the reductions are enforceable.

C. Quantifiable

The AERs were calculated using the actual quantities of fuel burned in each engine in the baseline period. The amounts of fuel burned were determined from copies of the "Daily Rounds Report" that were kept and recorded daily by the plant operator. The "Daily Rounds Report" shows the daily and cumulative fuel burned for each engine (MSCF). For NOx, CO and VOC, the emissions factors used were the lower of the source test derived values or the emissions limits required by Rule 4702. For PM10, an emissions factor from AP-42, Table 3.2-1, *Uncontrolled Emissions For 2-Stroke Lean Burn Engines*, was used.

Therefore the reductions have been properly quantified.

D. Permanent

The permits for the subject engines have been cancelled. The District will verify through on-site inspection that the equipment has been rendered permanently inoperable.

The reductions are considered permanent.

E. Surplus

Rule 2201 New and Modified Source Review (NSR)

Approval of replacement engines S-48-28, '29 and '30 required that the permitted emissions increases from these engines be mitigated as required under the provisions set forth in Rule 2201. As the emission reduction credits being granted in this project have been reduced by the permitted emissions increases from engines S-48-28, '29 and '30, full mitigation has occurred and the remaining emissions reduction credits are surplus of NSR requirements.

Rule 4701 (Internal Combustion Engines – Phase 1)

For lean burn engines, this rule requires emissions levels not exceeding 75 ppmv NOx, 2000 ppmv CO and 750 ppmv VOC, all at 15% O2. For NOx, CO and VOC, the HAE and AER were calculated in this project using the lower of the source test derived emissions factor or the rule required emissions limit. Thus, by the manner in which they were quantified, the HAE, AER and ERC approved in this project are surplus of the reductions required by this rule.

Rule 4702 (Internal Combustion Engines - Phase 2, as amended 4/20/06)

For lean burn engines, this rule proposes emissions levels not exceeding 65 ppmv NOx, 2000 ppmv CO and 750 ppmv VOC, all at 15% O2. For NOx, CO and VOC, the HAE and AER were calculated in this project using the lower of the source test derived emissions factor or the rule required emissions limit. Thus, by the manner in which they were quantified, the HAE, AER and ERC approved in this project are surplus of the reductions required by this rule. It is noted that each of the replaced engines was permanently shutdown prior to the earliest compliance date set forth in this rule, June 1, 2005 for 25% of the engines at a stationary source.

Settlement Agreement of April 6, 2005

As stipulated in the settlement agreement entered into between the District and Crimson Resource Management on April 6, 2005, Crimson agreed to surrender one-half of any NO_x generated and approved by the District as a result of the genset electrification project at the 1C Gas Plant. The NO_x ERC approved in this project have been reduced by one-half, and are thus surplus of the reduction required of the settlement agreement.

There are no emission reductions required for the engines under evaluation in this project by any other rule, regulation, agreement, or order of the District, State, or Federal Government, either existing, noticed for workshop, or proposed or contained in a State Implementation Plan. The reductions are surplus.

F. Timeliness

Applications for ERC were received on May 31, 2005, which was within 180 days of the date of reduction. Effective on the dates listed below, the operator notified the District that the engines were permanently shutdown and requested cancellation of the permits.

Crimson Resource Management, S-48 Project 1052797

<u>Unit</u>	Date of Shutdown
S-48-3	July, 2005
S-48-4	January 10, 2005
S-48-7	May 5, 2005
S-48-8	May 5, 2005
S-48-9	December 2, 2004
S-48-10	December 2, 2004

The dates that operator notified the District are the dates the reductions officially occurred. The applications were filed within 180 days of the dates the reductions occurred, thus the applications were timely.

VIII. RECOMMENDATION:

After public notice, review by the EPA and ARB, and after addressing any comments received during the noticing period, issue ERC Banking Certificates to Crimson Resource Management in the amounts shown in Section 1 of this evaluation.

Appendix A RAW Fuel Use Records

1C Gas Plant Fired Equipment Daily Rounds Report

Date: 1 - 2 - 63

3.598

Hot oil Skid

Night Operator Signature SchlichN Day Operator Signature Compressors Compressor Discharge Temperatures Wir Wir Oil Oil Oil Fuel Temp Temp Temp Press Used Crank Case Power Cylinder Temperatures Clark #2 570 38 560 520 580 94 Clark #5 2208 自12312 12047 177 Clark #6 200 231 215 580 612 50 900 350 590 50 500 67 yark #1 20 Are One Shot 200 213 On? JE .K-2 Lubricators Full? XVG Elect Assist Are One Shot Lubricators Full? R:0.System Pump. Auxillary **Emergency** Flow Rate Pass Press. Air Flare Seals Filter_D. P 1 st. | 2 nd. | 2 nd. | 1 st. | Final Pres Compressor 35 Up - Down Equipment P-5A Water Meter Reading Equipment Hrs. Hrs. Prev. Today Fuel F-1 Read Read Used Today-P-6A Yesterday P-6B F-2 -P-7A P-7B P-8A P-8B Stand By Electric Generators Hot Oil Skid **Fuel Chart Readings** Fuel Fuel Diff. Oil Fuel Tank Bat. Wtr. Hours Hours Prev. Today Fuel Equipment Coef. Static Hours Hours Prev. Today Fuel Temp Press Level Level Volt Temp. On Off Read Read Used RPM .~Qft Read -Used K21K3 3.01

1C Gas Plant Fired Equipment Daily Rounds Report Date: 3-30-03 Night Operator Signature Most Day Operator Signature Compréssors Wtr Wtr Oil Oil Oil Fuel Temp Temp Temp Press Used Compressor Discharge Temperatures Fuel Today Hrs Off Power Cylinder Temperatures Equip. R.O. ∑)Clark # 260 262 255 560540 520 520 40 42 DClark #6 Clark #1 1858 Clark #15 Clark #16 XVG Are One Shot On? Lubricators Full? XVG Elect Assist Are One Shot K-3 On? Lubricators Full? R.O. System **Auxillary Emergency Pump** Flow Rate Air Pass Press. Flare Seals Filter D. P 1 st. | 2 nd. 2 nd. 1 st. Final Compressor **OK** Leaks Up Down Equipment P-5A Water Meter Reading Equipment Hrs. Prev. Today Fuel F-1 Read Read Used 40 Today P-6A Yesterday P-68 F-2 135 Total 4-1A P-8A Stand By Electric Generators Hot Oil Skid Fuel Chart Readings Fuel Fuel Fuel Fuel guipment Eng Oil Fuel Tank Bat. Wtr. Hours Hours Prev. Today Fuel Static Diff. Hours Hours Prev. Today Fuel Equipment Coef.

Off Read Read

Used

K2 / K3

Hot oil Skid

Off Read Read Used

Comments:

500 KW

50 KW

Temp Press. Level Level Volt. Temp. On

10 Gas Plant Fired Equipment Daily Rounds Report Night Operator Signature 2D NITRO Date: 6-30-03

Day Operator Signature Bob Pust

								ren er G					Con	npr	ess	ors									40.00		id Vi
Equip.	Eng RPM	R.O. Rate		presso Tempe #2	r Discleratures	harge 3 #4	#1	P #2	ower C #3	ylinde #4	r Tem #5	peratui #6	res #7	#8	Wtr Temp In	Wtr Temp Out	Oil Temp In	Oil Temp Out	Oil Press	Fuel Used	Fuel Today Yesterday	Hrs On	Hrs Off	Crank Case Meter	Power Cyl. Meter	Comp. Cyl. Meter	
Clark #1	310		230	260	280		6 an	కరు	SYS	600	58 0	619			140	140	140	/80	35		27778	24	8	0423	4026	7269	1
Clark #2																					7932 7932						2
Clark #5	300		240	260	28,0		620	ලන	610	SPO	ଦେଅ	ಡ್ಡು			140	143	14 ن	(85	35		50251 5025	24	45	5723	793931	230054	5
Clark #6																					29827						6
)rk #12					:																26481						12
Clark #14			210	220												98	9.0		45			24	6	7/5"		1016	14
Clark #15							7.0																				15
Clark #16	320		28	વ્યહ	2 C S		G 8	ಕ್ಟ				රුව			140	142			35		79009 78773	24	-	8209	553783	161471	16
XVG K-2	330		/40	140	150	140	Elect A	Assist		One S ators		v			135	190			<i>3</i> 0			24	6			38552	K-2
XVG K-3	335		149	197	/S	1/ 6./3	Elect / On?	V€.5	Are Lubric	One S ators					ומנו	143			42			24	-13	5706		24259	к-3
	nlet	1	₹ ® Pass F	Section Cont. Trans.	Contract Contract	n Iow Ra	le l	Pump	·					(4) (4)	xilla Air							erg		Ten 62		imp:	

Inlet	Pass	Press.	F	ow Ra	te	Pump
Filter D. P.	1 st.	2 nd.	2 nd.	1 st.	Final	Press
						İ
		1				
	Water N	leter Re	eading			
To	day					
Yest	erday					
· To	otal					

	Au Con	Air		
Equipment	Hrs. On	Hrs. Off	Fuel Today Read	
4-1A	ϵ	રા જા		

Emerg Fla	enc re	У
Equipment	Up	Down
F-1	191	
F-2	182	

		imp als
Pump	ок	Leaks
P-5A		
P-5B	4	
P-6A	-	
P-6B	1.	
P-7A	t.e.	
P-7B	5	
P-8A	٤	
P-8B	(Z	

		S	tand	By	Ele	ctri	o Ge	ener	ato	rs			
					•	Fuel			_		Fuel	Fuel	
Equipment	Eng		Oil	Oil	Fuel	Tank	Bat.	Wtr.	Hours	Hours	Prev.	Today	Fuel
	RPM		Temp	Press.	Level	Level	Volt.	Temp.	On	Off	Read	Read	Used
500 KW									-6-	24			
150 KW									-&-	24			

	Hc	t O	il SI	∢id .
		Fuel	Fuel	
Hours	Hours			Fuel
On	Off	Read	Read	Used
24	6			

Fue	l Chai	f Readi	ngs
Equipment	Coef.	Static	Diff.
K2 / K3	3.01	7.4	5-4
Hot oil Skid	3.598		

Co	m	m	er	ıts
----	---	---	----	-----

TO Gas Plant Filed Equipment Daily Rounds Report

Date: 9-30:03 Night Operator Signature Must Compressors Compressor Discharge Temperatures #1 #2 #3 #4 Wir Wir Oil Oil Oil Fuel Temp Temp Temp Press Used Fuel Today Power Cylinder Temperatures Equip. R.O. #4 #5 Clark #1 294 4026 Clark #2 096121 56985 Clark #5 197 1235 245 Clark #6 39549 XVG Elect Assist Are One Shot K-2 On? Lubricators Full? XVG Elect Assist Are One Shot 01.585 On? Lubricators Full? K-3 Pump: R O System Auxillary Emergency Flow Rate Air Pass Press. Flare :: Seals Filter D. P. 1 st. 2 nd. 2 nd. 1 st. Final Press Compressor Leaks OK Pumo Up Down Equipment P-5A P-5B Water Meter Reading Equipment Hrs. Hrs. Prev. Today Fuel F-1 166 Read Read Used P-6A Today P-6B Yesterday F-2 P-7A Total 4-1A P-7B P-8A P-8B

	•	Stanc	1 By	Lie	CITI	CG	enei	rato	rs		
Jipmeni	Eng RPM	Oil Temp					Wtr. Temp.				
30 KW								A	24		
-30 KW								6	24	ļ.	

	Prov	Today	Fuel
ours Hours On Off		Read	Used

Fu	el Cha	rt Readi	ngs
Equipment	Coef.	Static	Diff.
K2 / K3	3.01	9.4	2.5
Hot oil Skid	3.598	6.5	3.0

Comments:

TO Gas Flant Fired Equipment Daily Rounds Report

Date: 12-31-03 Night Operator Signature ED WITKO Day Operator Signature Col Price Compressors Compressor Discharge Temperatures Wtr Wtr Oil Oil Oil Fuel Temp Temp Temp Press Used Hrs Off **Power Cylinder Temperatures** Equip. R.O. Rate Today On #4 #5 Meter Yesterday 445 7 7769 4026 Clark # 310 YES 220 240 260 120 130 Đ 10486 Clark #2 Clark #5 YES 230 245 240 Clark #6 325 130 100 44 140 40 192 240 280 260 Clark #1-Clark #1: 60 2 000 9426 Clark #16**[**경우교 514 125 سيز 28> 250 280 XVG Elect Assist Are One Shot C\$571 120 120 140 45 On? 1/25 K-2 Lubricators Full? XVG Elect Assist Are One Shot K-3 On? Lubricators Full? R. C. System Auxillary Emergency Pump Flow Rate Air Seals Flare ... Filter D. P. 1 st. 2 nd. 2 nd. 1 st. Final Pres Compressor Leaks Equipment Up Down P-5A Water Meter Reading Equipment Hrs. Hrs. Prev. Today Fuel P-58 F-1 Read Read Used P-6A Today Yesterday P-6B F-2 Total 4-1A P-7A P-7B P-8A Fuel Chart Readings Stand By Electric Generators Hot Oil Skid Equipment Eng Oil Fuel Tank Bat. Wtr. Hours Hours Prev. Today Fuel Hours Hours Prev. Today Equipment Coef. Diff. Fuel Temp Press. Level Level Volt. Temp, On Off Read Read Used Off Read Read Used **RPM** K2 / K3 500 KW 2.3 3.01 9.7 150 KW 3.598 tot oil Skid

Comments:

12

1C Gas Plant Fired Equipment Daily Rounds Report

The control of the company of the control of the co

Date: 3-29-04

	Day	Opera	tor Sig	nature_	(८०८	· Yhi	د						Nigh	t Oper	ator :	Signatur	e <u>Varr</u>	<u>ب کد</u>	11/11	rand			
									7 44		Comp	oress	ors										
Equip.	Eng RPM	R.O. Rate	Comp Te	ressor Dis emperatur #2 #		#1		er Cylind		peratures #6		Wtr Temp	Wtr Temp Out	Oil Temp To	Oil emp P Out	Oil Fuel ress Used	Fuel Today Yesterda	Hrs On v	Hrs Off	Crank Case Meter	Power Cyl. Meter	Comp. Cyl. Meter	
Clark #	1																55841 55267		ے				
Clark #2																	12048		24				
Clark #5																	71855	7	0				T
Clark #6										·							53/39		24				Ţ
C)#1:																	89090 88020	2	B				T
Clark #1																		24	Ð				Ī
Clark #15								ju vi										1	24				Γ
Clark #16																	24947	724	Ð				
XVG K-2						Elect As: On?		Are One bricators					1					H	24	-	1 1		K
XVG K-3						Elect As: On?		Are One bricators		1_2								24	D				ĸ
1	Inlet er D. P.		Pass Pro	ess.	Flow Ra	ite Pi Final P	ump ress					uxilla Air mpre	ssoi				En Equipr	ierge Flar	e s		Se Pump OK	mp als: Leaks	
			Vater Met	er Readin	g	·			ĺ	Equipm		Hrs.		oday Fu			F-1				P-5A P-5B		
上		Today Yesterd									On		Read F	Read Us	ea		F-2		196		P-6A P-6B		
		Total			-				[4-1A	· B	124				<u> </u>			<u> 14</u>		P-7A P-7B P-8A P-8B		:
		S	tand l	By, El		c Gen	erate	orsi					100 Par 100	Oil :	73	d ,		1	Fue	el Char	t Readin	gs	
Equipment	Eng RPM					Bat. W Volt, Te				Today F		Hours I	Hours F	Fuel Fü Prev. Too Read Re	lay	Fuel Used		Equipr	ment	Coef.	Static	Diff.	
500 KW												21/2	<u>a</u>					K2/	L	3.01	9.6	2,4	
150 KW								<u> </u>					Ď					Hot oil	Skid	3.598	6.4	3.2	
Com	ments	:	ï	op tu	de	entir	y to	<u>ike</u> i	r 4	-2-0	14 E	9:0	<u>v0 v</u>	qui	٠ د								


1C Gas Plant Fired Equipment Daily Rounds Report

Day Operator Signature SULIVAN

Comments:

Night Operator Signature Nitro

Date: 6-30-04



1C Gas Plant Fired Equipment Daily Rounds Report

Day Operator Signature Price

Date: 9-26-08

Night Operator Signature Nitto

					Sinte		<u> </u>				ing Ngjarjara		Co	mpi	ress	ors			i Na	4				<u> </u>		ing and the second of the seco	
Equip.	Eng RPM	R.O. Rate	Cor	npresso Tempe #2	or Disc eratures #3	harge s #4	#1	F #2	ower C	ylinde #4	r Tem	peratu	res #7	#8	Temp	Wtr Temp Out	Oil Temp	Oil Temp Out	Oil Press	Fuel Used	Fuel Today Yesterday	Hrs On		Crank Case Meter	Power Cyl. Meter	Comp. Cyl. Meter	
Clark #1	,		210	271	150										125			裁定	3%		79764	-					T
Clark #																						-					Ţ
Clark #5	302	10	220	229	235										125	136		-	37		81634						
Clark #6				1						-											70467	1					
): #12											.,.											0	24				T
Clark #14			240	724												87			49					3 034		46619	1
Clark #15			255	265												49	7		77					0871		31000	Ţ
Clark #16																-					32527 32527						,
XVG K-2							Elect A	ssist		One S ators f																	K
XVG K-3	335		140	141	190	193	Elect A	ssist	Are C	One S ators F					/30	134			43					6429		00966	ĸ
	nlet r D. P.		R.O. Pass I 1 st.	ress.	F	ow Ra	le Final	Pump Press							xilla Air						Em	erge Flar		y	Harite in Industry in 19	mp als	
-				.									<u> </u>	Com	pre	SSO					Equipme	ent	Up	Down	Pump OK	Leaks	
		V Today	Valer Mi	eter Rea	ading	,,					į	Equip	ment i				Today F Read L			ľ	F-1				P-5B P-6A		
	Ý	esterda Total										4-1	Α								F-2				P-6B P-7A		
				,							ļ														P-78 P-8A P-8B		ı
		St	and	Ву	Elec	ctric	Gei	nera	ators	3	Lota V Potas					Но	t Oil	Sk	id				Fue	l Char	t Readin	gs	
uiomen	Ena		Oil	Oil	Fuel	Fuel Tank	Bat '	Wir F	Hours H		Fuel		Fuel		Hours F		Fuel f		Fue			Fauina		Coef	Static	Diff.	

Off Read Read

Used

K2 / K3

Hat oil Skid

3.01

3.598

On

Off Read Read Used

						•
Co	m	m	е	ni	s	:

500 KW

150 KW

RPM

Temp Press, Level Level Volt, Temp. On

1C Gas Plant Fired Equipment Daily Rounds Report

Date: 12-3/-64 Morning Tower Operator Signature NHO

	Day () Operat	or Si	gnatı	ire	Pri	<u>ر و</u>				_			M	orning	Towe	r Ope	erato	Signatur	e	Nito				
	3 6 14 3 17 6				7 2 12												45.00		Ĥ					12 de 10 13 de 10	
Equip.	Eng RPM	R.O. Rate	Con #1	npresso Tempe #2	or Disci ratures #3	narge ; #4	#1	Power (Cylinder #3	Temper #4	rature: #5	s #6	Wtr Temp in	Wtr Temp Out	Oil Temp	Oil Temp Out	Oil Press	Fuel Used	Fuel Today Yesterday	Hrs On	Hrs Off	Crank Case Meter	Power Cyl. Meter	Comp. Cyl. Meter	
Clark #1	I KE IVI	Nate	TF 1	#2	1		<i>T</i> 1	#2	#3	17-4	#J	#9		000		Out			80069 80069			Motor	T T T T T T T T T T T T T T T T T T T		1
Clark #3			195	260	215												46			24	.6	1311	88734	143198	3
Clark #5																			830G 830G						5
Clark #6							-												71489						6
Clark #12		13 U	200	205	230	25€													1	24.	6-	5903			12
Clark #14														·						24	&-	3349		29483	14
Clark #15																			y inte						15
Clark #16								4.0																	16
XVG K-2			·····				Elect A	\ssist		One Sho ators Fu	- 1													•	K-2
XVG K-3	3 <i>3</i> 6		120	120,	45	lle	Elect A	Assist Y&∫	Are	One Sho ators Fu	ot	~	85	100			52		100	24	6	6509		15743	K-3

200	(U.	SYS	ten	1		
Total						Pump
D. S.	1 st.	2 nd.	2 nd.	1 st.	Final	Press
				,		L{
						Ī
<u>_</u>	vater M	eter Ke	ading			
Today						
esterda	У					
Total						
	D. S. V Today esterda	D. S. 1 st. Water M Today esterday	D. S. 1 st. 2 nd. Water Meter Re Today esterday	D. S. 1 st. 2 nd. 2 nd. Water Meter Reading Today esterday	D. S. 1 st. 2 nd. 2 nd. 1 st. Water Meter Reading Today esterday	D. S. 1 st. 2 nd. 2 nd. 1 st. Final Water Meter Reading Today esterday

7 1 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2		uxill Air mpr)r:	
Equipr	nent H	lrs.	Fuel Prev.	Fuel Today Read	Fuel
	Qn	Off	Read	Read	Used
4-1A	<u>.</u>	24	}		1.

Emerg Flar		y.
Equipment	Uр	Down
F-1	200	
F-2	140	

	Pu Se	ımp als
Pump	ок	Leaks
P-5A		
P-5B	v	
P-6A	J	
P-6B	Ψ,	
P-7A	J	
P-78	~	
P-8A	~	
P-8B		

		Sta	nd E	Зу Е	lect	ric (3en	erat	ors	Ţ.		
Equipment	Eng RPM	Oil Level	Oil Temp	Oil Press.	Day	Level Storg. Tank	Bat. Volt.	Wtr. Temp.	Hours On	Hours Off	Fuel Prev. Read	Fuel Today Read
500 KW									E	29		
150 KW									e	24		

Hc	t Oi	Skid
Hours On	Hours Off	Fuel Used
24	ф	

Fue	l Charl	Readin	gs
Equipment	Coef.	Static	Diff.
K2 / K3	3.01		
Hot oil Skid	3.598		

Comments:

Appendix B Engine Source Test Results

Crimson Resource Management Taft Area IC Engine 7D 1 - North Stack Project 129-3370D October 24, 2003 Permit No. S-48-3-3

		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O _z	Limits
	58	142	47	
NOx	58	144	48	
	75	181	60	
Mean	64	156	52	75 ppm @ 15% O ₂
	145	356	117	
CO	142	353	116	
	141	341	112	
Mean	143	350	115	2000 ppm @ 15% C
	382.0	936.6	308,7	
VOC	383.2	952.7	314.1	
C_3 - C_6 + as C_1	371.8	899.4	296,4	
Mean	379.0	929.6	306.4	750 ppm @ 15% O
Comments:				
				
			·	
				, <u>, , , , , , , , , , , , , , , , , , </u>

Crimson Resource Management Taft Area IC Engine 7D 1 - South Stack Project 129-3370D October 24, 2003 Permit No. S-48-3-3

-		ррт @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits ·
	79	214	71	
NOx	81	220	72	
	77	212	70	
Mean	79	215	71	75 ppm @ 15% O ₂
	156	423	139	
CO	164	445	147	
	171	471	155	
Mean	164	446	147	2000 ppm @ 15% O
	1917.3	5199.9	1713.9	
VOC	1976.3	5359.9	1766.7	
$C_3 \cdot C_6 + as C_1$	1743.8	4802.1	1582.9	
Mean	1879.1	5120.6	1687.8	750 ppm @ 15% O ₂
Comments:				
2 3111111211231	-			
		 -	·····	

Crimson Resource Management Taft Area I C Engine 2 - North Stack Project 129-3370A August 29, 2003 Permit No. S-48-4-3

		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	34	85	28	
NOx	36	91	30	
	38	93	31	
Mean	36	90	30	75 ppm @ 15% O ₂
	153	380	125	
co	155	391	129	
	151	370	122	
Mean	153	380	125	2000 ppm @ 15% O
	1772.1	4405.7	1452.1	·
voc	1846.2	4654.4	1534.1	
C ₃ - C ₆ + as C ₁	1906.6	4675.1	1541.0	
Mean	1841.6	4578.4	1509.1	750 ppm @ 15% O ₂
Comments:				
			- · · · · · · · · · · · · · · · · · · ·	
			·	

AEROS ENVIRONMENTAL, INC.

Summary Of Results

Crimson Resource Management Taft Area IC Engine 2 - South Stack Project 129-3370A August 29, 2003 Permit No. S-48-4-3

The second secon		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	36	79	26	
NOx	38	84	28	
	36	81	27	
Mean	37	81 .	27	75 ppm @ 15% O ₂
	160	349	115	
co	159	351	116	
	154	345	114	
Mean	158	348	115	2000 ppm @ 15% O
	968.2	2113.5	696.7	
voc	890.9	1968.8	648.9	
C_3 - C_6 + as C_1	898.3	2009.9	662.4	
Mean	919.1	2030.7	669.3	750 ppm @ 15% O ₂
Comments:	· · · · · · · · · · · · · · · · · · ·			
				

Crimson Resource Management Taft Area IC Engine 5 - North Stack Project 129-3370A August 27, 2003 Permit No. S-48-7-3

		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	109	250	82	
NOx	116	263	87	
	116	273	90	
Mean	114	262	86	75 ppm @ 15% O ₂
	321	737	243	
CO	345	782	258	
	336	791	261	
Mean	334	770	254	2000 ppm @ 15% O
	332.9	764.0	251.8	
voc	333.4	755.4	249.0	
C ₃ - C ₆ + as C ₁	306.6	722.2	238.1	
Mean	324.3	747.2	246.3	750 ppm @ 15% O
Comments:				

		·-·-		

Crimson Resource Management Taft Area IC Engine 5 - South Stack Project 129-3370A August 27, 2003 Permit No. S-48-7-3

		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	94	267	88	
NOx	92	266	88	
	100	280	92	
Mean	95	271	89	75 ppm @ 15% O ₂
	343	975	321	
co	365	1054	347	
	356	996	328	
Mean	355	1008	332	2000 ppm @ 15% O ₂
	1824.5	5183.9	1708.7	
voc	1934.7	5585.7	1841.1	
C ₃ - C ₆ + as C ₁	1936.6	5416.5	1785.3	
Mean	1898.6	5395,4	1778.4	750 ppm @ 15% O ₂
Comments:				
			WI	
· · · · · · · · · · · · · · · · · · ·				
		 .		
			<u>-</u>	
				·
		,,		
			<u>. </u>	

Crimson Resource Management Taft Aera IC Engine 6 - North Stack Project 129-3370B October 2, 2003 Permit No. S-48-8-3

18 To 18 To 18 About a a consultament come, po		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	82.5	183.9	60.6	
NOx	94.4	205.1	67.6	
	86.6	190.2	62.7	
Mean	87.8	193.1	63.6	75 ppm @ 15% O ₂
	432	963	317	
CO	450	978	322	
	459	1008	332	
Mean	447	983	324	2000 ppm @ 15% O
	1014.8	2262.0	745.6	
voc	1034.4	2247.1	740.6	
C3 - C6+ as C1	851.1	1869.3	616.1	
Mean	966.8	2126.1	700.8	750 ppm @ 15% O ₂
Comments:				
11				
**************************************	, us			-
			,	·

Crimson Resource Management Taft Aera IC Engine 6 - South Stack Project 129-3370B October 2, 2003 Permit No. S-48-8-3

Pollutant	ppm	ppm @ 3% O ₂	ppm @ 15% O ₂	Permit Limits
<u> </u>	66.5	197.1	65.0	
NOx	62.8	187.7	61.9	
	68.2	204.1	67.3	
Mean	65.8	196.3	64.7	75 ppm @ 15% O ₂
	239	708	233	
CO	224	669	221	
	242	724	239	
Mean	235	700	231	2000 ppm @ 15% O ₂
	1721.2	5100.9	1681.3	
voc	1796.9	5369.7	1770.0	
C3 - C6+ as C1	1911.4	5721.5	1885.8	
Mean	1809.8	5397.4	1779.0	750 ppm @ 15% O ₂
Comments:				
	A			
				
<u> </u>	·			
	<u> </u>			· <u>·</u> ····

Crimson Resource Management Taft Area IC Engine 12 North Stack Project 129-3370E November 26, 2003 Permit No. S-48-9-4

NOx 178.5 410.2 135.2 165.3 377.9 124.6 Mean 178.5 413.9 136.4 75 ppm @ 15% O ₂ CO 212 487 161 217 496 164 Mean 222 515 170 2000 ppm @ 15% O VOC 342.4 786.8 259.3 C ₃ - C ₆ + as C ₁ 268.7 614.2 202.5 Mean 300.9 697.2 229.8 750 ppm @ 15% O ₂ Comments:	Pollutant	ppm	ppm @ 3% O₂	ppm @ 15% O ₂	Permit Limits
Mean 165.3 377.9 124.6 Mean 178.5 413.9 136.4 75 ppm @ 15% O₂ CO 237 561 185 CO 212 487 161 217 496 164 Mean 222 515 170 2000 ppm @ 15% O₂ VOC 342.4 786.8 259.3 C₃ - C₅+ as C₁ 268.7 614.2 202.5 Mean 300.9 697.2 229.8 750 ppm @ 15% O₂		191.6	453.7	149.5	
Mean 178.5 413.9 136.4 75 ppm @ 15% O₂ CO 237 561 185 CO 212 487 161 217 496 164 Mean 222 515 170 2000 ppm @ 15% O₂ VOC 342.4 786.8 259.3 C₃-C₅+ as C₁ 268.7 614.2 202.5 Mean 300.9 697.2 229.8 750 ppm @ 15% O₂	NOx	178.5	410.2	135.2	
CO 212 487 161 217 496 164 Mean 222 515 170 2000 ppm @ 15% O VOC 342.4 786.8 259.3 C ₃ -C ₆ + as C ₁ 268.7 614.2 202.5 Mean 300.9 697.2 229.8 750 ppm @ 15% O		165.3	377.9	124.6	
CO 212 487 161 217 496 164 Mean 222 515 170 2000 ppm @ 15% O 291.7 690.7 227.7 VOC 342.4 786.8 259.3 C ₃ -C ₆ + as C ₁ 268.7 614.2 202.5 Mean 300.9 697.2 229.8 750 ppm @ 15% O	Mean	178.5	413.9	136.4	75 ppm @ 15% O ₂
Mean 217 496 164 Mean 222 515 170 2000 ppm @ 15% O 291.7 690.7 227.7 VOC 342.4 786.8 259.3 C ₃ - C ₆ + as C ₁ 268.7 614.2 202.5 Mean 300.9 697.2 229.8 750 ppm @ 15% O		237	561	185	<u> </u>
Mean 222 515 170 2000 ppm @ 15% O VOC 342.4 786.8 259.3 C ₃ - C ₆ + as C ₁ 268.7 614.2 202.5 Mean 300.9 697.2 229.8 750 ppm @ 15% O ₂	co	212	487	16 1	
VOC 342.4 786.8 259.3 C ₃ - C ₆ + as C ₁ 268.7 614.2 202.5 Mean 300.9 697.2 229.8 750 ppm @ 15% O ₂		217	496	164	
VOC 342.4 786.8 259.3 C ₃ - C ₆ + as C ₁ 268.7 614.2 202.5 Mean 300.9 697.2 229.8 750 ppm @ 15% O	Mean _	222	515	170	2000 ppm @ 15% O
C ₃ - C ₆ + as C ₁ 268.7 614.2 202.5 Mean 300.9 697.2 229.8 750 ppm @ 15% O ₂		291.7	690.7	227.7	
Mean 300.9 697.2 229.8 750 ppm @ 15% O	VOC	342.4	786.8	259.3	
	C3 - C6+ as C1	268.7	614.2	202.5	
Comments:	Mean	300.9	697.2	229.8	750 ppm @ 15% O
		· · · · · · · · · · · · · · · · · · ·			<u></u>
	·				· · · · · · · · · · · · · · · · · · ·
					

Crimson Resource Management Taft Area IC Engine 12 South Stack Project 129-3370E November 26, 2003 Permit No. S-48-9-4

	ppm @	ppm @	Permit
ppm	3% O ₂	15% O ₂	Limits
83.9	232.1	76.5	
87.6	240.1	79.1	
87.1	242.5	79.9	
86.2	238.2	78.5	75 ppm @ 15% O ₂
224	620	204	
218	598	197	
217	604	199	
220	607	200	2000 ppm @ 15% O
454.9	1258.5	414.8	
469.0	1285.7	423.8	
473.3	1317.6	434.4	
465.7	1287.3	424,3	750 ppm @ 15% O
,			
		<u> </u>	
	83.9 87.6 87.1 86.2 224 218 217 220 454.9 469.0 473.3	ppm 3% O₂ 83.9 232.1 87.6 240.1 87.1 242.5 86.2 238.2 224 620 218 598 217 604 220 607 454.9 1258.5 469.0 1285.7 473.3 1317.6	ppm 3% O₂ 15% O₂ 83.9 232.1 76.5 87.6 240.1 79.1 87.1 242.5 79.9 86.2 238.2 78.5 224 620 204 218 598 197 217 604 199 220 607 200 454.9 1258.5 414.8 469.0 1285.7 423.8 473.3 1317.6 434.4

Crimson Resource Management Taft Aera IC Engine 16 Project 129-3370B October 2, 2003 Permit No. S-48-10-4

		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	145.9	362.7	119.6	
NOx	128.2	310.1	102.2	
	127.4	304.5	100.4	
Mean	133.8	325.8	107.4	75 ppm @ 15% O ₂
	549	1365	450	
co	526	1272	419	
	548	1310	432	
Mean	541	1316	434	2000 ppm @ 15% O ₂
	393.8	979.1	322.8	
voc	403.2	975.4	321.5	
C ₃ - C ₆ + as C ₁	418.2	999.5	329.4	
Mean	405.1	984.7	324.6	750 ppm @ 15% O ₂
Comments:				
		<u> </u>		
		-		
	7 % 11			
				· · · · · · · · · · · · · · · · · · ·
uras vocavio romania di di di		Spanic Street Was I was a		

Appendix C Natural Gas Heating Value and F-Factor

State Certifica Phone # (661) 16 Fax # (661)7/ E-Mail mi

Rev.8/12/03

Midway Laboratory Inc.
Fetrolaga-la damptiol-Environmental
315 Main Street P.O. Box 1151
Talt California 23268
NATURAL GAS ANALYSIS

ELAP Cert. 1396

Customer: Crimson Resources Attention: Rick Hood

7432-7 Log #: Date Received: 1/12/2004 Date Completed: 1/12/2004 Report Date: 1/13/2004

Sample Description: Mater # 17

Analytical Parameter: Natural Gas Analysis

punanyuyan mas	SALMATAN IA	arrotat Gab Utlaikais		
Constituent		Mole %	M_ 3	<u>Lv. %</u>
Oxygen		0.861	1.283	0.558 *
Nitrogen		5.279	6.889	3,769
Carbon Dioxide		9.023	18.497	15.733 *
Mothano		75.323	50.289	63 .714 *
Ethane		5.584	7.793	10.402 *
Propane		2,681	5.466	3.659
Iso-Butane		0.283	0.766	0.462
N-Butane		0.558	1.510	0.878
Iso-Pentane		0.170	0.571	0.310
N-Pentane		0.279	0.937	0,504
Hexanes Plus		0.000	0.000	0,000
Hydrogan		0.000	0.000	0,000
Hydrogen Sulfide		0.000	<u>0.000</u>	0.000
	Total	100.000	100.000	100,000

Hydrogen Sulfide, ppm Total Sulfur, as H2S ppm Not Requested

Physical Date		⊈ CX	N/mil
STU cu.ft. idea)		971.55	954.54
BTU cu.R_ real		974.08	957.13
STUM, Ideal		17173.91	16875.08
Sp. Gr. (deal		0.7412	
Sp. Qr. Peed		0.7429	
CHONS		% by 1865.	
% Curbon		61.019	
% Hydrogen		17,380	
% Oxygen		14,732	
% Hitrogen		6.659	
% Sumur		0.000	
	Total	100.000	1

Balacas ASTM D 0228-90 ASTM D 1945-96 ASTM D 1946-94 ASTN/D 3588-91 GP# 2145-00

GPM

F. factor

Sc. Vol.

1,162

0.9974

8777

17.67

* Not edded to GPM value. All Calcustions labulated @ 60/80

Michael E. Mayfield Laboratory Director Midway Laboratory

Date 2 / / Eages	From 1977	Ço.	Fhore≉	Fex #	
Post-if: Fax Note 7571	To MALE	Co.Dept.	Phone # 414-162-535	Fara	

MERLINGER OF CRINSON

30.9

Appendix D

Spreadsheet Calculation of HAE, AER and Bankable AER

Unit	VOC E.F.	Qtr 1	Qtr 2	Qtr 3	Qtr 4
	lb/MM Btu				
3	0.692	4237	5739	5723	4082
4	0.931	713	2942	834	324
7	0.653	3754	5084	5243	3677
8	0.95	6773	4973	5425	3326
9	0.429	7408	2675	4525	4525
10	0.425	6338	4587	3099	3197
HAE Tota	al	29223	25999	24849	19131
PE2		3598	3598	3598	3598
AER		25625	22401	21251	15533
AQI Ded		2563	2240	2125	1553
Bankable	AER	23063	20161	19126	13979

e en este en egispalmatella transcalidad de la disse lla egad y de projektion en en la la la maria l'agrècie e


Unit	NOx E.F.	Qtr 1	Qtr 2	Qtr 3	Qtr 4
	lb/MM Btu				
3	0.232	1420	1924	1919	1368
4	0.107	82	338	96	37
7	0.245	1409	1908	1967	1380
8	0.242	1725	1267	1382	847
9	0.245	4231	1528	2584	2584
10	0.245	3654	2644	1786	1843
HAE Tota	al	12521	9608	9734	8060
PE2		2069	2069	2069	2069
AER		10452	7539	7665	5991
AQI Ded		1045	754	767	599
Bankable	AER	9407	6785	6898	5392



 $\{ (x_1, \dots, x_n) \in \mathcal{X} \mid x \in \mathcal{X}_1, \dots, x_n \in \mathcal{X}_n \}$

Unit	CO	Qtr 1	Qtr 2	Qtr 3	Qtr 4
	lb/MM Btu				
3	0.301	1843	2496	2489	1775
4	0.275	211	869	246	96
7	0.672	3864	5232	5395	3784
8	0.637	4541	3334	3638	2230
9	0.424	7322	2644	4473	4472
10	0.996	14854	10749	7262	7492
HAE Total		32634	25325	23503	19849
PE2		14104	14104	14104	14104
AER		18530	11221	939 9	5745
AQI Ded		1853	1122	940	575
Bankable	AER	16677	10099	8459	5170

Unit	PM	Qtr 1	Qtr 2	Qtr 3	Qtr 4
	lb/MM Btu				
3	0.0483	296	401	399	285
4	0.0483	37	153	43	17
7	0.0483	278	376	388	272
8	0.0483	344	253	276	169
9	0.0483	834	301	510	509
10	0.0483	720	521	352	363
HAE Tota	ıl	2509	2005	1968	1616
PE2		570	570	570	570
AER AQI Ded		1939 194	1435 143	1398 140	1046 105
Bankable	AER	1745	1292	1258	941



Appendix E

Spreadsheet Calculation of Permitted Emissions Replacement Engines '28, '29 and '30

1	1	
,		
١.	1.3	
4 .		

Unit		Hrs/qtr	Нр	VOC	voc	NOx	NOx	co	co	PM10	PM10
S-48			•	EF	lb/qtr	EF	lb/qtr	EF	lb/qtr	EF.	lb/qtr
				ppmv	pp	mv	ppr	'nν	g/	/bhp.hr	
	28	2190	1970	25	1199	5	690	56	4701	0.02	190
	29	2190	1970	25	1199	5	690	56	4701	0.02	190
	30	2190	1970	25	1199	5	690	56	4701	0.02	190
Total					3598		2069		14104		570

2190 hr/qtr x 1970 hp x 8483 Btu/bhp.hr x 25 scf/MM scf x 8777 scf/MM Btu x lbmol/379.5 scf x 16 lb/lbmol x 20.9/(20.9-15) = 1199 lb VOC/qtr

2190 hr/qtr x 1970 hp x 8483 Btu/bhp.hr x 5 scf/MM scf x 8777 scf/MM Btu x lbmol/379.5 scf x 46 lb/lbmol x 20.9/(20.9-15) = 690 lb NOx/qtr

2190 hr/qtr x 1970 hp x 8483 Btu/bhp.hr x 56 scf/MM scf x 8777 scf/MM Btu x lbmol/379.5 scf x 28 lb/lbmol x 20.9/(20.9-15) = 4701 lb CO/qtr

2190 hr/qtr x 1970 hp x 0.02 gram/bhp.hr/454 = 190 lb PM10/qtr

ERC PROJECT ROUTING FORM

FACILITY NAME: Crimson Resource	Management					
FACILITY ID: S-48	PROJECT N	UMBEI	R: 1052	797		-11
ERC #'s:						
DATE RECEIVED: May 31, 2005						
PRELIMINARY REVIEW	ENGR	D	ATE	SUPR		DATE
A. Application Deemed Incomplete						
Second Information Letter				, ,		
B. Application Deemed Complete				y		6123105
C. Application Pending Denial	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,					
D. Application Denied	,					
	************	<u>!</u>	1	* # U		
ENGINEERING EVALUATION	ON		INIT	TAL		DATE
E. Engineering Evaluation Complete			RWK		フ-	-18-05
F. Supervising Engineer Approval						
G. Compliance Division Approval []	Not Required					
H. Applicant's Review of Draft Authority to Construct Completed [] 3-day Review [] 10-day Review [] No Review Requested				4		·
I. Permit Services Regional Manager Approval				JEY 0		2 0 2006
DIRECTOR REV	′IEW: []Not Req	uired	[メ.] Require	ed		
DIRECTOR REVIEW			TLNI	TAL		DATE
J. Preliminary Approval to Director						
K. Final Approval to Director						

NSPS/NESHAP TRIGGERED: [] Yes [] No

If "Yes" then do the following:

2. Send or email form to Compliance (Tanya Good) after management approval of project.

^{1.} Complete form (on AlRnet at <u>Per</u> » <u>General</u> » <u>Internal Forms</u> : Miscellaneous: NSPS/NESHAP Report) and attach copy to engineering evaluation.



DEC 1 1 2006

Ms. Debra Monterroso Crimson Resource Management 5001 California Avenue, Suite 206 Bakersfield, CA 93309

Re:

Invoice of Engineering Evaluation Fees

Project Number: 1052797 - Crimson Resource Management

Dear Ms. Monterroso:

The Air Pollution Control Officer has issued Emission Reduction Credits to Crimson Resource Management for emission reductions generated by the replacement of six existing IC engines driving gas compressors with three lower emitting IC engine/generator sets driving gas compressors, at the I-C gas processing plant, Hwy 119 and Midway Road, Taft. The ERC documents will be mailed separately from our Central Region office.

Please find enclosed the invoice for the engineering evaluation fees for Project S1052797. Engineering evaluation fees are charged pursuant to District Rule 3010 for projects requiring public notice. Please remit the amount owed, along with a copy of the attached invoice, within 30 days.

Thank you for your cooperation in this matter. Should you have any questions, please contact Mr. Thomas Goff at (661) 326-6900.

Sincerely,

David Warner

Director of Permit Services

Level hele

DW:RWK Enclosures

c: Thomas E. Goff, Permit Services Manager

Seyed Sadredin

Executive Director/Air Pollution Control Officer

Due Date 1/5/2007 Amount Due

\$ 3,393.50

Amount Enclosed

ERCFEE 48 S64057 12/6/2006

> CRIMSON RESOURCE MANAGEMENT ATTN: ENV. H & S ENGINEER 5001 CALIFORNIA AVE., SUITE #206 BAKERSFIELD, CA 93309

SJVAPCD 2700 M Street, Suite 275 Bakersfield, CA 93301-2370

Facility ID S48 Invoice Date 12/6/2006 Invoice Number S64057

Invoice Type

Project: S1052797

CRIMSON RESOURCE MANAGEMENT 1-C GAS PLANT TAFT, CA

PROJECT NUMBER: 1052797

APPLICATION FILING FEES
ENGINEERING TIME FEES
TOTAL FEES
LESS PREVIOUSLY PAID PROJECT FEES APPLIED TO THIS INVOICE
PROJECT FEES DUE (Enclosed is a detailed statement outlining the fees for each item.)

\$ 3,393.50 \$ 4,043.50

(\$ 650.00)

\$ 3,393.50

\$650.00

San Joaquin Valley Air Pollution Control District

Invoice Detail

Facility ID: S48

CRIMSON RESOURCE MANAGEMENT

1-C GAS PLANT

TAFT, CA

Invoice Nbr:

S64057

Invoice Date:

12/6/2006

Page:

•

Application Filing Fees

Project Nbr	Permit Number	Description		Application Fee
S1052797	S-48-1052797-0	Emission Reduction C	Credit Banking Evaluation Fee	\$ 650.00

Total Application Filing Fees: \$ 650.00

Engineering Time Fees

Project Nbr	Quantity	Rate :	Description	Fee:
S1052797	50 hours	\$ 80.87 /h	Standard Engineering Time	\$ 4,043.50
			Less Credit For Application Filing Fees	(\$ 650.00)
			Standard Engineering Time SubTotal	\$ 3,393.50

Total Engineering Time Fees: \$ 3,393.50

San Joaquin Valley Air Pollution Control District

Account Summary

Facility ID: S48

CRIMSON RESOURCE MANAGEMENT

1-C GAS PLANT

TAFT, CA

Statement Date: 12/6/2006

Invoice Invoice Date Number 10/31/2006 S63551		scription of Fees e V Hourly Fees:	3rd Quarter 2	. 75%	A Lagran	Amount Due \$ 121.31
10/31/2006 S63552	12/30/2006 Title 200	e V Hourly Fees: 6	3rd Quarter	Fees Invoiced Payments	\$ 242.61 (\$ 30.00)	
			- 4	Balance Due	(\$ 30.00)	\$ 212.61
12/06/2006 S64057	01/05/2007 Proj	ject: S1052797		Fees Invoiced	\$ 4,043.50	
			-	Payments _ Balance Due	(\$ 650.00)	\$ 3,393.50
			6 1			<u> </u>
	52			Total Outstand	ling Balance:	\$ 3,727.42

Richard Karrs

From: Sent: Yannayon.Laura@epamail.epa.gov Monday, December 04, 2006 11:03 AM

To:

Richard.Karrs@valleyair.org

Subject:

EPA comments on Project S-1052797, ERCs for Crimson Resource

Richard.

EPA has reviewed the proposed ERC package and has only one comment regarding the methodology used to calculate the actual VOC emissions. For permit units '3, '4, '7 and '8, the VOC emission factors used are too high. For these engines source test data is available, which must be used rather than the VOC emission limit of Rules 4701 and 4702. The source test results for each engine are for two separate stacks. For each engine, one of the two stacks had measured VOC emissions greater than the 750 ppmv @ 15% O2 limit of both District rules. In these cases, the rule limit of 750 ppmv should be averaged with the other stack reading for each engine. I calculated the following emission factors, based on source test data, correcting for the 750 ppmv emission limit of the two prohibitory rules: Engine unit '3 - 528 ppmv, unit '4 - 710 ppmv, unit '7 - 498 ppmv, and unit '8 - 725 ppmv. Please revise the baseline historic actual emissions for VOC using these VOC emission factors, and recalculate the revised amount of VOC ERC's to be issued.

If you have any questions, please feel free to call me.

Laura Yannayon

US EPA, Region 9 Air Division, Permits Office (Air-3) San Francisco, CA 94105-3901

(415) 972-3534 (415) 947-3579 (fax) yannayon.laura@epa.gov



San Joaquin Valley Air Pollution Control District

August 2, 2005

Patty Lee Kusek Crimson Resource Management 5001 California Avenue, Suite 206 Bakersfield, CA 93309

Re: Emission Reduction Credit (ERC) Project -1052797

Dear Ms. Kusek:

Processing on the above-referenced project to grant ERCs for the shutdown and replacement of six IC engines at the 1C gas processing plant has halted. This is due to the failure of the replacement engines, units '28-0, '29-0 and '30-0, to demonstrate compliance with one or more of their permitted emissions limits. We understand that the replacement engines are operating under variance and that you have applied to modify the engines to add catalyst to affect compliance.

The District will resume processing of your application for ERCs once the engines have demonstrated compliance with all emissions limits and conditions of operation as set forth in the Authorities to Construct.

Thank you for your cooperation in this matter. If you have any questions, please contact Richard Karrs at (661) 326-6954.

Sincerely,

David Warner

Director of Permit Services

Thomas Goff, P.E.

Permit Services Manager

rwk

Summary of Phone Conversation

With:

Patty Lee Kusek

Telephone:

(661) 716-5001 ext-11

Date:

8/2/05

Company:

Crimson Resource Management

District Rep:

Richard Karrs

Project:

1052797(S-48)

RWK

I asked PLK about engines 28, 29 and 30, which are under variance to add catalyst and to meet their BACT limit. We want to delay issuing the ERC until the engines have been modified and demonstrated compliance through source testing with their limits.

PLK

I have reviewed the draft ATCs to add catalyst. It is no problem to delay issuing the

ERCs.

RWK

I asked if she had a preference for how we issued the ERCs, in light of the requirements to provide 50% of the NOx credits back to the District. I asked about the disposition of the shutdown engines. I asked about the history of the replacement action.

PLK

No, we don't have a preference. Most of the engines have been disposed of as scrap. I think one or two remain onsite. Sometime in 2004 the three replacement engines were installed at one time. We were unsure of our plans. We requested emergency service for all of the shutdown engines, though we only were contemplating converting one or two to emergency. I am not sure if any of the replaced engines ever served as emergency backups. I am also not sure if emergency backup service from PGE.

Summary of Phone Conversation

With:

Patty Lee Kusek

Telephone:

(661) 716-5001 ext-11

Date:

7/14/05

Company:

Crimson Resource Management

District Rep:

Richard Karrs

Project:

1052797(S-48

RWK

Why hasn't the PTO for engine '3 been cancelled yet?

PLK

I have just recently canceled as part of annual renewal biling.

RWK

I asked how the remaining full time use engines, units '11 (K2) and '24 (K3) were picking

up any of the load that the surrendered engines used to carry.

PLK

No. They are not picking up any of the load. These two engines are part of a separate system and are used to compress propane. Propane is used as a refrigerant in a

separate cooling loop used in the plant.

RWK

I asked about some discrepancies in the raw fuel use data for engine '9.

PLY

Patty checked some of the raw records for that unit for some of the intervening dates in the first quarter. The most likely scenario is that the gas meter was replaced around 1/16/03. The new meter was zeroed, run for a short period and reset to zero again.

RWK

This make sense and seems to agree with the fuel use calculated by your consultant.



San Joaquin Valley Air Pollution Control District

June 23, 2005

Ms. Patty Lee Kusek Crimson Resource Management 5001 California Avenue, Suite 206 Bakersfield, CA 93309

Re: Notice of Receipt of Complete Application - Emission Reduction Credits

Project Number: 1052797

Dear Ms. Kusek:

The District has completed a preliminary review of your application for Emission Reduction Credits (ERCs) resulting from the shutdown and surrender of permits for seven natural gas-fired IC engines located at the 1C Gas Plant.

Based on this preliminary review, the application appears to be complete. However, during processing of your application, the District may request additional information to clarify, correct, or otherwise supplement, the information on file.

Pursuant to District Rule 3010, section 3.0, your application may be subject to an hourly Engineering Evaluation Fee. If the applicable fees exceed the submitted application filing fee, the District will notify you at the conclusion of our review.

Thank you for your cooperation. Should you have any questions, please contact Mr. Thomas Goff at (661) 326-6900.

Sincerely,

David Warner Director of Permit Services

Keinard landing

Anthomas Goff, P.E. Permit Services Manager

DW:rwk

David L. Crow Executive Director/Air Pollution Control Officer

San Joaquin Valley Air Pollution Control District May 3 / 2015 Application for Southern Roy 1 2015

[X] EMISSION REDUCTION CREDIT (ERC)

1.	ERC TO BE ISSUED TO: Crimson Resource	Management				Facility ID: S - 48 (if known)
2.	MAILING ADDRESS: Street/P.O. Box: 5001 Ca	difornia Avenue, Suite 20)6	_		
	City: <u>Bakersfi</u>	eld		·	State:CA_ Zip Cod	e; <u>93309</u>
3.	LOCATION OF REDUCTION:				4. DATE OF REDU	CTION:
	Street:1630 North Lincoln					
	City:Taft					
	/4 SECTION1 TOWNSHI	P32 S	RANGE 23 E		. <u></u>	
5.	PERMIT NO(S):	EXISTING E	ERC NO(S):			
6.	METHOD RESULTING IN EMISSION RED	JCTION:				<u>, , , , , , , , , , , , , , , , , , , </u>
	[X] SHUTDOWN [] RETRO	OFIT [] PROCESS CHANG	GE	[]OTHER	
	DESCRIPTION:					
Shut	tdown compressor engines, installed gensets to drive electric t	notors				(Use additional sheets if necessary
7.	REQUESTED ERCs (In Pounds Per Calenda	r Quarter):				
	VOC	NOx	со	PMIC	SOx	OTHER
	1ST QUARTER 26697	9443	22268	1752		
	2ND QUARTER 24990	6803	15608	1293		
	3RD QUARTER 23891	6895	13892	1254		
	4TH QUARTER 14490	3760	10604	616		
8.	SIGNATURE OF APPLICANT:		TYPE OR PI	RINT TITL	E OF APPLICANT: 1	ES&H Engineer
9.	TYPE OR PRINT NAME OF APPLICANT: P	atty Lee Kusek			DATE: 5/31/05	TELEPHONE NO: (661)716-5001 ext 11
FOR	APCD USE ONLY:					
	DATE STAMP	FILING FEE RECEIVED: \$_	650.			<u></u> -
			6/15/05			
		PROJECT NO.:	105279	T_FAC	ILITY ID.: <u></u>	48
	1.441 50/	1 1.1.1.	5-14	a		/

MAY 3 1 2005
SJVAPCD
Southern Region

Application to the San Joaquin Valley Air Pollution Control District for Emission Reduction Credits

Prepared for:

CRIMSON RESOURCE MANAGEMENT

5001 California Avenue, Suite 206 Bakersfield, CA 93306

Prepared by:



IMPACT SCIENCES

3256 Penryn Road, Suite 220 Loomis, CA 95630 Phone: (916) 652-6300

Fax: (916) 652-5335

Application to the San Joaquin Valley Air Pollution Control District for Emission Reduction Credits

Prepared for:

Crimson Resource Management 5001 California Avenue, Suite 206 Bakersfield, California 93306

Prepared by:

Impact Sciences, Inc. 3256 Penryn Road, Suite 220 Loomis, California 95630 Phone: (916) 652-6300

Fax: (916) 652-5335

Summary

Crimson Resource Management (Crimson) is requesting Emission Reduction Credits (ERCs) for the shutdown of seven internal combustion (IC) engines at its 1C gas processing facility in Taft. The facility is located at Section 1, Township 32 South, Range 23 East, in Kern County.

Crimson is installing three engine-generator sets each powered by a 1,970 brake horsepower (bhp) gas-fired Waukesha internal combustion engine to replace seven existing engines at its 1C Gas Plant. The existing engines, which provided power to gas compressors, are being shutdown. The compressors will be powered by electric motors, with the electrical power provided by the new engine-generator sets.

San Joaquin Valley Air Pollution Control District (SJVAPCD or District) Rule 2301, Emission Reduction Credit Banking, will be applicable for these changes as the compressor engines will result in emission reductions of oxides of nitrogen (NO_x) , volatile organic compounds (VOC), suspended particulate matter (PM_{10}) , and carbon monoxide (CO). As documented in this application, all the emission reductions meet the criteria of being real, quantifiable, surplus, permanent, and enforceable.

TABLE OF CONTENTS

Section	<u> </u>		Page
	Sum	nmary	i
1.0	Proje	ect Description	1
	1.1	Applicant's Name and Business Description	1
	1.2	Type of Application	1
	1.3	Description of Facility	2
		1.3.1 Site Location	
		1.3.2 General Purpose	2
		1.3.3 Current Equipments	2
	1.4.	Proposed Modifications	2
2.0	Emi	ssions	
	2.1	Current Actual Emissions	
	2.2	Emission Reduction Calculations	8
	2.3	Actual Emission Reduction	10
	2.4	Air Quality Improvement Deduction	11
3.0	Con	npliance with Applicable Rules and Regulations	12
٠	3.1	General	12
	3.2	Permitting and Prohibitory Rules	12

LIST OF APPENDICES

- A Emission Calculations
- B Fuel Gas Analysis
- C Settlement Agreement
 D Fuel Usage Data
 E Source Test Results

LIST OF TABLES

Table	Title	Page
1	Shutdown Dates of Existing Compressor Engines	
2	Specifications of Existing Compressor Engines	
3	Current Emission Limits for Natural Gas-Fired Two-Stroke Engines	<u>۔</u> ع
4	Quarterly Emissions of Engine No. 1 (S-48-3) in 2003	3
5	Quarterly Emissions of Engine No. 1 (S-48-3) in 2004	4
6	Quarterly Emissions of Engine No. 2 (S-48-4) in 2003	4
7	Quarterly Emissions of Engine No. 2 (S-48-4) in 2004	
8	Quarterly Emissions of Engine No. 3 (S-48-5) in 2003	
9	Quarterly Emissions of Engine No. 3 (S-48-5) in 2004	
10	Quarterly Emissions of Engine No. 5 (S-48-7) in 2003	
11	Quarterly Emissions of Engine No. 5 (S-48-7) in 2004	
12	Quarterly Emissions of Engine No. 6 (S-48-8) in 2003	
13	Quarterly Emissions of Engine No. 6 (S-48-8) in 2004	
14	Quarterly Emissions of Engine No. 12 (S-48-9) in 2003	
15	Quarterly Emissions of Engine No. 12 (S-48-9) in 2004	
16	Quarterly Emissions of Engine No. 16 (S-48-10) in 2003	
17	Quarterly Emissions of Engine No. 16 (S-48-10) in 2004	
18	Quarterly Emissions of All Engines Average 2003-2004	
19	Post-Project Potential to Emit	
20	Quarterly Actual Emission Reduction	
21	Quarterly Emission Reductions After AQI Deduction	11

1.0 PROJECT DESCRIPTION

1.1 Applicant's Name and Business Description

Name:

Crimson Resource Management

Facility Location:

Section 1, Township 32 South, Range 23 East, Kern County

Mailing Address:

5001 California Avenue, Suite #206, Bakersfield, CA 93306

General Business:

Gas processing

Facility Contact:

Patty Lee Kusek

Phone: (661) 716-5001 X11

Consultants:

Impact Sciences, Inc.

3256 Penryn Road, Suite 220

Loomis, CA 95650

Contact: David Deckman Phone: (916) 652-6300

Estimated Date of Activity:

Table 1, Shutdown Dates of Existing Compressor Engines, shows the

dates on which the permits to operate were or are expected to be

surrendered.1

Table 1
Shutdown Dates of Existing Compressor Engines

PTO Number ¹	Date of Shutdown
S-48-3	December 2, 2004
S-48-4	January 10, 2005
S-48-5	Expected June 2005
S-48-7	May 3, 2005
S-48-8	May 3, 2005
S-48-9	December 2, 2004
S-48-10	December 2, 2004

Source: Crimson Resource Management
¹ Permit To Operate (PTO) Number

1.2 Type of Application

This application is for banking emission reduction credits generated by the shutdown of gas-fired compressor engines.

Per SJVAPCD Rule 2301, Section 3.11, the date of shutdown of a permitted source is the earlier of date of the permanent cessation of emissions from an emitting unit or the date on which the permit to operate is surrendered.

Description of Facility 1.3

- 1.3.1 Site Location: The facility is located at Section 1, Township 32 South, Range 23 East, in western Kern County.
- 1.3.2 General Purpose: Gas processing.
- 1.3.3 Current Equipments: Table 2, Specifications of Existing Compressor Engines, provides the detailed information about engines.

Table 2 **Specifications of Existing Compressor Engines**

Engine ID No.	1	2	3	5	6	12	16
PTO Number	S-48-3	S-48-4	S-48-5	S-48-7	S-48-8	S-48-9	S-48-10
Manufacturer	Clark						
Model	RA 6	RA 6	RA 6	HRA 6M	HRA 6M	RA 8	HRA 6M
BHP ¹	600	600	600	660	660	800	660
Fuel/Ignition	Natural gas/ spark						
Combustion	Lean						
Type	burn						

Source: Crimson Resource Management

1 Brake Horse Power (RHP)

Brake Horse Power (BHP).

Proposed Modifications 1.4

Crimson Resource Management is installing three engine-generator sets each powered by a 1,970 bhp gas-fired Waukesha IC engine. The engine-generator sets will provide power to electric-powered gas compressors, which will replace seven existing engine-driven gas compressors at its 1C Gas Plant. After installing the generator sets, use of these compressor engines will be discontinued.

2.0 EMISSIONS

2.1 Historic Actual Emissions

The District requires that the historic actual emissions (HAE) be calculated on a quarterly basis. The HAE are the emissions that occurred during the baseline period and which are considered surplus. Accordingly, the HAE are based on the lesser of emission limits in existing or proposed rules or the actual emissions, based on source test results, fuel consumption, or similar process data. Fuel consumption records and source test results are found in Appendices D and E, respectively. The basis for the HAE is discussed further in Section 3.2 of this application. The applicable emission limits are found in District Rule 4702. The existing limits are shown in Table 3, Current Emission Limits for Natural Gas-Fired Two-Stroke Engines. Quarterly Emissions for the compressor engines for the two years prior to the date of application are listed in Table 4 to Table 17. Sulfur oxides emissions have not been calculated as the combustion fuel has less than 1 part per million (ppm) of sulfur, and the resultant HAE would be minimal. Refer to Section 2.2 and Appendix A for additional information regarding the HAE calculations.

Table 3
Current Emission Limits for Natural Gas-Fired Two-Stroke Engines

Pollutant	ppmv (at 15% Oxygen)
NO _x	65
NO _x CO	2000
VOC	<i>7</i> 50

Source: SIVAPCD Rule 4702

Table 4
Quarterly Emissions of Engine No. 1 (S-48-3) in 2003

Pollutant	Emissions (pounds per quarter)					
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter		
NO _x	316.52	1,128.82	1,148.47	2,666.51		
co	410.39	1,463.60	1,489.07	3,457.32		
VOC	1,342.62	4,788.22	4,871.54	11,310.74		
PM_{10}	65.96	235.24	239.33	555.68		

Table 5 Quarterly Emissions of Engine No. 1 (S-48-3) in 2004

Pollutant	Emissions (pounds per quarter)					
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter		
NO_x	2,521.79	2,715.50	2,685.25	67.96		
CO	3,269.68	3,520.84	3,481.61	88.11		
VOC	10,696.89	11,518.55	11,390.23	288.25		
PM_{10}	525.53	565.89	559.59	14.16		

Table 6 Quarterly Emissions of Engine No. 2 (S-48-4) in 2003

Pollutant	Emissions (pounds per quarter)					
	1 st Quarter	2 nd Quarter	3 rd Quarter	4th Quarter		
NO_x	1.05	49.80	192.51	74.70		
CO	2.68	127.63	493.38	191.45		
VOC	9.58	455.84	1,762.07	683.76		
PM_{10}	0.47	22.39	86.57	33.59		

Source: Impact Sciences, Inc.

Table 7
Quarterly Emissions for Engine No. 2 (S-48-4) in 2004

Pollutant	Emissions (pounds per quarter)					
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter		
NO_x	163.42	628.99	0	0		
CO	418.84	1,612.06	0	0		
VOC	1,495.84	5,757.36	0	0		
PM_{10}	73.49	282.85	0	0		

Table 8
Quarterly Emissions of Engine No. 3 (S-48-5) in 2003

Pollutant	Emissions (pounds per quarter)					
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter		
NO _x	Required	Required	Required	Required		
CO	Required	Required	Required	Required		
VOC	Required	Required	Required	Required		
PM ₁₀	Required	Required	Required	Required		

Table 9
Quarterly Emissions of Engine No. 3 (S-48-5) in 2004

Pollutant		Emissions (pour	nds per quarter)	
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
NO _x	Required	Required	Required	Required
CO	Required	Required	Required	Required
VOC	Required	Required	Required	Required
PM_{10}	Required	Required	Required	Required

Source: Impact Sciences, Inc.

Table 10 Quarterly Emissions of Engine No. 5 (S-48-7) in 2003

Pollutant		Emissions (pour	ids per quarter)	
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
NO _x	2,483.72	3,153.75	2,428.37	2,416.91
CO	6,814.87	8,653.30	6,662.98	6,631.56
VOC	9,968.12	12,657.19	9,745.95	9,699.98
PM_{10}	489.72	621.83	478.81	476.55

Table 11 Quarterly Emissions of Engine No. 5 (S-48-7) in 2004

Pollutant		Emissions (pou	nds per quarter)			
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter		
NO_x	333.34	661.20	1,505.41	342.17		
CO	914.63	1,814.20	4,130.56	938.85		
VOC	1,337.83	2,653.63	6,041.78	1,373.26		
PM_{10}	65.73	130.37	296.83	67.47		

Table 12 Quarterly Emissions of Engine No. 6 (S-48-8) in 2003

Pollutant		Emissions (pou	nds per quarter)	
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
NO_x	546.71	57.22	1,154.39	1,452.52
CO	1,486.94	150.68	3,039.61	3,824.62
VOC	2,296.43	232.71	4,694.37	5,906.75
PM_{10}	112.82	11.43	230.63	290.19

Table 13 Quarterly Emissions of Engine No. 6 (S-48-8) in 2004

Pollutant		Emissions (pou	nds per quarter)	
	1st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
NO_x	2,882.67	2,473.85	1,607.00	240.67
CO	7,590.34	6,513.8 9	4,231.39	633.72
VOC	11,722.53	10,060.06	6,534.97	978.71
PM_{10}	575.92	494.24	321.06	48.08

Table 14 Quarterly Emissions of Engine No. 12 (5-48-9) in 2003

Pollutant		Emissions (pou	nds per quarter)	
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
NO _\	3,858.14	3,055.44	5,168.60	5,167.88
CO	5,148.48	4,077.33	6,897.23	6,896.27
VOC	6,752.13	5,347.33	9,045.57	9,044.31
PM_{10}	760.72	602.45	1019.11	1018.97

Table 15 Quarterly Emissions of Engine No. 12 (S-48-9) in 2004

Pollutant		Emissions (pou	nds per quarter)	
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
NO_x	4,602.85	0	0	0
CO	6,142.26	0	0	0
VOC	8,055.45	0	0	0
PM_{10}	907.56	0	0	0

Source: Impact Sciences, Inc.

Table 16 Quarterly Emissions of Engine No. 16 (S-48-10) in 2003

Pollutant		Emissions (pou	nds per quarter)	
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
NO_{x}	3,628.35	3,454.40	3,572.52	66.57
CO	14,746.40	14,039.43	14,519.47	14,977.20
VOC	6,302.41	6,000.26	6,205.42	115.64
PM_{10}	715.41	681.11	704.40	13.13

Table 17 Quarterly Emissions of Engine No. 16 (S-48-10) in 2004

Pollutant		Emissions (pou	nds per quarter)	
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
NO _x	3,678.70	1,833.50	0	0
CO	14,951.02	7,451.75	0	0
VOC	6,389.86	3,184.78	0	0
PM_{10}	725.34	361.52	0	0

Table 18, Quarterly Emissions of All Engines, Average 2003–2004, shows the quarterly emissions averaged over the two-year period prior to this application for ERCs.

Table 18 Quarterly Emissions of All Engines Average 2003–2004

Pollutant		Emissions (pounds per quarter)			
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter	
NO _v	12,518	9,606	9,731	6,248	
co	32,633	25,320	23,501	19,848	
VOC	33,186	31,328	30,146	19,701	
PM_{10}	2,509	2,005	1,968	1,259	

2.2 Emission Reduction Calculations

The HAE is the decrease of actual emissions, during the Baseline Period from an emissions unit. For the proposed shutdowns, the emission reductions meet all the criteria specified by District Rule 2201 to qualify for the HAE, specifically:

- These emissions are real, enforceable, quantifiable, and permanent.
- These emissions are surplus as:
 - o These are available in excess of any emissions that are required or encumbered by any laws, rules, regulations, agreements, or orders.
 - o No additional emission reductions are attributed to a control measure noticed for workshop, are proposed or contained in a State Implementation Plan, or are proposed in the Air Pollution Control Officer's adopted air quality plan pursuant to the California Clean Air Act.

The emission reduction calculations are based on the equations in USEPA Method 19 – Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxide Emission Rates.² Sample calculations for the NO_x emissions for PTO S-48-3 are shown below. The HAE for each engine for every quarter during the baseline period is shown in the Appendix A.

Sample Calculations

Engine PTO: S-48-3

When measurements are on a dry basis for both oxygen ($\%O_{2d}$) and pollutant (C_d) concentrations, the following equation is used:²

$$E = C_a \times F_d \times \frac{20.9}{(20.9 - \%O_{2d})}$$

where:

E is emission factor in lbs/106 Btu

 C_d is pollutant concentration in lbs/dscf³

 F_d is volume of combustion components per unit of heat content (F-factor) based on 0 percent oxygen (dry basis) in dscf/10⁶ Btu

 $%O_{2d}$ is the concentration of oxygen on a dry percent basis.

 $F_d = 8777 \, dscf / 10^6 \, Btu \, at 60^{\circ} F$

The F-Factor used in these calculations was taken from a fuel gas analysis dated January 13, 2004. A copy of the gas analysis is found in **Appendix B**.

 C_d = Concentration in ppm × Molecular Weight of NO_x in lbs/lb-mole × Molar Volume in dscf/lb-mole

Hence, concentration of NO, is calculated as:

$$C_{d} = \frac{61.5}{10^{6}} \frac{parts}{parts} \times \frac{46}{1} \frac{lbs}{lb-mole} \times \frac{1}{379.5} \frac{lb-mole}{dscf}$$
$$= 7.455 \times 10^{-6} \frac{lbs}{dscf}$$

Hence, emission factor is calculated as:

E =
$$7.455 \times 10^{-6} \frac{lbs}{dscf} \times \frac{8777}{10^{6}} \frac{dscf}{Btu} \times \frac{20.9 - 0}{20.9 - 15}$$

= $\frac{0.232}{10^{6}} \frac{lbs}{Btu}$

Source: United States Environmental Protection Agency Technology Transfer Network Emission Measurement Center. http://www.epa.gov/ttn/cmc/methods/method19.html.

³ Dry standard cubic feet (dscf).

Therefore,

HAE for NO, is calculated as:

HAE = E in lbs/10⁶ Btu × Heat Content in Btu/dscf × Fuel Usage in 1,000 dscf/Quarter

$$= \frac{0.232}{10^6} \frac{lbs}{Btu} \times 974.08 \frac{Btu}{dscf} \times 1402 \times 10^3 \frac{dscf}{quarter}$$
$$= 316.8 \frac{lbs}{quarter}$$

2.3 Actual Emission Reduction

Per Section 4.12 of Rule 2201, the Actual Emission Reduction (AER) is the HAE less the Post-Project Potential to Emit (PE2). Table 19, Post-Project Potential to Emit, shows the new Engine-Generator emissions that represent PE2. Table 20, Quarterly Actual Emission Reduction, shows the emissions after subtracting the PE2 from the HAE.

Table 19 Post-Project Potential to Emit

Pollutant		Emissions (pou	nds per quarter)	
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
NO _x	2,025	2,048	2,070	2,070
CO	<i>7,</i> 891	7,978	8,066	8,066
VOC	3,523	3,562	3,601	3,601
PM_{10}	562	568	575	575

Source: SJVAPCD Application Review, Project # S-1030826. Annual emissions have been distributed by quarter based on the number of days per quarter.

Table 20 Quarterly Actual Emission Reduction

Pollutant		Emissions (pou	nds per quarter)	
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
NO_x	10,492	7,558	7,661	4,178
CO	24,742	17,342	15,435	11,782
VOC	29,663	27,766	26,545	16,100
PM_{10}	1,947	1,436	1,393	684

2.4 Air Quality Improvement Deduction

Per Section 4.12.1 of Rule 2201, a 10 percent Air Quality Improvement (AQI) Deduction factor applies to the AER before the AER becomes eligible for banking. Hence, 90 percent of AER is available to the applicant for banking. The adjusted AER is shown in **Table 21**, **Quarterly Emission Reductions after AQI Deduction**.

Table 21
Quarterly Emission Reductions after AQI Deduction

Pollutant	Emissions (pounds per quarter)								
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter					
NO _x	9,443	6,803	6,895	3,760					
CO	22,268	15,608	13,892	10,604					
VOC	26,697	24,990	23,891	14,490					
PM_{10}	1,752	1,293	1,254	616					

3.0 COMPLIANCE WITH APPLICABLE RULES AND REGULATIONS

3.1 General

The District is responsible for ensuring that Kern County's air quality meets state and federal health standards. The facility is subjected to the District's Rules and Regulations. The following rules may apply to the proposed action.

Regulation 2 - Permits

Rule 2201: New and Modified Source Review Rule 2301: Emission Reduction Credit Banking

Regulation 3 - Fees

Rule 3060: Emission Reduction Credit Banking Fees

Regulation 4 – Prohibitions

Rule 4701: Internal Combustion Engines Phase I Rule 4702: Internal Combustion Engines Phase II

3.2 Permitting and Prohibitory Rules

Rule 2201

- General: Rule 2201 provides an orderly procedure for the review of new sources and of the
 modification and operation of existing sources through the issuance of permits. It also
 establishes the methods by which emission reductions for which emission reduction banking is
 requested per Rule 2301 are to be calculated.
- Significance with the Proposed Project: This permit application, seeking the emission reduction credits for the shutdown of seven gas-fired engines, is intended to conform to the rule. The HAE from the shutdown of the engines has been calculated in accordance with Rule 2201.

Rule 2301

General: Rule 2301 provides an administrative mechanism for sources to store and transfer
emission reduction credits to other sources for use as offsets where allowed by the District Rules
and Regulations. It also defines eligibility standards, quantitative procedures, and administrative
practices to ensure that emission reduction credits are real, permanent, surplus, quantifiable, and
enforceable. A brief description of these terms is as follows.

Surplus: The emission reductions that are not required by State Implementation Plan (SIP), not already relied on for SIP planning purposes, and not used by the source to meet any other regulatory requirement can be considered surplus.

Quantifiable: The emissions calculated on the reliable basis for calculating the amount and the rate of reduction and describing its characteristics.

Permanent: The emissions that are assured for the life of the corresponding change, whether unlimited or limited in duration.

Enforceable: The emission reductions must be approved by the District and must be federally enforceable at the time an ERC is used.

Actual: The emissions having occurred from a source, based on source test or monitoring data, actual fuel consumption, and process data.

Significance with the Proposed Project:

The ERCs requested in this application will meet the criteria in Rule 2301 as follows:

Surplus: The HAE for each engine has been based on the lesser of the measured emissions or the limits in Rule 4702. Thus, only those emissions that have not been counted as part of the District's attainment strategy have been included in this application.

Quantifiable: The HAE has been quantified using standard engineering calculations using the equations in USEPA Method 19 (to convert measure exhaust concentrations to lbs/MMBtu) and the measured fuel gas consumption.

Permanent: The PTOs for these engines have or will be surrendered to the District. Furthermore, Crimson has signed a settlement agreement, which requires the engines be permanently disabled within 15 days of the start-up of all of the engine-generator sets. Per the agreement, "permanently disable" means to render the engines forever inoperable so that they may never be re-sold or re-used. A copy of the settlement agreement is included in **Appendix C**.

Enforceable: Rule 2010 requires that any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants, shall first obtain a written permit from the APCO. The PTOs have been or will be surrendered, and Crimson would not be allowed to operate the compressor engines. Furthermore, Crimson has signed a settlement agreement that will enforce the permanent disabling of the compressor engines.

Actual: The HAE for each engine has been calculated using actual source test data (or the limits in Rule 4702), monitoring fuel consumption data, and the measured heat content of the fuel gas. Accordingly, these emissions represent the actual emissions that occurred during the baseline period.

Rule 3060

- General: Rule 3060 establishes fees to be charged for emission reduction credit applications requiring public notice, as well as, for applications not requiring public notice pursuant to Rule 2201.
- Significance with the Proposed Project: The proposed change requires public notice pursuant to Rule 2201. Hence, a nonrefundable fee of \$650 has to be paid by the applicant.

Rule 4701

- General: Rule 4701 limits the emissions of oxides of nitrogen (NO_x), carbon monoxide (CO), and volatile organic compounds (VOC) from any internal combustion engine rated more than 50 bhp that requires a PTO.
- Significance with the Proposed Project: The proposed project consists of spark ignited gas-fired two-stroke engines with rate at more than 50 bhp. Rule 4701 is applicable currently, but Rule 4702 will be partially applicable from June 1, 2005 and fully applicable from June 1, 2007. Since

Rule 4702 contains NO_x emission limits that are more stringent, it establishes the maximum allowable levels of calculating surplus NO_x emissions.

Rule 4702

- General: Rule 4702 limits the emissions of oxides of nitrogen (NO_v), carbon monoxide (CO), and volatile organic compounds (VOC) from spark ignited internal combustion engines.
- Significance with the Proposed Project: The proposed project consists of spark ignited gas-fired two-stroke engines rated at more than 100 bhp. Hence, the Rule 4702 applies to these engines, and the rule contains NO_x, CO, and VOC emission limits of 65 ppm, 2000 ppm, and 750 ppm, respectively, for the purpose of establishing surplus emissions.

APPENDIX A

Emission Calculations

Crimson Resource Management Historic Actual Emission Calculations Assumptions

	Data Source	Value	Units
Standard Temperature	1	60 °	F
Molar Volume	2	379.5 s	scf/lb-mole
Heat Content of Gas	3	974.08	Stu/scf
F-Factor	3	8,777 d	dscf/MMBtu
Molecular Weight NOx CO VOC		28 1	b/lb-mole b/lb-mole b/lb-mole
PM10 Emission Factor	4	4.83E-02 l	b/MMBtu (filterable + condensible)

Data Sources:

- 1. SJVAPCD Rule 1020
- 2. Ideal Gas Law
- 3. Midway Laboratory Inc., Natural Gas Analysis, January 2004
- 4. USEPA, AP-42, Section 3.2

			Actual Concentration	Rule 4702 limit	Concentration used for calculations	Emission factor				
Pollutant	Year	Quarter	in ppm	in ppm	in ppm	in ibs/MMBtu	kı	icf		lbs/quarter
							start of quarter	Reading at the end of quarter	Usage in kscf/quarter	
NOx	2003	1					21376	22778	1402	316.52
		2			61.5	0.232	22778	27778	5000	1,128.82
		3	51.5				27778	32865	5087	1,148.47
	2004	4		65			32865	44676	11811	2,666.51
	2004	2					44676	55846	11170	2,521.79
		3			61.5	0.232	55846	67874	12028	2,715.50
		4					67874 79768	79768 80069	11894	2,685.25
	Average	1					19100	600069	301	67.96 1,419.16
		2								1,922.16
		3								1,916.86
		4								1,367.23
co	2003	1					21376	22778	1402	410.39
		. 2			131.0	0.301	22778	27778	5000	1,463.60
		3	131.0				27778	32865	5087	1,489.07
		4		2000			32865	44676	11811	3,457.32
	2004	1					44676	55846	11170	3,269.68
	,	2			131.0	0.301	55846	67874	12028	3,520.84
		3					67874	79768	11894	3,481.61
	Average	1					79768	80069	301	88.11
	Average	2								1,840.04 2,492.22
		3								2,485.34
		4								1,772.71
voc	2003	1					21376	22778	1402	1,342.62
		2			750.0	0.983	22778	27778	5000	4,788.22
		3	997 1				27778	32865	5087	4,871.54
	2004	4		750			32865	44676	11811	11,310.74
	2004	1 2					44676	55846	11170	10,696.89
		3			750.0	0.983	55846	67874	12028	11,518.55
		4					67874 79768	79768 80069	11894 301	11,390.23
	Average	1					19100	00009	301	288.25 6,019.75
		2								8,153.39
		3								8,130.88
		4								5,799.50
PM10	2003	1					21376		1402	65.96
		2					22778	27778	5000	235.24
		3					27778	32865	5087	239.33
		4					32865	44676	11811	555.68
	2004	1					44676	55846	11170	525.53
		2					55846	67874	12028	565.89
		3					67874	79768	11894	559.59
	Average	4					79768	80069	301	14.16
	Average	2								295.74 400.57
		3								399.46
		4								284.92

Pollutant				Rule 4702 limit	Concentration used for calculations	Emission factor				
POROLARIC	Year	Quarter	in ppm	in ppm	in ppm	in lbs/MMBtu	K	icf		lbs/quarter
							start of quarter		Usage in kscf/quarter	
NOx	2003	1 2	27.0 30.0				7446	7456	10	1.05
		3			28.5	0.107	7456 7932	7932 9772	476	49.80
		4	28.5				9772	10486	1840 714	192.51 74.70
	2004	1		65			10486	12048	1562	74.70 163.42
		2					12048	18060	6012	628.99
		3			28.5	0.107			0	0.00
		4							0	0.00
,	Average	1								82.23
		2								339.40
		3								96.25
		4								37.35
co	2003	1	115.0				7446	7456	10	2.68
		2	125.0				7456	7932	476	127.63
		3			120.0	0.275	7932	9772	1840	493.38
		4	120.0	2000			9772	10486	714	191.45
	2004	1		2000			10486	12048	1562	418.84
		2			120.0	0.275	12048	18060	6012	1,612.06
		3				0.2.0			0	0.00
	A	4 1							0	0.00
	Average	2								210.76
		3								869.85
		4								246.69 95.73
										30.70
voc	2003	1	669.3				7446	7456	10	9.58
		2	1509.1		750.0	0.983	7456	7932	476	455.84
		3 4	1089.2				7932	9772	1840	1,762.07
	2004	1		750			9772	10486	714	683.76
	2004	2					10486 12048	12048 18060	1562 6012	1,495.84
		3			750.0	0.983	12040	10000	0	5,757.36 0.00
		4							ō	0.00
	Average	1							v	752.71
		2								3,106.60
		3								881,03
		4								341.88
PM10	2003	1					7446	7450	4.5	
-14110	2003	2					7446 7456	7456 7932	10 476	0.47
		3					7932	9772	1840	22.39
		4					9772	10486	714	86,57 33,59
	2004	1					10486	12048	1562	73.49
		2					12048	18060	6012	282.85
		3							0	0.00
		4							0	0.00
	Average	1								36,98
		2								152.62
		3 4								43.28
		4								16.80

Pollutant	Year	Quarter	Actual Concentration in ppm	Rule 4702 limit in ppm	Concentration used for calculations in ppm	Emission factor				lbs/quarter
NOx	2003	1	52.0				start of quarter	Reading at the end of quarter	Usage in kscf/quarter	
1402	2000	2	71.0				21376	22764	1388 0	0.31 0.00
		3			61.5	0.232			0	0.00
		4	61.5	65					0	0.00
	2004	1		05					0	0.00
		2			61.5	0.232			0	0.00
		3 4							0	0.00
	Average	1							0	0.00 0.16
		2								0.00
		3								0.00
		4								0.00
СО	2003	1 2	115.0 147.0				27225	34277	7052	2.06
		3			131.0	0.301			0	0.00 0.00
		4	131.0						0	0.00
	2004	1		2000					. 0	0.00
		2			131.0	0.301			0	0.00
•		3			131.0	0.301			0	0.00
		4							0	0.00
	Average	1 2					•			1.03
		3								0.00 0.00
		4								0.00
voc	2003	1	306.4				21376	22764	1388	1.33
		2	1687.8		750.0	0.983			0	0.00
		. 4	997.1						0	0.00
	2004	1		750					0	0.00 0.00
		2							0	0.00
		3			750.0	0.983			0	0.00
		4							0	0.00
	Average	1								0.66
		2								0.00
		4								0.00 0.00
PM10	2003	1					21376	22764	1388	0.07
		2							0	0.00
		3 4							0	0.00
	2004	1							0	0.00
	2004	2							0	0.00 0.00
		3							0	0.00
		4							ō	0.00
	Average	1								0.03
		2								0.00
		3 4								0.00
		4								0.00

			Burgaran San		Concentration		The last of the			
			Actual	5.1.4-00	used for					
Pollutant	Year	Quarter	in ppm	Rule 4702 limit in ppm	calculations in ppm	Emission factor in lbs/MMBtu		icf		
				"' <i>"</i>	m Man	100 # 500				lbs/quarter
							Reading at the	Reading at the	Usage in	
NOx	2003	1	86.0			a diameter	start of quarter 27225	end of quarter 37634	kscf/quarter	0.400.70
	2000	2	89.0				37634	50851	10409 13217	2,483.72
		3			65.0	0.245	50851	61028	10177	3,153.75 2,428.37
		4	87.5				61028	71157	10129	
	2004	1		65			71157	72554		2,416.91
	200 /	2					72554	75325	1397	333.34
		3			65.0	0.245	75325	81634	2771 6309	661.20
		4					81634	83068		1,505.41
	Average	1					01034	03000	1434	342.17 1,408.53
	,gc	2								•
		3								1,907.47
		4								1,966.89
		-								1,379.54
CO	2003	1	254.0				27225	37634	10409	6,814.87
		2	332.0				37634	50851	13217	8,653.30
		3			293.0	0.672	50851	61028	10177	6,662.98
		4	293.0				61028	71157	10129	
	2004	i		2000			71157	72554	1397	6,631.56
	255.	2					72554	75325	2771	914.63
		3			293.0	0.672	75325	81634	6309	1,814.20 4,130.56
		4					81634	83068	1434	
	Average	1					01034	63006	1434	938.85
	7.1.0.L.g.	2								3,864.75 5,233.75
		3								
		4								5,396.77 3,785.20
		•								3,765.20
VOC	2003	1	246.3				27225	37634	10409	9,968.12
		2	1778.4				37634	50851	13217	12,657.19
		3			750.0	0.983	50851	61028	10177	9,745.95
		4	1012.4				61028	71157	10129	9,699.98
	2004	1		750			71157	72554	1397	1,337.83
		2					72554	75325	2771	2,653.63
		3			750.0	0.983	75325	81634	6309	6,041.78
		4					81634	83068	1434	1,373.26
	Average	1					0.501	55555	1404	5,652.98
	-	2								7,655.41
		3								7,893.87
		4								5,536.62
										-,
PM10	2003	1					27225	37634	10409	489.72
		2					37634	50851	13217	621.83
		3					50851	61028	10177	478.81
		4					61028	71157	10129	476.55
	2004	1					71157	72554	1397	65.73
•		2					72554	75325	2771	130.37
		3					75325	81634	6309	296.83
		4					81634	83068	1434	67.47
	Average	1								277.72
		2								376.10
		3								387.82
		4								272.01

				Rule 4702 limit	Concentration used for calculations	Emission factor				
Pollutant	Year	Quarter	in ppm	in ppm	in ppm	in ibs/MMBtu	kı	ci		lbs/quarter
							start of quarter		Usage in kscf/quarter	
NOx	2003	1 2	64.7				27186	29584	2398	564.71
		3	63.6		64.2	0.242	29584	29827	243	57.22
		4	64.2				29827 34729	34729	4902	1,154.39
	2004	1		65			40897	40897 53138	6168 12241	1,452.52 2,882.67
		2					53138	63643	10505	2,473.85
		3			64.2	0.242	63643	70467	6824	1,607.00
		4					70467	71489	1022	240.67
	Average	1								1,723.69
		2								1,265.54
		3								1,380.69
		4								846.60
co	2003	1	231.0				27186	29584	2398	1,486.94
		2	324.0		277.5	0.637	29584	29827	243	150.68
		3	277.5		2.1.0	0.007	29827	34729	4902	3,039.61
		4		2000			34729	40897	6168	3,824.62
	2004	1					40897	53138	12241	7,590.34
		2			277.5	0.637	53138	63643	10505	6,513.89
		4					63643	70467	6824	4,231.39
	Average	1					70467	71489	1022	633.72
	Average	2								4,538.64
		3								3,332.28 3,635.50
		4								2,229.17
voc	2003	1	1779.0				27186	29584	2398	2,296.43
		2	700.8		750.0	0.983	29584	29827	243	232.71
		3	1239.9		7 30.0	0.903	29827	34729	4902	4,694.37
		4	1200.0	750			34729	40897	6168	5,906.75
	2004	1					40897	53138	12241	11,722.53
		2			750.0	0.983	53138	63643	10505	10,060.06
		3 4					63643	70467	6824	6,534.97
	Average	1					70467	71489	1022	978.71
	Average	2								7,009.48
		3								5,146.38
		4								5,614.67 3,442.73
PM10	2003	1					27186	29584	2398	112.82
		. 2					29584	29827	243	11.43
		3					29827	34729	4902	230.63
		4					34729	40897	6168	290.19
	2004	1					40897	53138	12241	575.92
		2					53138	63643	10505	494.24
		3					63643	70467	6824	321.06
		4					70467	71489	1022	48.08
	Average	1 2								344.37
		3								252.84
		4								275.84
		7								169.14

1. 18 A. W. W. L.			er programmer in		Concentration		A STANSON STANSON	三十二十二十二十二十二十二十二十二十二十二十二十二十二十二十二十二十二十二十二		SAN BOARD
			Actual Concentration	Rule 4702 limit	used for calculations	Emission factor				
Pollutant	Year	Quarter	in ppm	in ppm	in ppm	in lbs/MMBtu		icí		lbs/quarter
			그 김사랑 경기					Reading at the	Usage in	
NOx	2003	1	136.4			THE REST REST HERE	Start of quarter 65252	end of quarter 81421	kscf/quarter 16169	2 050 4 4
	2000	2					13676	26481	12805	3,858.14 3,055.44
		3			65.0	0.245	26481	48142	21661	5,168.60
		4					48142	69800	21658	5,167.88
	2004	1		65			69800	89090	19290	4,602.85
		2							0	0.00
		3			65.0	0.245			0	0.00
		4							0	0.00
	Average	1								4,230.49
		2								1,527.72
		3								2,584.30
		4								2,583.94
CO	2003	1	170.0				65252	81421	16169	6,683.99
		2			405.0		13676	26481	12805	5,293.37
		3			185.0	0.424	26481	48142	21661	8,954.30
		4	100.0	2000			48142	69800	21658	8,953.06
	2004	1		2000			69800	89090	19290	7,974.16
		2			185.0	0.424			0	0.00
		3			165.0	0.424			0	0.00
		4							0	0.00
	Average	1								7,329.08
		2								2,646.69
		3								4,477.15
		4								4,476.53
VOC	2003	1					65252	81421	16169	6,752.13
		2			327.1	0.429	13676	26481	12805	5,347.33
		3			527.1	0.420	26481	48142	21661	9,045.57
		4		750			48142	69800	21658	9,044.31
	2004	1					69800	89090	19290	8,055.45
		2			327.1	0.429			0	0.00
		- S 4							0	0.00
	A	1							0	0.00
	Average	2								7,403.79
		3								2,673.66
		4								4,522.78
										4,522.16
PM10	2003	1					65252	81421	16169	760.72
		2					13676	26481	12805	602.45
		3					26481	48142	21661	1,019.11
		4					48142	69800	21658	1,018.97
	2004	1					69800	89090	19290	907.56
		2							0	0.00
		3							0	0.00
		4							0	0.00
	Average	1								834.14
		2								301.23
		3								509.55
		4								509.48

			Actual Concentration	Rule 4702 limit	Concentration used for calculations	Emission factor				
Pollutant	Year	Quarter	in ppm*	in ppm	in ppm	in lbs/MMBtu		scf		lbs/quarter
							Reading at the start of quarter	Reading at the end of quarter	Usage in kscf/quarter	
NOx	2003	.1	107.4				49326	64532	15206	3,628.35
		2	107.4		65.0	0.245	64532	79009	14477	3,454.40
		3 4	107.4				79009	93981	14972	3,572.52
	2004	1		65			93981	94260	279]	445 66.57
	2004	2					9426	24843	15417	3,678.70
		3			65.0	0.245	24843	32527	7684	1,833.50
		4							0	0.00
	Average	1							U	0.00 3,653.53
		2								2,643.95
		3								1,786.26
		4								33.29
co	2003	1	434.0				49326	64532	15206	14,746.40
		2	434.0				64532	79009	14477	14,039.43
		3	424.0		434.0	0.996	79009	93981	14972	14,519.47
		4	434.0	2000			93981	9426	15444	14,977.20
	2004	1		2000			9426	24843	15417	14,951.02
		2			434.0	0.996	24843	32527	7684	7,451.75
		3			104.0	0.000			0	0.00
		4							0	0.00
	Average	1 2								14,848.71
		3								10,745.59
		4								7,259.73
										7,488.60
voc	2003	1 2	324.6 324.6				49326	64532	15206	6,302.41
		3	324.6		324.6	0.425	64532	79009	14477	6,000.26
		4	324.6			•	79009 93981	93981	14972	6,205.42
	2004	1		750			9426	94260 24843	279 15417	115.64
		2					24843	32527	7684	6,389.86 3,184.78
		3			324.6	0.425	2.040	02021	0	0.00
		4							o	0.00
	Average	1							_	6,346.14
		2								4,592.52
		3								3,102.71
		4								57.82
PM10	2003	1					49326	64532	15206	715.41
		2					64532	79009	14477	681.11
		3					79009	93981	14972	704.40
		4					93981	94260	279	13.13
	2004	1					9426	24843	15417	725.34
		2					24843	32527	7684	361.52
		3 4							0	0.00
	Average	1							Q	0.00
	Average	2								720.38
		3								521.32
		4								352.20 6.56

^{*} Engine S-48-10 has only one stack

Crimson Resource Management

Historic Actual Emissions (HAE)

Pollutant	ı	Emissions i	n pounds p	er quarter IV	Total									
NOx	12,518	9,606	9,731	6,248	38,103									
CÓ	32,633	25,320	23,501	19,848	101,303									
VOC	33,186	31,328	30,146	19,701	114,360									
PM10	2,509	2,005	1,968	1,259	7,741									
	New Engine-Generator Emissions (PE2)													
Pollutant		Emissions i			Total									
NOx	2,025	II 2,048	III 2,070	IV 2,070	Total 8,214									
со	7,891	7,978	8,066	8,066	32,001									
voc	3,523	3,562	3,601	3,601	14,286									
PM10	562	568	575	575	2,280									
Actual Emission Reductions (AER)														
Pollutant		Emissions i		1										
NOx	۱ 10,492	11 7,558	III 7,661	IV 4,178	Total 29,889									
co	24,742	17,342	15,435	11,782	69,302									
voc	29,663	27,766	26,545	16,100	100,074									
PM10	1,947	1,436	1,393	684	5,461									
	Emis	sion Reduc	tion Credit	ts										
Pollutant	1	Emissions i		er quarter IV	Total									
NOx	9,443	II 6,803	III 6,895	3,760	Total 26,900									
co	22,268	15,608	13,892	10,604	62,371									
	22,200	,	•	,										
VOC	26,697	24,990	23,891	14,490	90,067									

PM10

1,752

1,293


1,254

4,915

616



Fuel Gas Analysis



NATURAL GAS ANALYSIS

ELAP Cort. 1396

Sinte Certifica Phose # (661) 762 Fax # (663) 76 E-Mail mad

Rev. 9/12/03

Customer: Crimson Resources Attention: Rick Hood

7432.7 Log #: Date Received: 1/12/2004 Date Completed: 1/12/2004

Report Date: 1/13/2004

Semple Description: Meter # 17

Analytical Parameter: Natural Gas Analysis

Constituent		Mole %	WL 7	6. Y. X.
Охурал		0.861	1.283	0.568 *
Nitrogen		5.279	6.889	3.769
Carbon Dioxida		9.023	18.497	15.733 ~
Mothano		75.323	50.289	63.714 *
Ethano		5.584	7.793	10.402 *
Propane		2.681	5.466	3.659
Iso-Butane		0.283	0.766	0.482
N-Butane		0.558	1.510	0.878
tso-Pentane.		0.170	0.571	0.310
N-Pentane		0.279	0.937	0.504
Hexanes Plus		0.000	0.000	0.000
Hydrogen		0.000	0.000	0.000
Hydrogen Sulfide		0.000	0.000	<u>0.000</u>
	Total	100.000	100,000	100.000

Hydrogen Sulfide, ppm ٥ Total Sulfur, as H2S ppm Not Requested

Physical Date		⊈ CX	wat	
BTU cu.ft. kisai		971.55	954.64	3PM
BTU cu.ft. real		974.08	957.13	zfactor
BYUMb, Ideal		17173.91	16875.08	Ffactor
Sp. Gr. Ideal		0.7412		Sp. Vol.
Mp. Or, Pearl		0.7429		
CHONS		% by 192		BEOLOGICAL
% Carbon		61.010		ASTM D 0228-90
% Hydrogen		17.3 3 0		ASTM D 1945-96
% Oxygen		14.732		ASTM D 1946-94
Teganii #		6.559	,	ASTM/D 3588-91
% Suttur		0.000	A	GP# 2145-00
	Total	100.000		1/

* Not edded to GPM value . All Calcuations tabulated @ 80/60

Michael E. Mayfield Laboratory Director **Midway Laboratory**

Frors 7671 Post-it? Fax Note

CRIMSON UH 27:50 V(

1.162 0.9974

8777

17.67

80°d

1291231199



SETTLEMENT AGREEMENT AND GENERAL RELEASE

This Settlement Agreement and General Release (the "Agreement") is made, entered into and executed this <u>fatter</u> day of April 2005 (the "Effective Date"), by and between **SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT**, its predecessors, successors, assigns, subsidiaries, parents, affiliates, agents, representatives, attorneys, insurers, officers, directors and employees (hereinafter referred to as "District"), and **CRIMSON RESOURCE MANAGEMENT CORPORATION**, a Colorado corporation, its predecessors, successors, assigns, subsidiaries, parents, affiliates, agents, representatives, attorneys, insurers, officers, directors and employees (hereinafter referred to as "Crimson").

RECITALS:

- WHEREAS, District issued numerous Notices of Violation to Crimson as referenced in Exhibit 1 of this Agreement attached hereto and incorporated herein;
- WHEREAS, District alleges, as set forth in said Notices of Violation, that Crimson violated District rules at its oil production facilities located in Kern County, California. District seeks civil penalties as a result of said Notices of Violation pursuant to California Health and Safety Code sections 42402 to 42402.3;
- WHEREAS, Crimson disputes the allegations made by District in the Notices of Violation and Crimson denies that it has violated District rules or is in any way liable for any such alleged violations;
- WHEREAS, District acknowledges that Crimson has spent approximately Three Million dollars (\$3,000,000.00) to purchase and install equipment that will allow Crimson to electrify its 1-C Gas Plant, located in Taft, California, which will reduce air emissions in the San Joaquin Valley when completed;
- **WHEREAS**, it is estimated that the electrification project Crimson is undertaking will reduce potential NOx emissions in the San Joaquin Valley by an estimated 73,816 pounds per year;
- WHEREAS, Crimson and District desire to settle, resolve and compromise any and all disputes between them.
- NOW, THEREFORE, in consideration of the covenants, promises, and undertakings set forth herein, and for good and valuable consideration, the receipt and sufficiency of which is hereby acknowledged, Crimson and District agree as follows:

1. Payment.

A. <u>Cash</u>. Crimson shall pay District the total sum of Four Hundred Thousand Dollars (\$400,000.00), payable as follows: Crimson will pay District Thirteen Thousand, Three Hundred Thirty Four dollars (\$13,334.00) each

month for a period of thirty (30) months, or until the total amount of \$400,000 is paid in full. The initial payment is due May 1, 2005. The parties agree that, pursuant to section 523(a)(7) of the Federal Bankruptcy Code, 11 U.S.C. § 523(a)(7), the above \$400,000.00 fine is non-dischargeable should Crimson file for bankruptcy prior to paying the fine in full.

- B. <u>Emission Reduction Credits</u>. In addition to the cash payments stated in section 1.A. above, Crimson shall also surrender to the District, upon the issuance of emission reduction credit ("ERC") certificates pursuant to District Rule 2301, one-half (1/2) of any ERCs for NOx generated and approved by the District as a result of the genset electrification project Crimson is currently undertaking at the 1-C Gas Plant. The total available ERCs for NOx are currently estimated at a value of approximately \$800,000.
- 2. <u>Schedule</u>. Pursuant to this Agreement, Crimson shall implement the following schedule:

A. Start-Up.

The parties agree that start-up of the genset engines as described in and authorized by District permit numbers S-48-28-0, S-48-29-0, and S-48-30-0 occurred prior to the execution of this Agreement.

- B. <u>Testing</u>. Crimson agrees to conduct source testing of the genset engines within sixty (60) days of start-up of the engines, unless Crimson is granted a variance from the 60-day deadline by the District's Hearing Board due to unforeseen difficulties beyond Crimson's reasonable control. In the case that Crimson is granted a variance, testing shall occur by the deadlines set forth in the variance.
- C. <u>Submission of Test Results</u>. Crimson agrees to submit the results of the testing conducted pursuant to paragraph 2.B. above within sixty (60) days of the completion date of the testing for each genset engine, whether or not the test results demonstrate compliance with District rules.
- D. <u>Decommissioning Existing 1-C Gas Plant IC Engines.</u>
 Crimson agrees to permanently disable the seven (7) IC engines (District ID numbers S-48-3, S-48-4, S-48-5, S-48-7, S-48-8, S-48-9 and S-48-10) that were in existence at the 1-C Gas Plant prior to the installation of the genset engines and have not been electrified to date by July 1, 2005. Crimson shall notify the District when it has complied with this requirement and the District shall verify Crimson's compliance with this requirement by conducting an inspection at Crimson's facility. "Permanently disable" as used in this paragraph shall mean to render the engines forever inoperable so that they may never be re-sold or re-used.

- Request for Extension. It is understood that one or more of the 3. actions identified in the schedule in paragraph 2 may not be achieved by the date provided in this Agreement for reasons beyond the reasonable control of Crimson, including but not limited to, reasons such as late delivery of necessary equipment by a vendor, the delivery of malfunctioning equipment, equipment malfunctions, or delays in approval by PG&E. For those actions governed solely by the terms of this Agreement. Crimson shall notify the District, through its counsel, whenever, due to circumstances beyond Crimson's control, it believes that it will be unable to complete an action by the deadline date and shall request an extension. District shall evaluate the circumstances surrounding the delay and shall make a determination in writing whether to grant the extension. District's approval of the extension shall not be unreasonably withheld. In the event that the delayed action is regulated pursuant to a District rule, Crimson shall consult with the District regarding the appropriate method for obtaining an extension and, if necessary, shall pursue an extension through the District variance process.
- 4. <u>Non-Compliance with Schedule</u>. In the event that Crimson does not comply with the schedule set forth in paragraph 2 and District does not authorize an extension of that date or an extension is not granted through District's variance process, Crimson shall be liable to District for an additional Five Hundred dollars (\$500.00) per day following the date of District's denial of the extension or denial of the variance until the action has been completed. Payment of the \$500.00 per day penalty does not preclude District from filing appropriate legal action to enforce the terms or schedules contained in this Agreement.
- 5. Release. As a material inducement to Crimson to enter into this Agreement, District hereby irrevocably and unconditionally releases, acquits and forever discharges Crimson and each of Crimson's predecessors, successors, assigns, and heirs, and as to each of the aforementioned, their agents, managing agents, directors, officers, shareholders, servants, employees, representatives and attorneys, and all persons acting by, through, under or in concert with any of them (collectively "Crimson Releasees"), from any and all charges, complaints, claims of action, suits, rights, demands, costs, losses, debts and expenses (including attorneys' fees and costs actually incurred) of any nature whatsoever, whether known or unknown, direct or indirect, suspected or unsuspected, fixed or contingent, which District now has, owns or holds, or claims to have, own or hold, or which District at any time heretofore had, owned or held, or claimed to have, own or hold, against each and all of Crimson Releasees which arises out of or related in any way to the Notices of Violation described in Exhibit 1 hereto.
- 6. <u>Authority of Signatories</u>. Crimson and District, individually, represent and warrant that no other person or entity has, or has had, any interest in the claims, demands, obligations and causes of action referred to in this Agreement; that it has sole right and exclusive authority to execute this Agreement and receive the sums specified in it; and that it has not sold, assigned, transferred, conveyed or

otherwise disposed of any of the claims, demands, obligations or causes of action referred to in this Agreement.

- 7. <u>Press Release</u>. In the event District issues a press release regarding the terms of this Agreement, District shall provide Crimson with a copy of said press release at least five (5) days prior to it being issued.
- 8. <u>No Admission of Liability</u>. Crimson and District, individually, acknowledge and agree that the payment and acceptance of the sums described in Paragraph 1 and the execution and performance of this Agreement are the result of a compromise of disputed claims. Neither the payment of money by Crimson nor this Agreement shall be deemed to be an admission of liability concerning any of the claims and/or Notices of Violation referenced in this Agreement, and no past or present wrongdoing or liability upon the part of any of those herein released shall be implied by any of the agreements herein. This Agreement shall not constitute any admission of violation as to any District rule, nor shall it be inferred to be such an admission in any administrative or judicial proceeding.
- 9. <u>Waiver</u>. Crimson and District, individually, expressly waive and assume the risk of any and all claims for damages which exist as to the claims and/or Notices of Violation which are the subject of this Agreement, but which it does not know of or suspect to exist, whether through ignorance, oversight, error, negligence or otherwise, and which, if known, might materially affect its decision to enter into this Agreement and, further assumes the risk that it may suffer damages in the future which it does not now anticipate or suspect may occur and therefore waive all rights under Section 1542 of the Civil Code of California which reads as follows:
- "A GENERAL RELEASE DOES NOT EXTEND TO CLAIMS WHICH THE CREDITOR DOES NOT KNOW OR SUSPECT TO EXIST IN HIS FAVOR AT THE TIME OF EXECUTING THE RELEASE WHICH, IF KNOWN BY HIM, MUST HAVE MATERIALLY AFFECTED HIS SETTLEMENT WITH THE DEBTOR."
- 10. <u>Construction</u>. In entering into this Agreement, each party, individually, represents that it has relied upon the legal advice of its attorneys who are attorneys of its own choice; it further represents that the terms of this Agreement have been completely read by it, or fully understood and voluntarily accepted by both its attorneys and itself, it and its counsel has reviewed and revised, or had the opportunity to revise this Agreement, and accordingly the normal rule of construction to the effect that any ambiguities are to be resolved against the drafting party is not applicable and therefore shall not be employed in the interpretation of this Agreement or any amendment of it.

against the drafting party is not applicable and therefore shall not be employed in the interpretation of this Agreement or any amendment of it.

- 11. <u>Entire Agreement</u>. This Agreement contains the entire understanding of Crimson and District with regard to the matters set forth herein and may only be amended by writing executed by both Crimson and District.
- 12. <u>California Law</u>. This Agreement has been entered into in the State of California and shall be construed and interpreted in accordance with the laws of said state.
- 13. <u>Venue</u>. The parties agree that venue for any action arising out of this agreement shall be only in Kern County, California.
- 14. <u>Counterparts</u>. This Agreement may be executed in counterparts, and each of those counterparts shall be deemed an original for all purposes.

WHEREFORE, the authorized representatives of the parties hereto have executed this Agreement on the date first above written.

MANAGEMENT CORPORATION	POLLUTION CONTROL DISTRICT
By: My Mulause Gary Buntmann you Vice President	By: David L. Crow
Date: 3/30/05	Executive Director / APCO Date: 4/6/05
Approved as to legal form:	Approved as to legal form:

By: Philip M. Jay
Attorney for District
Date: 4-5-05

SAN JOAQUIN VALLEY UNIFIED AIR

DNVR 1-60294546-02

Date:

CRIMSON RESOURCE

Mark N. Semenot

Attorney for Crimson

30/02

APPENDIX D
Fuel Usage Data

1C Gas Plant Fired Equipment Daily Rounds Report Night Operator Signature JULIUAN Day Operator Signature Compressors Crank Case Meter Comp. Cyl. Meter Wir Wir Oil Oil Oil Fuel Temp Temp Temp Press Used Fuel Today Compressor Uischarge Temperatures Power Cylinder Temperatures Cyl. Meter Equip. R.O. Clark # Clark #2 13 60 520 500 元278 月10312 12-12-17 Clark #6 33/17/186 9 7k #12 XVG Elect Assist Are One Shot 155 200 213 ∠K-2 Lubricators Full? شؤسق XVG Elect Assist Are One Shot Lubricators Full? Pump

			₹.:0	Sy	ster	n		
K	inlet			ress.		low Ra		Pump
ľ	ilter D. P		1 st.	2 nd.	2 nd.	1 st.	Final	Press
L	ـــــــــــــــــــــــــــــــــــــ	- ^_			<u>-</u>		-	107
	Water Meter Reading							
-		Today	,					
		Yesterd						
IL.		Total						

		xilla A <u>ir</u> ipre	SSC		
Equipment		Hrs. -Off		Today	Fuel Usedi
4-1 <u>A</u>	15				

Emerc Fla	jenç re	Y.
Equipment -	Up	 - Dow.~
F-1	-	
F-2	-	

		Sea	als		i i
Pump-	ОК	Leaks	Pump	DК	Lea
P-5A		-	-		\Box
P-5B	i			<u></u>	L
-P-6A	4				
P-68					Ľ.
P-7A					
P-7B					
AB-9	1				
P-88					


4		- 5	tanc	l RÀ	Lle	ctri	c Ge	enei	ato	rs			
						Fuel				·	Fuel	Fuel	
men	Eng		Oil	Oil				Wtr.					
	RPM		Temp	Press.	Level	Level	Volt	Temp.	On	ŌĦ	Read	Read	Used
KW	-	-	-		-	-	-	į.	3	27	-		-
4]				10	24			

	Hot Oil Skid							
		Fuel	Fuel					
Hours	Hours	Prev.	Today	Fựel				
Qn.	QĦ	Read	Read	Us <u>ed</u>				
1	-	_		- j.				
12+	1			54°				
<u></u>	ليجيا	<u></u>	<u></u> _					

Fue	l Char	t Readin	gs	}
Equipment	Coef.	Static	Diff.	
K2 / K3	3.01	1.4		bil
Hot oil Skid	3.598			34

Day Operator Signature Scale of Mose

Date: 3-30-03



Oil Fuel Tank Bat. Wtr. Hours Hours Prev. Today Fuel

Off Read Read Used

Temp Press, Level Level Volt, Temp, On

Comm	en	ts:

Eng

quipment

900 KW 50 KW

Hot Oil Skid						
		Fuel	Fuel			
Hours	Hours	Prev.	Today	Fuei		
On	Off	Read	Read	Used		
	_					
122	7					

Fu	Fuel Chart Readings													
Equipment	Coef.	Static	Diff.											
K2 / K3	3.01	96	2-0											
Hot oil Skid	3.598	6.3	3,4											

						1C	Ga	s P	lan	t Fi	red	EC	Juip	me	nt L	Jail	у К	lou	nds	Re	eport			_	/ 5	1 m N 2	
	Day (Operat	tor Si	gnatu	are\	306	R	حث								Nigh	ıt Op	erato	r Sigı	natur	e_2D	N	TV	D م	ate: <u>6~ </u>	0-03	
													Col	mpr													
Equip.	Eng RPM	R.O. Rate	Com #1		or Disci eratures #3		#1	#2	ower C	ylinde #4	r Tem #5	peratui #6	res #7	#8	Wtr Temp In	Wtr Temp Out	Oil Temp In	Oil Temp Out	Oil Press	Fuel Used	Fuel Today Yesterday	Hrs On	Hrs Off	Crank Case Meter	Power Cyl. Meter	Comp. Cyl. Meter	
Clark #1	310		230	260	280		681	500	ડ્યક	6૦૦	چین	613			140	140	140	/80	35		27772	24	8	0423	4026	7269	1
Clark #2																		,			7932	{					2
Clark #5	300		240	260	280		6 20	උන	610	SFO	೯೦೨	SED			140	143	440	185	35		5025 50676	24	4	5723	793931	230054	5
Clark #6	,																				29827						6
)rk #12																					26481	1					12
Clark #14			110	220		all.										98			45		nist.	24	é	1/5		1016	14
Clark #15										1		(2) (3)			ri. Sept												15
Clark #16	320		25	ભાર	242		600	డలు	SE0	5%	610	රුව			140	142			35		79009 78773	24	6-	8209	₅₅ 3783	161471	16
XVG K-2	330		/40	140	150		Elect A	\ssist		One S cators		V			135	190			B			24	20			38552	K-2
XVG K-3	335		143	105	150	1/4/5	Elect A	λssist У€5		One S ators		/			12.5	149			معود ريو چر وي		611 (1912) 14 (1912)	24	18	5706		24259	К-3
Telestra in the second	Harris H.		ם מ	e.	Afar		J markin	1040.72.2				da de	ŠAŅIZDI.	i A.J.	321112	* ********		ante de				र सुधा प्रकार । नहीं। संदेश	PROUD'S	7.55.51	(a);	imn	1

	R. 0	. Sy	sten	n								
Inlet Pass Press. Flow Rate F												
Filter D. P.	1 st.	2 nd.	2 nd.	1 st.	Final							
<u></u>		<u> </u>				L						
	Water M	leter Re	eading									
Tod	fay											
Yeste	erday											
To	tal											

ASSESSMENT OF THE PERSONS AND ADDRESS AND ADDRESS AND ADDRESS AND ADDRESS AND ADDRESS AND ADDRESS AND	THE RESERVE OF THE PARTY.	1			Charles Manager
	Au	vill.	37.6		BINDIANE.
	MU	VIIIC		2012234	
	7-1425	Δir	5 CO CO CO		244.
					591.691
Manual Control of the Control			Tival)		
	Con	nnre	122	12	B. B
Britist Francisco	and adding		CHARLES WOOD	* >=***********************************	Washing.
			Fuel	Fuel	
Equipment	Hen	Lien	Dear	Today	Eural
Equipment	ms.	Hrs.		Today	
l	On	Off	Read	Read	Used
	I	1			
4-1A		i	i		
4-174	6	20			
	I -		ļ	1	i 1
	I			<u> </u>	

Service Management Cont.		
Emerg Flai	enc e	y .
Equipment	Up	Down
F-1	191	
F-2	182	

	Pi Se	imp als
Pump	ок	Leaks
P-5A		
P-5B	1	
P-6A	1.2	
P-6B	1, 0	
P-7A	t.	
P-7B	100	
P-8A	 	
P-88	(se)	

			S	tanc	l By	Ele	etric	c G	ener	ato	rs			
ĺ							Fuel					Fuel	Fuel	
Ì	=quipment			Oil	Oil	Fuel	Tank	Bat.	Wtr.	Hours	Hours	Prev.	Today	Fuel
į		RPM		Temp	Press.	Level	Level	Volt.	Temp.	On	Off	Read	Read	Used
[500 KW									-6-	24			
į	150 KW							 -		-6-	24			

	Hc	ot O	il SI	(id
		Fuel	Fuel	
Hours	Hours	Prev.	Today	Fuel
Qn	Off	Read	Read	Used
			-	
211	-			
7				

Fue	el Cha	rt Readi	ngs
Equipment	Coef.	Static	Diff.
K2 / K3	3.01	7.4	5-4
Hot oil Skid	3.598		7

Comments:

Day Operator Signature Sulleran

O KW

Comments:

Night Operator Signature Myss

Date: 9-30-63

3.598

Hot oil Skid

Compressors Compressor Discharge Temperatures Fuel Today Power Cylinder Temperatures emp Temp Temp Temp Press Used R.O. Equip. #3 #4 Out Yesterdai 4026 294 Clark #2 9228 096/21 56985 Dlark #5 297 40 235 26 Clark #6 ark #15 ark #16 XVG Elect Assist Are One Shot Lubricators Full? XVG Are One Shot Elect Assist 01.585 On? K-3 Lubricators Full? Pump* R.O. System Auxillary Emergency Flow Rate Air Seals Flare Filter D. P. 1 st. 2 nd. 2 nd. 1 st. Final Press Compressor Pump Leaks Equipment Up Down P-5A P-58 Water Meter Reading Equipment Hrs. Hrs. Prev. Today Fuel F-1 166 Read Read Used P-6A Today P-6B Yesterday F-2 4-1A P-7A Total P-7B P-8A P-88 Stand By Electric Generators Hot Oil Skid Fuel Chart Readings Fuel Fuel Fuel Diff. Static i pment Coef. Fuel Tank 8at. Wtr. Hours Hours Prev. Today Fuel Hours Hours Prev. Today Fuel Equipment Eng Temp Press, Level Level Volt. Temp. On Off Read Read Used Off Read Read Used **RPM** K2 / K3 9.4 3.01 0 KW

Night Operator Signature ED 17 TRO Date: 10-3-03 Day Operator Signature Cod Price

													Compi	ress	ors											
Equip.	Eng RPM	R.O. Rate	#1	mpress Tempe #2	or Disc erature: #3	harge s #4	#1	#2	ower C	ylinder #4	Temp	peratu #6	res #7 #8	Wtr Temp	Wtr Temp	Oil Temp	Oil Temp Out	Oil Press	Fuel Used	Fuel Today Yesterday	Hrs On	Hrs Off	Crank Case Meter	Power Cyl. Meter	Comp. Cyl. Meter	
Clark #1			220	240	2100									120	130			46		UUST	24	æ		4026		1
Clark #2													re que an							10486	1					2
Clark #5																				-;						5
Clark #6	50	y	230	245	240								1923 (V) 1923 (V)		130	120	170	77			€4	É		65 =	: 13/32	6
° 7#12	3/3	V85	240	195	265	C. J								130	140	ಆವಿ	95	32		상사						12
Clark #14																								e de la composition della comp		14
Clark #15	基準												eranda eta eta La la		60			1 7					9920			15
Clark #16	\ (%)	75	96.	<u> </u>	580									1.7	/to			.,		9426	2.75	چين	519	4915 x	- 971 a	16
XVG K-2	332		120	120	195		- · · · · · · · · · · · · · · · · · · ·	V85		One SI ators F		1/		Par.	130			45			<u>.</u> 4	Ø			CS 71	K-2
XVG K-3							Elect A	ssist		One Sl ators F																K-3
res;			₹. 0	. Sy	ster	'n	1 1 1 2 2					F. C.	Αü	xilla	irV#					. Em	era	ene	V.	Pu	mp 💮	-

	R.O	. Sy	ster	n .		
Inlet	Pass	Press.	F	Pump		
Filter D. P.	1 st.	2 nd.	2 nd.	1 st.	Final	Press
					1	
	<u>t</u>		نـــــــــا			Ь —
	Water M	leter Re	eading			
To	day	•				
Yes	erday					
To	otal			• •		\neg

				1300	
	Au Con	ixilla Air apre	ar y	or.	
Equipment	Hrs. On	Hrs. Off		Today	Fuel Used
4-1A					

		<u>. </u>
Emerg Flar	enc e	ý
Equipment	Uр	Down
F-1		
F-2		

		ımp als
Pump	OK	Leaks
P-5A		
P-5B		
P-6A		
P-6B		·
P-7A		
P-7B		
P-8A		
P-8B		

) }}::	Star	ıd By	Ele	ctri	c G	ener	ato	rs			;
Equipment	F	0:	. 01	C1	Fuel	D-4	144.				Fuel	
-quipinem	Eng RPM	Oi Ten	l Oil 1p Press.	Fuel Level	Level	Volt.	Temp.	Hours On	Off	Prev. Read	Today Read	Fuel Used,
500 KW												
150 KW												

	Fuel	Fuel	
Hours	Prev.	Today	Fuel
Off	Read	Read	Used
			Hours Prev. Today Off Read Read

Fu	el Cha	rt Readi	ngs
Equipment	Coef.	Static	Diff.
K2 / K3	3.01	9-7	2.3
Hot oil Skid	3.598		

Comments:

Date: 3-29-04

3.598

Hot oil Skid

12

16

K-2

Night Operator Signature <u>Barry Sullivan</u> Day Operator Signature Col Price Compressors Wtr Wtr Oil Oil Oil Fuel Temp Temp Temp Press Used Compressor Discharge Temperatures Hrs Hrs Power Cylinder Temperatures R.O. Rate Equip. Today Yesterday #3 #4__ #5 Clark # 55267 Clark #2 11881 Clark #5 Clark #6 53003 B Clark #1 Clark #10 XVG Elect Assist Are One Shot K-2 On? Lubricators Full? XVG Elect Assist Are One Shot K-3 Lubricators Full? Pump * R. O. System Auxillary Emergency Flow Rate Seals Air Flare: Filter D. P. 1 st. 2 nd. 2 nd. 1 st. Final Press Compressor OK Pump Down Equipment Water Meter Reading Equipment Hrs. Hrs. Prev. Today Fuel P-5B F-1 On Off Read Read Used P-6A Today P-6B Yesterday P-7A Total 4-1A 24 P-7B P-8A Stand By Electric Generators Hot Oil Skid **Fuel Chart Readings** Diff. quipment Oil Fuel Tank Bat. Wtr. Hours Hours Prev. Today Fuel Equipment Coef. Eng Hours Hours Prev. Today Fuel Temp Press. Level Level Volt. Temp. On Off Read Read Used Off Read Read **RPM** K2 / K3 500 KW

Comments:

150 KW

Topfuel unding taken 4-2-04 e givo sur.

Day Operator Signature SUIIVAN

Night Operator Signature Nitro

Date: 6-30-04

Compressors Compressor Discharge Temperatures #1 #2 #3 #4 Wtr Wtr Oil Oil Oil Fuel Temp Temp Temp Press Used Comp. Cyl. Meter Power Cylinder Temperatures Equip. Today Yesterday Off Clark # Clark #2 293 Clark #5 Clark #6 Clark #14 24/0 Clark #15 04000 Clark #16 54/321 XVG Elect Assist Are One Shot K-2 On? Lubricators Full? XVG Elect Assist Are One Shot K-3 **Tubricators Full?** R. O. System Auxillary ::-Emergency Pump Pass Press. Flow Rate Pumo Air Flare Seals Fifter D. P. 1 st. 2 nd. 2 nd. 1 st. Final Press Compressor OK Leaks Pump Equipment QD. Down P-5A Water Meter Reading Equipment Hrs. Hrs. Prev. Today Fuel P-5B F-1 222 On Read Read Used Today P-6A Yesterday P-6B F-2 4-1A P-7A P-7B P-8A P-8B

		 tanc	ı By	LIE	CTI	C (5)	enei	ato	rs	, A		ij.
	!				Fuel					Fuel	Fuel	
quipmen	Eng	Oil	Oil				Wtr.					
	RPM	 Temp	Press.	Level	Level	Volt.	Temp.	On	Off	Read	Read	Used
500 KW								Ð	24			
150 KW								Û	24			

Comments:

· 선물보다로 프로프 프라이트 시간 시간 사고 문으로 함께 가면 깨끗을 들어야 하다. (i)

Fuel		
	Fue	
s Prev.	Today	Fuel
Read	Read	Used
<u> </u>		
		s Prev. Today Read Read

Fu	el Cha	rt Readi	ngs
Equipment	Coef.	Static	Diff.
K2 / K3	3.01	9.6	2.0
Hot oil Skid	3.598	6.6	3.3

1C Gas Plant Fired Equipment Daily Rounds Report

Price

Night Operator Signature Nitto

Date: 9-26-04

Day Operator Signature_

Comments:

						·			ě		Ç.	. •	Со	mpi	ress	ors			÷ .	<u>.</u>						- · · · · ·	
Equip.	Eng RPM	R.O. Rate	ı	npress Tempe #2	or Disc erature: #3	narge s #4	#1	#2	Power #3	-		nperatu #6		#8	Wir Temp In		Oil Temp In	Oil Temp Out	Oil Press	Fuel Used	Fuel Today Yesterday	Hrs On	Hrs	Crank Case Meter	Power Cyl. Meter	Comp Cyl. Meter	
Clark #	1294	10	210	271	150										125	135		4535	33		79768 79963						
Clark #	2		<u> </u>												Material			,									
Clark #	5302	10	220	229	235										175	136		-	37		81634 31307 70407	-					
Clark #	6														an Wasser						70467						
<u>)</u> ; #1	2																					0	24	-			
Clark #1	4		240	124												87			49					7034		46619	
Clark #1	5		255	265												४९			77					0871		31000	>
Clark #1	6																				32527 32527						
XVG K-2	<u> </u>						Elect A	Γ	Lubri	one s	Full?																*
XVG K-3	335		140	141	190	193	Elect A	Assist	E .	One S		[130	134		圖	43					6429		00966	<u> </u> K
	Inlet		R.O.	⁻ress.	F	low Ra		Pump						Au	ixilla Air							erge Flar		.y	II sive in the state of	ump eals	
	ter D. P.		1 st.	2 nd.	2 nd.	1 st.	Final	Press	,				(Con	npre	sso					Equipm		Up	Down	Pump OK		
			Vater M	eter Re	ading							Equi	ipment		Hrs.		Today F				F-1				P-5A P-5B		1
		Today Yesterd												On	Off	Read	Read L	Jsed		-	F-2				P-6A P-6B		
<u> </u>		Total	<u></u>]			4-	-1A							L				<u> </u>	P-7A P-7B		1
																					_				P-8A P-8B		4
	· ·	S	tand	Ву	Ele		: Ge	ner	atoı	rs						Но	t Oil		id				Fu	el Char	t Readi	ngs	
quipmen	Eng RPM		Oil Temp		Fuel Level						Prev.				Hours I On		Fuel 1 Prev. T Read F	oday	Fue Use	- 11		Equipn	nent	Coef.	Static	Diff.	
500 KW																						K2/1	К3	3.01	9-7	2.2	
150 KW	1 1		ĺ	ŀ	1	T			Ţ					Ĥ			ł	- 1		1		انه ده	أمناع	3.598	1	14.7	il .

Date: 12-3/-04

Day Operator Signature Price Morning Tower Operator Signature

							ere ere				in Tolla C. M. K. S. Swart Marks				ri Lit Martinita						energy Berly A	i de la companya de Companya de la companya de la compa		
Equip.	Eng RPM	R.O. Rate	Con #1	npresso Tempe #2	r Discr ratures #3	arge #4	#1	ower (Sylinder #3	Tempera #4	atures #5 #6	VVtr Temp In	Wtr Temp Out	Oil Temp In	Oil Temp Out	Oil Press	Fuel Used	Fuel Today Yesterday	Hrs On	Hrs Off	Crank Case Meter	Power Cyl. Meter	Comp. Cyl. Meter	
Clark #1																		80069 80069						1
Clark #3			195	260	215											46		29.5	24	e	1311	88734	143198	3
Clark #5																		830G 830K					""	5
Clark #6																		71489						6
Clark #12			200	205	230	25్డ				er er									24 ·	6	5903			12
Clark #14	K TES	124			- -														24	&-	3349		29483	14
Clark #15											troppi 1861											undundus Alexandra		15
Clark #16																	teath at							16
XVG K-2							Elect / On?	\ssist		One Sho ators Ful	1											A side a	A	K-2
XVG	3 <i>5</i> 6	ari kata Mata	120	120 .	45	ιίω	Elect / On?	Assist પ્રદેડ	Are	One Sho		85	100			52			24	6	6509		15743	K-3

	H.A.B	l. O.	Sys	sten			
Inlet	Total		Press.		low Ra		Pump
Filter D. P.	D. S.	_1 st.	2 nd.	2 nd.	1 st.	Final	Press
 	L		l .	L	L	<u> </u>	L
	V	Vater M	eter Ke	eading			
	Today			İ			
, , , , , , , , , , , , , , , , , , ,	esterda	ıy					
	Total						

	A Co	lixu Aiı npr	ary esso)I	
Equipy	nent H	rs.	Fuel		
Edoth		. • .	Prev.	Today	Fuel
Equipi	On	Off	Prev. Read		Fuel Used

Emerg Flar	enc e	Y Sagar
Equipment	Up	Down
F-1	200	
F-2	140	

	Pi Se	ımp als
Pump	ОК	Leaks
P-5A		
P-5B	7	
P-6A	~	-
P-6B	ĺ	
P-7A	7	
P-7B	~	
P-8A	レ	
P-8B		

		Sta	nd E	By E	lect	ric (Gen	erat	ors			
						Level					Fuel	Fuel
Equipment	Eng	Oil	Oil	Oil		Storg.						
	RPM	Level	Temp	Press.	Tank	Tank	Volt.	Temp.	On	Off	Read	Read
500 KW									e-	24		
150 KW			•						e	24		

Fue	l Char	t Readin	gs
Equipment	Coef.	Static	Diff.
K2 / K3	3.01		
Hot oil Skid	3.598		

Comments:



Source Test Results

Crimson Resource Management Taft Area IC Engine 7D 1 - North Stack Project 129-3370D October 24, 2003 Permit No. S-48-3-3

Pollutant	ppm	ppm @ 3% O ₂	ppm @ 15% O ₂	Permit Limits
1 Officiality	58	142		Limits
NOx	58	144	47 48	
NOX	75	181	60	
Mean	64	156	52	75 ppm @ 15% O ₂
	145	356	117	
CO	142	353	116	
	141	341	112	,
Mean	143	350	115	2000 ppm @ 15% O
	382.0	936.6	308.7	
voc	383.2	952.7	314.1	• •
C3 - C5+ as C1	371.8	899.4	296,4	}
Mean	379.0	929,6	306.4	750 ppm @ 15% O ₂
Comments:				
		······································		
	•		·PE	
*****	·······	· · · · · · · · · · · · · · · · · · ·		·
				
		<u>, </u>		
				<u> </u>

Crimson Resource Management Taft Area IC Engine 7D 1 - South Stack

Project 129-3370D October 24, 2003 Permit No. S-48-3-3

<u></u>		ррт @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	79	214	71	
Nox	81	220	72	
	77	212	70	
Mean	79	215	71	75 ppm @ 15% O ₂
	156	423	139	
CO	164	445	147	
	171	471	155	
Mean	164	446	147	2000 ppm @ 15% O ₂
	1917.3	5199.9	1713.9	
VOC	1976.3	5359.9	1766.7	
C3 - C6+ as Ct	1743.8	4802.1	1582.9	
Mean	1879.1	5120.6	1687.8	750 ppm @ 15% O ₂
Comments:	·			
		··-		
				
			,	
				and the second s

Crimson Resource Management Taft Area I C Engine 2 - North Stack Project 129-3370A August 29, 2003 Permit No. S-48-4-3

		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	34	85	28	
NOx	36	91	30	
	38	93	31	
Mean	36	90	30	75 ppm @ 15% O ₂
•	153	380	125	
co	155	391	129	
	151	370	122	
Mean	153	380	125	2000 ppm @ 15% O
	1772.1	4405.7	1452.1	
voc	1846.2	4654.4	1534.1	
C ₃ - C ₆ + as C ₁	1906.6	4675.1	1541.0	
Mean	1841.6	4578.4	1509.1	750 ppm @ 15% O ₂
Comments:				
			-	
				
		·		

Crimson Resource Management Taft Area IC Engine 2 - South Stack Project 129-3370A August 29, 2003 Permit No. S-48-4-3

		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	36	79	26	
NOx	38	84	28	
	36	81	27	
Mean	37	81	27	75 ppm @ 15% O ₂
	160	349	115	
co	159	351	116	
	154	345	114	
Mean	158	348	115	2000 ppm @ 15% O
	968.2	2113.5	696.7	
VOC	890.9	1968.8	648.9	
C ₃ - C ₆ + as C ₅	898.3	2009.9	662.4	
Mean	919.1	2030.7	669.3	750 ppm @ 15% O ₂
Comments:				
				
		•		<u></u>

Crimson Resource Management Taft Area IC Engine 1 - North Stack Project 129-3370A August 27, 2003 Permit No. S-48-5-3

		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	61	144	47	
NOx	63	154	51	
	60	145	48	
Mean	61	148	49	75 ppm @ 15% O ₂
	140	330	109	
co	135	331	109	
	135	327	108	
Mean	137	329	109	2000 ppm @ 15% O
	364.7	859.0	283.1	
VOC	342.4	839.6	276.7	
C ₃ - C ₆ + as C ₁	295.3	714.2	235.5	
Mean	334.1	804.3	265.1	750 ppm @ 15% O ₂
Comments:				
			· · · · · · · · · · · · · · · · · · ·	
	A41			
	-			

Crimson Resource Management Taft Area IC Engine 1 - South Stack Project 129-3370A August 28, 2003 Permit No. S-48-5-3

		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	37	88	29	
NOx	36	86	28	
	30	75	25	
Mean	34	83	27	75 ppm @ 15% O ₂
	294	702	231	
CO	248	592	195	
	256	636	210	
Mean	266	643	212	2000 ppm @ 15% O
	1172.8	2799.1	922.6	
VOC	1267.8	3025.8	997.3	
C ₃ - C ₆ + as C ₁	1298.9	3229.2	1064.4	
Mean	1246.5	3018.0	994.8	750 ppm @ 15% O ₂
Comments:				
	<u></u>			
·				
			···	

Crimson Resource Management Taft Area IC Engine 5 - North Stack Project 129-3370A August 27, 2003 Permit No. S-48-7-3

		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	109	250	82	
NOx	116	263	87	
	116	273	90	
Mean	114	262	86	75 ppm @ 15% O ₂
	321	737	243	
CO	345	782	258	
	336	791	261	
Mean	334	770	254	2000 ppm @ 15% O
<u></u>	332.9	764.0	251.8	
voc	333.4	755.4	249.0	
C3 - C6+ as C1	306.6	722.2	238.1	
Mean	324.3	747.2	246.3	750 ppm @ 15% O ₂
Comments:				

Crimson Resource Management Taft Area IC Engine 5 - South Stack Project 129-3370A August 27, 2003 Permit No. S-48-7-3

		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	94	267	88	
NOx	92	266	88	
	100	280	92	
Mean	95	271	89	75 ppm @ 15% O ₂
	343	975	321	
co	365	1054	347	
	356	996	328	
Mean	355	1008	332	2000 ppm @ 15% O
	1824.5	5183.9	1708.7	
voc	1934.7	5585.7	1841.1	
C3 - C6+ as C1	1936.6	5416.5	1785.3	
Mean	1898.6	5395.4	1778.4	750 ppm @ 15% O
Comments:		<u></u>		

Crimson Resource Management Taft Aera IC Engine 6 - North Stack Project 129-3370B October 2, 2003 Permit No. S-48-8-3

		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	82.5	183.9	60.6	
NOx	94.4	205.1	67.6	
	86.6	190.2	62.7	
Mean	87.8	193.1	63.6	75 ppm @ 15% O ₂
	432	963	317	
CO	450	978	322	
	459	1008	332	
Mean	447	983	324	2000 ppm @ 15% C
	1014.8	2262.0	745.6	
voc	1034.4	2247.1	740.6	
C ₃ - C ₆ + as C ₁	851.1	1869.3	616.1	
Mean	966.8	2126.1	700.8	750 ppm @ 15% O
Comments:				
				
		· · · · · · · · · · · · · · · · · · ·		

Crimson Resource Management Taft Aera IC Engine 6 - South Stack Project 129-3370B October 2, 2003 Permit No. S-48-8-3

		ppm@	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	66,5	197,1	65.0	
NOx	62.8	187.7	61.9	
	68.2	204.1	67.3	
Mean	65.8	196.3	64.7	75 ppm @ 15% O ₂
	239	708	233	
CO	224	669	221	
	242	724	239	
Mean	235	700	231	2000 ppm @ 15% O ₂
	1721.2	5100.9	1681.3	
voc	1796.9	5369.7	1770.0	
C ₃ - C ₆ + as C ₁	1911.4	5721.5	1885,8	
Mean	1809.8	5397.4	1779.0	750 ppm @ 15% O ₂
Comments:				
	<u></u>			
	 			
				·—·

Crimson Resource Management Taft Area IC Engine 12 North Stack Project 129-3370E November 26, 2003 Permit No. S-48-9-4

		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	191.6	453.7	149.5	
NOx	178.5	410.2	135.2	
	165.3	377.9	124.6	
Mean	178.5	413.9	136.4	75 ppm @ 15% O ₂
	237	561	185	
CO	212	487	161	, i
	217	496	164	
Mean	222	515	170	2000 ppm @ 15% O ₂
	291.7	690.7	227.7	
VOC	342.4	786.8	259.3	
C ₃ - C ₆ + as C ₁	268.7	614.2	202.5	-
Mean	300.9	697.2	229.8	750 ppm @ 15% O ₂
Comments:				
	 			
	<u> </u>			
	<u> </u>			
		1		
	<u> </u>			
	······································			
•	_			·

Crimson Resource Management Taft Area IC Engine 12 South Stack Project 129-3370E November 26, 2003 Permit No. S-48-9-4

	ppm @	ppm @	Permit
ppm	3% O ₂	15% O ₂	Limits
83.9	232.1	76.5	
87.6	240.1	79.1	,
87.1	242.5	79.9	
86.2	238.2	78.5	75 ppm @ 15% O ₂
224	620	204	
218	598	197	
217	604	199	
220	607	200	2000 ppm @ 15% O
454.9	1258.5	414.8	
469.0	1285.7	423.8	
473.3	1317.6	434.4	
465.7	1287.3	424.3	750 ppm @ 15% O ₂
		.,	
· · · · · · · · · · · · · · · · · · ·			
	83.9 87.6 87.1 86.2 224 218 217 220 454.9 469.0 473.3	ppm 3% O ₂ 83.9 232.1 87.6 240.1 87.1 242.5 86.2 238.2 224 620 218 598 217 604 220 607 454.9 1258.5 469.0 1285.7 473.3 1317.6	ppm 3% O ₂ 15% O ₂ 83.9 232.1 76.5 87.6 240.1 79.1 87.1 242.5 79.9 86.2 238.2 78.5 224 620 204 218 598 197 217 604 199 220 607 200 454.9 1258.5 414.8 469.0 1285.7 423.8 473.3 1317.6 434.4

Crimson Resource Management Taft Aera IC Engine 16 Project 129-3370B October 2, 2003 Permit No. S-48-10-4

		ppm @	ppm @	Permit
Pollutant	ppm	3% O ₂	15% O ₂	Limits
	145.9	362.7	119.6	
NOx	128.2	310.1	102.2	
	127.4	304.5	100.4	
Mean	133.8	325.8	107.4	75 ppm @ 15% O ₂
	549	1365	450	
CO	526	1272	419	
	548	1310	432	
Mean	541	1316	434	2000 ppm @ 15% O
	393.8	979.1	322.8	
VOC	403.2	975.4	321.5	
C3 - C6+ as C1	418.2	999.5	329.4	
Mean	405.1	984.7	324.6	750 ppm @ 15% O
Comments:				
			·····	
				 -
<u>v-</u>				