



Pursuant to the authority vested in the Air Resources Board by the Health and Safety Code, Division 26, Part 5, Chapters 1 and 2; and

Pursuant to the authority vested in the undersigned by Health and Safety Code Sections 39515 and 39516 and Executive Order G-02-003;

IT IS ORDERED AND RESOLVED: That the following equipment produced by the manufacturer is certified as described below. Production equipment shall be in all material respects the same as those for which certification is granted.

ENGINE DESCRIPTION			
MANUFACTURER	ENGINE FAMILY (E.O. NUMBER)	ENGINE SIZE (cc)	FUEL TYPE (CNG/LNG=compressed/liquefied natural gas LPG=liquefied petroleum gas)
CUMMINS POWER GENERATION	CN5XS.6532GG (TBC) CN5XS.6532GL (TBC) CN5XS.6532GI (TBC) CN5XS.6532CC (TBC) CN5XS.6532LC (TBC) CN5XS.6532IC (TBC)	653	Gasoline
TBC = To Be Certified			
EQUIPMENT DESCRIPTION			
MODEL YEAR	EVAPORATIVE FAMILY	FUEL TANK SIZE (liters)	EQUIPMENT APPLICATION
2012	CM1035P	See Attachment	Generator Set with Refueling Pump
EMISSION CONTROL SYSTEMS (ECS)		ENGINE and/or EQUIPMENT MODEL	
Canister / Metal		See Attachment	
<small>A. ECS TYPE (Venting Control Type/Tank Barrier Type): 1. Venting Control Type and Code:- Canister=C Sealed Tank=S Other=O 2. Tank Barrier Type and Code:- Metal=M Treated HDPE or PE=P Co-extruded=C Selar=L Nylon=N Acetal=A Other=O B. EVAPORATIVE FAMILY 2-Letter CODE (Venting Control Codes =C, S, O); (Tank Barrier Codes = M, P, C, L, N, A, O). Note: Always list venting control type or code first before tank barrier type or code. Do not use abbreviations for ECS types.</small>			

The following are the evaporative emission standards (Title 13, California Code of Regulations, 13 CCR Section 2754(a) or 2754(b), as applicable), and certification levels in grams per day (g/day) or grams per square meter per day (g/m²/day) or grams per liter (g/l) for this evaporative family or the component Executive Order, as applicable. The running loss emissions control has been demonstrated by the manufacturer.

STANDARD	PERFORMANCE BASED (grams HC/day)		
	EVAPORATIVE FAMILY EMISSION LIMIT DIFFERENTIAL (EFELD)	EVAPORATIVE MODEL EMISSION LIMIT (EMEL)	CERTIFICATION LEVEL
1.20 + 0.056* Tank Vol. (L)	*	*	3.3

BE IT FURTHER RESOLVED: That the evaporative model emission limit (EMEL), as applicable, is the diurnal emissions level declared by the manufacturer based on diurnal test results for a worst-case engine or equipment model within an evaporative family. No engine or equipment emissions within the evaporative family could be closer to its respective standard than the evaporative family emission limit differential (EFELD) calculated from the declared EMEL for the worst-case engine or equipment.

BE IT FURTHER RESOLVED: That the evaporative family emission limit differential (EFELD), as applicable, is an emission level differential between the effective standard level for a specific model representing the entire evaporative family and the EMEL declared for the specific model and it's for use in the averaging and banking program. It serves as the applicable evaporative emission standard for determining compliance on a corporate average basis of any equipment within this evaporative family under 13 CCR Sections 2754.1(e).

BE IT FURTHER RESOLVED: That for the listed equipment, the manufacturer has submitted, and the Executive Officer hereby approves, the information and materials to demonstrate certification compliance with 13 CCR Section 2759 (labeling) and 13 CCR Sections 2760 and 2764 (emission control system warranty).

Equipment certified under this Executive Order must conform to all applicable California emission regulations.

This Executive Order is only granted to the engine family and model-year listed above. Equipment in this family that is produced for any other model-year is not covered by this Executive Order.

Executed at El Monte, California on this 14 day of November 2011.

Annette Hebert, Chief
Mobile Source Operations Division

Small Off-Road Evaporative Certification Database Form
(Supplementary Information)

MODEL SUMMARY

S1. Worst Case (Check One)	S2. Engine or Equipment Model	S3. Sales Codes (check all appropriate)			S4. Engine Class (I or II)	S5. Fuel System (FI or CARB)	S6. Fuel Tank Vol. (Liters)		S7. Fuel Tank Internal Surface Area (m ²)	S8. Fuel Line Type	S9. Nominal Fuel Line Length ⁽¹⁾ (mm)	S10. Fuel Line Inside Diameter (mm)	S11. Exhaust Family	S12. Fuel Tank Executive Order	S13. Fuel Line Executive Order	S14. Carbon Canister or Other Venting Control Executive Order
		CA Only	49-State	50-State			Total	Nominal								
	ST14P			X	II	CARB	52.99	50.34	.8732	Multi Layer	10668	6.35	CN5XS.6532GG CN5XS.6532GL CN5XS.6532GI CN5XS.6532CC CN5XS.6532LC CN5XS.6532IC	Exempt	G-05-018 C-U-07-019 Q-09-022	Q-07-016 Q-07-015B Q-07-014 Q-07-013A
	ST15P			X	II	CARB	68.13	64.72	1.4492	Multi Layer	10668	6.35	CN5XS.6532GG CN5XS.6532GL CN5XS.6532GI CN5XS.6532CC CN5XS.6532LC CN5XS.6532IC	Exempt	G-05-018 C-U-07-019 Q-09-022	Q-07-016 Q-07-015B
	ST16P			X	II	CARB	113.56	107.88	1.9788	Multi Layer	10668	6.35	CN5XS.6532GG CN5XS.6532GL CN5XS.6532GI CN5XS.6532CC CN5XS.6532LC CN5XS.6532IC	Exempt	G-05-018 C-U-07-019 Q-09-022	Q-07-016
	ST17P			X	II	CARB	113.56	107.88	1.9788	Multi Layer	10668	6.35	CN5XS.6532GG CN5XS.6532GL CN5XS.6532GI CN5XS.6532CC CN5XS.6532LC CN5XS.6532IC	Exempt	G-05-018 C-U-07-019 Q-09-022	Q-07-016

	ST19P			X	II	CARB	75.70	71.92	1.4771	Multi Layer	10668	6.35	CN5XS.6532GG CN5XS.6532GL CN5XS.6532GI CN5XS.6532CC CN5XS.6532LC CN5XS.6532IC	Exempt	G-05-018 C-U-07-019 Q-09-022	Q-07-016 Q-07-015B
	ST20P			X	II	CARB	98.42	93.50	1.8116	Multi Layer	10668	6.35	CN5XS.6532GG CN5XS.6532GL CN5XS.6532GI CN5XS.6532CC CN5XS.6532LC CN5XS.6532IC	Exempt	G-05-018 C-U-07-019 Q-09-022	Q-07-016
	ST21P			X	II	CARB	113.56	107.88	1.9788	Multi Layer	10668	6.35	CN5XS.6532GG CN5XS.6532GL CN5XS.6532GI CN5XS.6532CC CN5XS.6532LC CN5XS.6532IC	Exempt	G-05-018 C-U-07-019 Q-09-022	Q-07-016
X	ST22P			X	II	CARB	113.56	107.88	2.4805	Multi Layer	10668	6.35	CN5XS.6532GG CN5XS.6532GL CN5XS.6532GI CN5XS.6532CC CN5XS.6532LC CN5XS.6532IC	Exempt	G-05-018 C-U-07-019 Q-09-022	Q-07-016
	ST24P			X	II	CARB	90.8498	86.31	1.7558	Multi Layer	10668	6.35	CN5XS.6532GG CN5XS.6532GL CN5XS.6532GI CN5XS.6532CC CN5XS.6532LC CN5XS.6532IC	Exempt	G-05-018 C-U-07-019 Q-09-022	Q-07-016 Q-07-015B

(1) The nominal fuel line lengths can be grouped into increment of ± 3 inches (76 mm)