

Pursuant to the authority vested in the Air Resources Board by the Health and Safety Code, Division 26, Part 5, Chapters 1 and 2; and

Pursuant to the authority vested in the undersigned by Health and Safety Code Sections 39515 and 39516 and Executive Order G-02-003;


IT IS ORDERED AND RESOLVED: That the following equipment produced by the manufacturer is certified as described below.

ENGINE DESCRIPTION			
MANUFACTURER	ENGINE FAMILY (E.O. NUMBER)	ENGINE SIZE (cc)	FUEL TYPE <small>(CNG/LNG=compressed/liquefied natural gas LPG=liquefied petroleum gas)</small>
KOHLER POWER SYSTEMS	DKGXS.6742GA (U-U-035-0072)	674	Gasoline
EQUIPMENT DESCRIPTION			
MODEL YEAR	EVAPORATIVE FAMILY	EQUIPMENT APPLICATION	
2013	DKGXSOOAAAAA	Generator Set	
EQUIPMENT MODELS	5EKD, 7.5EKD, 10EKD		
*=not applicable	FUEL HOSE PERMEATION		
STANDARD (g/m ² /day)	CERTIFICATION LEVEL (g/m ² /day)	COMPONENT EXECUTIVE ORDER	
15	*	G-05-018	

BE IT FURTHER RESOLVED: That the aforementioned equipment is exempt, pursuant to 13 CCR Section 2766(c), equipment (generators) fueled by a vehicle fuel tank, from diurnal emissions requirements in section 2754(a) and fuel tank permeation and carbon canister requirements in section 2754(b). However, the aforementioned equipment must use fuel hose that meets the design requirements specified in section 2754(b).

This Executive Order is only granted to the equipment models and model-year listed above. Equipment that is produced for any other model-year is not covered by this Executive Order.

Executed at El Monte, California on this 21 day of Decemberr 2012.



Annette Hebert, Chief
Mobile Source Operations Division